

From: Pettit, Tracy@DWR

Sent: Tuesday, June 23, 2015 5:17 PM

To: Howard, Tom; Evoy, Barbara@Waterboards; Grober, Les@Waterboards; Riddle, Diane@Waterboards; Fernandez, Patricia@Waterboards; Rico, Christine@Waterboards; George, Michael@Waterboards

Cc: Leahigh, John@DWR; Pettit, Tracy@DWR; Hinojosa, Tracy@DWR; Yamanaka, Dan@DWR; Ford, John@DWR; Mizell, James@DWR; RMILLIGAN@usbr.gov; pfujitani@usbr.gov; ekiteck@usbr.gov; rsahlberg@usbr.gov; Aufdemberge, Amy (Email); ngmplcs@pacbell.net; E-mail:; tshephard@neumiller.com; Herrick, John @aol.com; Masier, Guy@DWR; Miller, Aaron@DWR; Chu, Andy@DWR; Giorgi, Bryant@DWR

Subject: Notification of Exceedance of One of the South Delta Objectives

Dear Mr. Howard,

Pursuant to our January 24, 2013, letter "Protocol to Provide Earlier Notification to the State Water Resources Control Board and Partner Fisheries Agencies", this email serves as notification that the 30-day running average EC value at Old River near Middle River exceeded 0.7 mmhos/cm beginning Friday, June 19, 2015. The 30-day average value reached 0.8 mmhos/cm on that day.

Water quality information can be found on the Department of Water Resources' website at the following link: <http://wwwdwr.water.ca.gov/swp/operationscontrol/deltaops.cfm>.

A formal notification letter is forthcoming. Please let me know if you have any questions.

Take care.

Tracy

Tracy Pettit-Polhemus, P.E.
SWP Operations Control Office
Department of Water Resources
Phone: (916) 574-2662
Fax: (916) 574-2785
Tracy.Pettit@water.ca.gov