

PETITION OF CALIFORNIA SPORTFISHING PROTECTION ALLIANCE (WASTE DISCHARGE REQUIREMENTS ORDER NO. R5-2007-0134[NPDES NO. CA0079260] FOR CITY OF YUBA CITY WASTEWATER TREATMENT PLANT) DRAFT ORDER, Dated October 6, 2008

On page 5 :

Delete the second sentence of the last paragraph:

~~If the dilution model results are based on 40 open ports, the effluent limitations in the Permit must be revised to be consistent with the dilution that can be achieved through the diffuser maintenance requirements of a minimum of 25 open ports.~~

Replace the sentence with:

If the dilution model results are based on 40 open ports, the effluent limitations in the Permit may not be adequately protective because the Permit only requires that 25 ports be kept open. The permit must be revised either: (1) to include effluent limitations that are protective in all conditions when 25 ports are open; or (2) to require maintaining up to 40 ports open when necessary to achieve adequate dilution.

On page 10:

Add the following sentence to Order #2:

2. Confirm whether the dilution model results are based on 25 or 40 open ports. **Based on this determination, revise the permit to ensure that maintenance requirements and/or effluent limitations are protective of beneficial uses.**

Delete Order #3:

~~If the dilution model results are based on 40 open diffuser ports, revise the effluent limitations in the Permit to be consistent with the dilution that can be achieved through the diffuser maintenance requirements of a minimum of 25 open ports.~~

Renumber the following order numbers.