California Regional Water Quality Control Board
Central Coast Region

Linda S. Adams
Secretary for Environmental Protection

Internet Address: http://www.waterboards.ca.gov/centralcoast
895 Aerovista Place – Suite 101, San Luis Obispo, CA 93401-7906
Phone (805) 549-3147 • FAX (805) 543-0397

Arnold Schwarzenegge
Governor

May 29, 2007

Mr. Richard McClure
Olin Corporation
Environmental Remediation Group
P.O. Box 248
Charleston, TN 37310-0248

Dear Mr. McClure:

SITE CLEANUP PROGRAM: 425 TENNANT AVENUE, MORGAN HILL; RESPONSE TO OLIN'S MAY 7, 2007 REPLACEMENT WATER MONITORING FREQUENCY REVISION REQUEST

Central Coast Regional Water Quality Control Board staff reviewed your May 7, 2007, request for concurrence to revise the sampling frequency for six wells from bimonthly to semiannual. The request for revised sampling frequencies is made in accordance with State Water Resources Water Quality Control Board (State Water Board) Order WQ-2005-0007 and our letters dated October 6, and December 8, 2006.

After replacement water (e.g., bottled water) service has been terminated, with concurrence of the Central Coast Water Board's Executive Officer, the monitoring requirements described in our letter dated October 6, 2006, must be implemented. The Executive Officer must approve the post-bottled water termination monitoring frequency for each well before the monitoring frequency is implemented.

In accordance with State Water Board Order WQ-2005-0007 and our letter dated October 6, 2006, Olin may change the monitoring frequency of a well from bimonthly to semiannually if:

1. The well had a perchlorate concentration less than 6.0 micrograms per liter during the last sampling event before bottled water was terminated, and
2. The well has been sampled bimonthly for eight months or four sampling events, and there is a stable, decreasing, or probably decreasing trend in perchlorate concentrations.

Central Coast Water Board staff reviewed Tables 1 through 3 of Olin's May 7, 2007 letter and the associated laboratory and quality control reports for the perchlorate concentration data. Central Coast Water Board staff concurs that Olin may sample the following wells semiannually:

10S03E01G005
10S03E01K015
10S03E12G005
10S04E18K010
10S04E18Q009
10S04E19D008

Thank you for continuing to provide the requests for changes in post bottled water monitoring frequencies in writing and providing the supporting information in electronic format. If you have any questions, please contact **Thea Tryon at (805) 542-4776**, Hector Hernandez at (805) 542-4641, or Harvey Packard at (805) 542-4639.

Sincerely,

Roger W. Briggs
Executive Officer

S:\Site Cleanup Program\Regulated Sites\Santa Clara Co\OLIN Corp\Water Board\Bottled Water Termination\Mon Freq Revisions\5-7-07\0507 Post BW Mon Freq Req.doc

cc via mail
Well users

cc vía E-mail:
Ms. Lori Okun
Office of the Chief Counsel
State Water Resources Control Board

Olin Correspondence IPL