

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
CENTRAL VALLEY REGION

ORDER NO. R5-2013-0033

RESCISSION OF

TIME SCHEDULE ORDER R5-2007-0114
FOR
CITY OF LODI
WHITE SLOUGH WATER POLLUTION CONTROL FACILITY
SAN JOAQUIN COUNTY

The California Regional Water Quality Control Board, Central Valley Region, (hereafter referred to as Central Valley Water Board) finds that:

1. The City of Lodi (Discharger) owns and operates the White Slough Water Pollution Control Facility. The Discharger is regulated under Waste Discharge Requirements Order R5-2007-0113 (NPDES No. CA0079243).
2. On 14 September 2007, the Central Valley Water Board adopted Time Schedule Order (TSO) R5-2007-0114. The TSO required full compliance with manganese, nitrate, and nitrite effluent limitations by 18 May 2010.
3. As of 1 January 2010, the Discharger had achieved compliance with the manganese, nitrate, and nitrite effluent limitations after constructing nitrification-denitrification improvements to the treatment plant and modifying its use of chemical coagulants.
4. The Central Valley Water Board has notified the Discharger and interested agencies and persons of its intent to rescind Order R5-2007-0114, and has provided them with an opportunity for a public hearing and an opportunity for them to submit their written views and recommendations.
5. Issuance of this Order is exempt from the provisions of the California Environmental Quality Act (Public Resources Code section 21000 et seq.), in accordance with California Code of Regulations, title 14, section 15321(a) (2).
6. The Central Valley Water Board, in a public meeting, heard and considered all comments and evidence pertaining to this matter.

IT IS HEREBY ORDERED that Time Schedule Order R5-2007-0114 is rescinded.

I, PAMELA C. CREEDON, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Central Valley Region, on 12 April 2013.

PAMELA C. CREEDON, Executive Officer