

**San Andreas Sanitary District Tentative Order Review – Attachment A**

Page	Section	Comment
F-24	IV.C.3.f	<p>“The maximum average upstream receiving water aluminum concentration was 7 µg/L, based on two samples...”</p> <p>The correct value is 11 µg/L as correctly shown in the Summary of Reasonable Potential Analysis (Attachment G).</p>
F-27	IV.C.3.h	<p>“Studies conducted by the Discharger indicate that the use of intravenous (IV) bags at the local convalescent home and hospital is the source of bis(2-ethylhexyl)phthalate at the Facility.”</p> <p>This statement should be removed or revised. Bis(2-ethylhexyl)phthalate source investigation studies have not conclusively identified all sources.</p>
F-30	IV.C.3.m	<p>Last paragraph. “...to assure compliance with ammonia effluent limitations.”</p> <p>Should read “diazinon” not “ammonia”.</p>
F-31	IV.C.3.n	<p>Last paragraph. “...based on based on the CTR criterion...”</p> <p>Remove one “based on”.</p>
F-57	VI.E.2.a	<p>“This Order requires the Discharger to monitor quarterly for effluent conductivity and total dissolved solids in the municipal water supply...”</p> <p>“effluent” should be removed from sentence.</p>