

ITEM: 25  
SUBJECT: City of Lincoln, Wastewater Treatment and Reclamation Facility  
BOARD ACTION: Consideration of Resolution Amending Time Schedule Order No. R5-2008-0157

BACKGROUND: The City of Lincoln (Discharger) owns the City of Lincoln Wastewater Treatment and Reclamation Facility. The regional facility discharges tertiary treated wastewater to the Auburn Ravine, tributary to the Sacramento River via the East Side Canal and Cross Canal.

On 23 October 2008, the Regional Water Quality Control Board adopted Time Schedule Order (TSO) No. R5-2008-0157, granting the Discharger a time schedule for compliance with the final monthly average copper effluent limitation in Waste Discharge Requirements (WDR) Order No. R5-2008-0156. A performance-based interim copper effluent limitation of 4.7 ug/L, determined using statistical methodology, was included in the TSO. The interim copper limitation, however, was discovered to be erroneous because it is less (more stringent) than the final maximum daily copper limitation of 7.0 ug/l in the adopted WDR Order. The proposed Resolution amends the TSO to reflect the correct interim copper limitation of 7.0 ug/L as a maximum daily limit.

ISSUES: None

Mgmt. Review \_\_\_\_\_  
Legal Review \_\_\_\_\_  
23/24 April 2009  
11020 Sun Center Dr. #200  
Rancho Cordova, CA 95670