

From: Dean Brown <deanb@tejonranch.com>
To: Denise Soria <Dsoria@waterboards.ca.gov>
CC: "Dixon, Darrel" <darrel.dixon@stantec.com>
Date: 6/14/2011 4:54 PM
Subject: 20110614 - Missed comment to draft order c-3 page 13

Denise-

We have a little oversight. If you noticed in our comments to you as well as CDPH (on their comments to you on the Draft Order) we expressed that the plant does not monitor or control based on transmittance. The system utilizes turbidity meters and UV intensity is monitored by a UV sensor. UV intensity is a function of transmittance.

We intended on striking item C-3 on page 13 and replacing it with new language that is in line with plant controls and operations. How can we get this taken care of and not impact the August hearing date???

Dean