

LATE REVISIONS – 6 February 2014

Item 7 City of Clovis, Clovis Sewage Treatment and Water Reuse Facility, Fresno County– Consideration of NPDES Permit Renewal (NPDES CA0085235)

NPDES Order

Page 33 Revise Special Provision VI.C.5.c. as follows:

- c. Collection System.** On 2 May 2006, the State Water Board adopted State Water Resources Control Board Order No. 2006-0003-DWQ, Statewide General Waste Discharge Requirements (WDRs) for Sanitary Sewer Systems. The Discharger shall be subject to the requirements of Order No. 2006-0003-DWQ and any future revisions thereto. Order No. 2006-0003-DWQ requires that all public agencies that currently own or operate sanitary sewer systems apply for coverage under the general WDRs. The Discharger has applied for and has been approved for coverage under Order 2006-0003-DWQ for operation of its wastewater collection system.

~~Regardless of the coverage obtained under Order 2006-0003-DWQ, the Discharger's collection system is part of the treatment system that is subject to this Order. As such, pursuant to federal regulations, the Discharger must properly operate and maintain its collection system [40 CFR 122.41(e)], report any non-compliance [40 CFR 122.41(l)(6) and (7)], and mitigate any discharge from the collection system in violation of this Order [40 CFR 122.41(d)].~~

Fact Sheet

Page F-51 Revise Section IV.C.3.d.ii.(b). as follows:

The beneficial uses of both Fancher Creek and the Diversion Channel include water contact recreation and agricultural irrigation supply. The beneficial uses of Little Dry Creek include municipal and domestic supply, water contact recreation, and agricultural irrigation supply. To protect these beneficial uses, the Central Valley Water Board finds that the wastewater must be disinfected and adequately treated to prevent disease. Although the Discharger provides disinfection, inadequate or incomplete disinfection creates the potential for pathogens to be discharged and provides the basis for the discharge to have a reasonable potential to cause or contribute to an exceedance of the Basin Plans' narrative toxicity water quality objective. Therefore, the Central Valley Water Board finds the discharge has reasonable potential for pathogens and WQBELs are required.