



Stantec Consulting Services Inc.  
3875 Atherton Road  
Rocklin CA 95765  
Tel: (916) 773-8100  
Fax: (916) 773-8448

December 9, 2013  
File: 184030087

**Attention: Ms. Gayleen Perreira**  
California Regional Water Quality Control Board  
Central Valley Region  
11020 Sun Center Drive #200  
Rancho Cordova, CA 95670

Dear Galyeen,

**Reference: City of Lincoln WWTRF Tentative Order Comments**

The purpose of this letter is to provide comments on the City of Lincoln Wastewater Treatment and Reclamation Facility (WWTRF) Tentative Order. We are in support of the Tentative Order, and have only the following minor comments.

- **Page 6 (IV.A.2.e.ii)** – The mercury mass limit is incorrectly shown as 0.0234 pounds per month. The correct mercury mass limit is 0.0238 pounds per month ( $0.022$  [City of Lincoln] +  $0.0018$  [Placer County SMD-1] = 0.0238 pounds per month).
- **Table E-8** – We believe the word “average” was inadvertently left out of footnote #3. For clarity, footnote #3 should read “Report daily minimum hourly average dose...”.
- **Table F-1** – Mark Miller is no longer the Director of Public Services. Michael Kashiwagi, Interwest Consulting, is the City’s Interim Director of Public Services.
- **Page F-4 (II.A)** – The statement that “Sludge is anaerobically digested...” is not correct. Sludge is not digested at the WWTRF.
- **Table F-3** – Footnote #3 should be corrected to reflect the correct mercury mass limit of 0.0238 pounds per month.



December 9, 2013  
Ms. Gayleen Perreira  
Page 2 of 2

Please feel free to contact me if you have any questions or would like to discuss further the foregoing comments.

Regards,

**STANTEC CONSULTING SERVICES INC.**

A handwritten signature in cursive script that reads "Stephen Gittings".

Stephen Gittings  
Chief Plant Operator  
Phone: (916) 434-5062  
Stephen.Gittings@stantec.com

- c. Michael Kashiwagi, City of Lincoln Interim Director of Public Services
- Robert Emerick, Stantec Consulting Services
- Eric Zeigler, Stantec Consulting Services