

ITEM: 38

SUBJECT: Mariposa Public Utility District, Mariposa Wastewater Treatment Facility,
Mariposa County

BOARD ACTION: *Consideration of Amendment to Time Schedule Order*

BACKGROUND: Mariposa Public Utility District (District) owns and operates a wastewater treatment facility (Facility) which provides sewerage service for the community of Mariposa and serves a population of approximately 2,000. The Facility currently provides secondary treatment with chlorine disinfection and is authorized to discharge up to 610,000 gallons a day to Mariposa Creek, a water of the United States. The discharge to Mariposa Creek is regulated by Waste Discharge Requirements (WDRs) Order R5-2014-0042 (NPDES Permit No. CA0079430). Time Schedule Order (TSO) R5-2014-0043 includes time schedules for the District to meet final effluent limitations by 18 May 2015 for dichlorobromomethane and 4 December 2017 for chlorodibromomethane, nitrate plus nitrite (as N), and total trihalomethanes. The District requested an extension for meeting the final effluent limitations for dichlorobromomethane and provided information regarding the progress made toward compliance.

The proposed Order amends TSO R5-2014-0043 to extend the time schedule for complying with the final effluent limitations for dichlorobromomethane to 18 May 2020.

Adopt the order to amend the Time Schedule Order

RECOMMENDATION:

Mgmt. Review _____

Legal Review _____

16/17 April 2015 Central Valley Water Board Meeting
1685 E Street
Fresno, CA 93706