

## Palmer, Joshua@Waterboards

---

**From:** Tim Shaw <opudmgr@opud.org>  
**Sent:** Monday, January 04, 2016 3:39 PM  
**To:** Palmer, Joshua@Waterboards  
**Cc:** Taylor, Brian@Waterboards; Serratos, Alejandra@Waterboards; Sherry Mills; John Tillotson; Rob Price  
**Subject:** FW: Olivehurst WWTF Tentative Order Posting  
**Importance:** High

Mr. Palmer:

We have a concern about our tentative order. Specifically, the monitoring and reporting requirements for Total Coliform monitoring are apparently inconsistent with one another. One section (page E-5) requires monitoring twice/week, which is consistent with our current order. A new section (page E-9) stipulate daily monitory for Total Coliform.

I have also attempted to call you, but my call went to voicemail.

<b>Priority Pollutants</b>	
Mercury, Total Recoverable	ng/L
Priority Pollutants and Other Constituents of Concern	See Section IX.D
<b>Non-Conventional Pollutants</b>	
Ammonia Nitrogen, Total (as N)	mg/L
Electrical Conductivity @ 25°C	µmhos/cm
Hardness, Total (as CaCO <sub>3</sub> ) <sup>7</sup>	mg/L
Nitrate Nitrogen, Total (as N)	mg/L
Nitrite Nitrogen, Total (as N)	mg/L
Nitrate plus Nitrite (as N)	mg/L
Total Coliform Organisms	MPN/100 mL
Total Dissolved Solids	mg/L
Temperature	°C

<sup>1</sup> Pollutants shall be analyzed using the analytical

## Table E-7. Filtration System and UV Disin

Parameter	Units	Sample
Flow	MGD	Met
Turbidity	NTU	Met
UV Transmittance	Percent (%)	Met
Total Coliform Organisms	MPN/100mL	Gra

*Tim Shaw*

General Manager  
Olivehurst Public Utility District  
(530) 743-0317  
[opudmgr@opud.org](mailto:opudmgr@opud.org)

*Our mission is to provide high quality services to enhance our community's quality of life.*

---

**From:** Palmer, Joshua@Waterboards [<mailto:Joshua.Palmer@waterboards.ca.gov>]

**Sent:** Friday, December 04, 2015 2:57 PM

**To:** Rob Price <[rprice@opud.org](mailto:rprice@opud.org)>

**Cc:** Taylor, Brian@Waterboards <[Brian.Taylor@waterboards.ca.gov](mailto:Brian.Taylor@waterboards.ca.gov)>

**Subject:** Olivehurst WWTF Tentative Order Posting

Rob,

Please find the Notice of Public Hearing, Tentative Order, Proof of Posting, and Cover Letter with posting instructions attached. Please let me know if you have any questions. The original documents have been sent by mail.

Thanks,

Josh

Josh Palmer, P.E.  
Senior Water Resource Control Engineer  
Sacramento Point Source Permitting Unit  
Central Valley Water Board  
(916) 464-4674

[Spam](#)

[Phish/Fraud](#)

[Not spam](#)

[Forget previous vote](#)