



CALAVERAS COUNTY WATER DISTRICT

120 Toma Court • Post Office Box 846 • San Andreas, CA 95249 • Main Line (209) 754-3543

June 28, 2016

James D. Marshall, P.E.
Senior Engineer
California Regional Water Quality Control Board
Central Valley Region
11020 Sun Center Drive #200
Rancho Cordova, CA 95670

RE: NOTICE OF PUBLIC HEARING AND TENTATIVE ORDER AMENDING WASTE DISCHARGE REQUIREMENTS ORDER R5-2013-0072 (NPDES PERMIT NO. CA0084620 AND RECINDING TIME SCHEDULE ORDER R5-2012-0055 FOR CALAVERAS COUNTY WATER DISTRICT AND SADDLE CREEK GOLF COURSE L.P. COPPER COVE WASTEWATER RECLAMATION FACILITY CALAVERAS COUNTY

Dear Mr. Marshall,

The District would like to make the following corrections to the Amending Waste Discharge Requirements Order R5-2013-0072:

1. Page 1, item 3, 1st paragraph, 7th line: 25 acres of spray irrigation fields: Should be, 35 acres per our WDR R5-2010-007.
2. Page 1, item 3, 2nd paragraph, 1st line: During the summer, typically June through August: Should be, During the seasonal discharge period, typically April 1st through November and sometimes in December.
3. Page 1, item 3, 3rd paragraph, lines 2-4: The Facility typically only conveys tertiary treated wastewater to Pond NC-2D for about 3 months during the summer, because the golf course demand for irrigation water exceeds the supply of reclaimed water: Should read, The Facility typically starts to convey tertiary treated wastewater to Pond NC-2D starting April 1st and does so until Pond 6 is empty and will treat as flow comes in from the biological plant through the remainder of the year.
4. Page 3, item 2, letter C, 2nd paragraph, line 8: irrigation on CCWD's 25 acres: Should be in reference to item 1 of this letter.
5. Page 4, still under item 2, letter C, 3rd paragraph, line 1: During the summer, typically June through August: Should be in reference to item 2 of this letter.
6. Page 9, item A, 1st paragraph, line 8: irrigation on CCWD's 25 acres: Should be in reference to item 1 of this letter.
7. Page 9, item A, 2nd paragraph, line 1: During the summer, typically July through August: Should be in reference to item 2 of this letter.
8. Page 9, item A, 3rd paragraph, line 2: CCWD Typically only discharges to Pond NC-2D for 3 months: Should be in reference to item 3 of this letter.

If there are any questions about the changes listed above, please feel free to contact me at
(209) 754-3316

Sincerely,

CALAVERAS COUNTY WATER DISTRICT



Jesse Hampton, Plant Operations Manager