

**Exhibit B**  
Status of Solutions for Kern Systems with Nitrate Exceedances

Water System Name	Population Served <sup>1</sup>	No. of Connections <sup>2</sup>	Number of Exceedances				Most recent NO <sub>3</sub> conc. <sup>1</sup> , ppm NO <sub>3</sub>	Compliance Period <sup>1</sup>	Solutions Identified <sup>2</sup>
			2005-2007	2008-2010	2011	2012			
Anthony Vineyard Water System	104	8	6	11	3	3	50		Handwashing permit recently revoked due to changing regulations. Bottled water currently provided, POU with RO being considered.
Arvin Community Services District	14,713	3,536	2	2					Issue resolved, as affected well is offline. Replacing when funds are available.
Brock Mutual WC <sup>3</sup>	500	155		2					Consolidating with Vaughn Water Co. Well
East Wilson Road Water Company	35				4	1	54	1st Qtr 2012	Connection to East Niles CSD. They got a planning grant and are extending a pipeline and will abandon affected wells.
Enos Lane Public Utility District	270	82	1				52.1	2nd Qtr 2007	Options: Nitrate blending treatment <b>OR</b> consolidate w Vaughn Water Co.
Farmer John Egg Ranch #2	30	6	3	10	4	6	97	2nd Qtr 2012	Bottled water provided until permanent solution determined
Golden State Vintners-Franzia McFarland	35	1	11	8	4	3	85.6		Recently had handwashing permit revoked due to changing regulations. Bottled water provided as interim solution
Gooselake Water Company	80	32		1			48.3	4th Qtr 2008	Options: Drill 2nd well <b>OR</b> consolidate w nearby water system.
Grimmway Farms Frozen Foods <sup>4</sup>	300	7				3	54	3rd Qtr 2012	Solution being identified.
Heck Cellars Water System	45	8	5	8		3	60	2nd Qtr 2012	Bottled water provided until permanent solution determined
I & I Farms Inc.	50		1		3	1	74	1st Qtr 2012	RO treatment (assumed)
Murray Family Farms Fruit Stand	50			1		1	50	1st Qtr 2012	RO treatment (assumed)
Orange Grove RV Park <sup>3</sup>	200	180	2						Considering connection to East Niles CSD.
San Joaquin Estates Mutual Water Co	165				2	1	57	1st Qtr 2012	Options: Consolidate w East Niles, drill new well, <b>OR</b> treat water
Seventh Standard Mutual	66	22	2	2	1	1	46	1st Qtr 2012	Install water delivery pipeline & new lines & meters to residents. Consolidating with Oildale Mutual.

**Exhibit B**  
**Status of Solutions for Kern Systems with Nitrate Exceedances**

Water System Name	Population Served <sup>1</sup>	No. of Connections <sup>2</sup>	Number of Exceedances				Most recent NO <sub>3</sub> conc. <sup>1</sup> , ppm NO <sub>3</sub>	Compliance Period <sup>1</sup>	Solutions Identified <sup>2</sup>
			2005-2007	2008-2010	2011	2012			
Son Shine Properties	500	106		2	1		49	4th Qtr 2011	Consolidation with Arvin CSD pending.
Sun Pacific Shippers - Maricopa Water Sys	350				2	1	48	1st Qtr 2012	RO treatment (assumed)
Sun World International, Inc. Com Center	80	6	9	9	2	5		2nd Qtr 2012	Bottle water provided until permanent solution determined
Sunview Cold Storage Water System	130	4	8						RO treatment provided since 2006
Sycamore Canyon Golf Course	400	1	10	3	3	4	47	2nd Qtr 2012	Bottle water provided currently for purchase. Potential connection with Arvin CSD for solution
Wheeler Farms Headquarters	25	13			4	1	140	1st Qtr 2012	RO treatment (assumed)
Wilson Road Water Community	72			3	4	1	76	1st Qtr 2012	Options: water treatment or intertie with East Niles CSD
<b>Total Exceedance by Year</b>			<b>54</b>	<b>51</b>	<b>34</b>	<b>32</b>			

<sup>1</sup> Information from database search on EPA's SDWIS website ([http://oaspub.epa.gov/enviro/sdw\\_form\\_v2.create\\_page?state\\_abbr=CA](http://oaspub.epa.gov/enviro/sdw_form_v2.create_page?state_abbr=CA))

<sup>2</sup> Information from database search from CA Dept. of Public Health for unincorporated water systems

<sup>3</sup> Water system added from database search from CA Dept. of Public Health for incorporated water areas

<sup>4</sup> Grimmway Farms exceedance occurred late in 2012 and a compliance order has just been sent to them