

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 77-12

WASTE DISCHARGE REQUIREMENTS
FOR
SHACKLETT CAMPER CORRAL
Northwest of Indio - Riverside County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. S. W. Shacklett (hereinafter also referred to as the discharger), 34-225 Washington Street, Indio, California 92201, submitted a Report of Waste Discharged dated December 3, 1976.
2. The discharger proposes to discharge a maximum average of 20,000 gallons-per-day of domestic sewage from a recreational vehicle park designed to have 152 spaces. The wastewater is to be discharged through 14 septic tanks and 28 seepage pits located in the N $\frac{1}{2}$, NE $\frac{1}{4}$, NE $\frac{1}{4}$ of Section 25, T4S, R6E, SBB&M.
3. The discharger has reserved areas of sufficient size for 100% replacement for each of the seepage pits. These areas are designated on Attachment "A" incorporated herein and made a part of this Order.
4. The Water Quality Control Plan for the West Colorado River Basin was adopted by the Board on April 10, 1975, and this Order implements the objectives stated in the Plan.
5. The beneficial uses of the groundwaters of the Coachella Hydrologic Subunit are:
 - a. Municipal supply
 - b. Industrial supply
 - c. Agricultural supply
6. The Board has notified the discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the proposed discharge.
7. The Board in a public meeting heard and considered all comments pertaining to the proposed discharge.

Rescinded
5/16/84

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications

1. Neither the treatment nor the discharge of wastewater shall cause a pollution or a nuisance.
2. No wastewater other than domestic sewage shall be discharged at this location.
3. Sewage effluent discharged subsurface shall be retained underground with no materials of sewage origin evident on the ground surface.
4. There shall be no discharge of sewage within 200 feet of any water supply well.
5. Adequate protective works shall be provided to assure that flood or surface drainage waters do not erode or otherwise render portions of the treatment and discharge facilities inoperable.
6. Septic tank cleanings shall be discharged only by a duly authorized service.

B. Provisions


1. As represented in Finding No. 3, above, said sewage disposal site shall at all times be retained servient to this recreational vehicle park, for the purpose of providing additional subsurface sewage disposal capacity, until such time as this park is connected to a municipal sewerage system.
2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of waste.
3. Prior to any modifications in this facility which would result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.

4. Prior to any proposed change in operation, or in control or ownership of the land upon which the discharge facilities are located, the discharger shall report in writing to the Regional Board.
5. Prior to any future sale of this recreational vehicle park, the discharger shall:
 - a. Specify as a condition of sale that said sewage disposal site must remain servient to the park, for the purpose of providing additional subsurface sewage disposal capacity, until such time as this recreational vehicle park is connected to a municipal sewerage system.
 - b. Notify the succeeding owner, in writing, of the existence of this Order, and forward a copy of said correspondence to the Regional Board.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on

January 26, 1972.

Arthur Swajian
Executive Officer



SITE MAP
FOR
SHACKLETT CAMPER CORRAL
 Northwest of Indio - Riverside County
 N $\frac{1}{2}$, NE $\frac{1}{4}$, NE $\frac{1}{4}$, of Section 25, T4S, R6E, SBB&M
 U.S.G.S. Thousand Palms 15 min. Topographic Map

Order No. 77-12

ATTACHMENT "A"
ORDER NO. 77-12

ACKLETT CAMPER CORRAL

No Swimming Pool.

Sewer lines, septic tanks, and seep pits shown as solid lines.

Reserve seep pits and lines shown as dotted lines.

Arc at upper right hand corner indicates a 200' radius from existing well.

From the North west corner of the property to the North east corner there is an eleven foot fall and from the North west corner to the South west corner there is a six foot fall.

Reduced Scale
1" = 160'

