

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

ORDER NO. 78-48

WASTE DISCHARGE REQUIREMENTS
FOR
BOB'S PLAYA RIVIERA
North Shore of Salton Sea - Imperial County

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. Bob Granillo, (hereinafter also referred to as the discharger), 10-565 Hwy. 111, North Shore, CA 92254, submitted updated information on the discharge of waste on February 27, 1978.
2. The discharger is discharging an average of about 3,600 gallons-per-day of domestic sewage from a travel trailer park consisting of 20 travel trailer spaces, two restrooms, a house, and laundry facilities. An additional 180 travel trailer spaces are to be constructed in phases which would produce a total discharge of 30,000 gallons-per-day. The wastewater is to be discharged through septic tanks into leach fields located in the N $\frac{1}{2}$ of the NW $\frac{1}{4}$ of Section 4, T9S, R11E, SBB&M. The existing septic tank/leach field system is approximately 25 feet from the present water line of the Salton Sea.
3. The discharger has reserved an area of sufficient size for 100% replacement of the leach fields. This area is designated on Attachment "A" incorporated herein and made a part of this Order.
4. The discharge from this travel trailer park has been subject to waste discharge requirements adopted in Board Order No. 72-1.
5. The Water Quality Control Plan for the West Colorado River Basin was adopted by the Board on April 10, 1975. The Basin Plan contains water quality objectives for the Imperial Hydrologic Unit.
6. Shallow groundwaters at the discharge location are saline and are not beneficially used.

*Suspended
May 8-59*

7. The discharger states that depth to groundwater in the discharge area is about 10 feet.
8. The Board has notified the discharger and interested agencies and persons of its intent to update waste discharge requirements for the discharge.
9. The Board in a public meeting heard and considered all comments pertaining to the discharge.
10. The Imperial County Planning Department has prepared Negative Declaration EA776-78 (filing date April 26, 1978) for the proposed expansion of this park. This assessment states that this project will not have any significant adverse effects on the environment.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications

1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage shall be discharged at this location.
3. Wastewater discharged subsurface shall be retained underground with no surfacing.
4. There shall be no installation of wastewater disposal facilities within 200 feet of the water line of the Salton Sea.
5. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
6. Septic tank cleanings shall be discharged only by a duly authorized service.

B. Provisions


1. The area reserved for 100% replacement of the leach fields, as shown on Attachment "A", shall at all times be retained servient to this travel trailer park, for the purpose of providing additional subsurface sewage disposal capacity, until such time as this park is connected to a municipal sewerage system.

2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of waste.
3. Prior to any modifications in this facility which would result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.
4. Prior to any future change of ownership of this travel trailer park, the discharger shall:
 - a. Specify as a condition of transfer that said sewage disposal and replacement areas must remain servient to the park, for the purpose of providing additional subsurface sewage disposal capacity, until such time as this park is connected to a municipal sewerage system.
 - b. Notify the succeeding owner, in writing, of the existence of this Order, and forward a copy of said correspondence to the Regional Board.
5. This Order supersedes Board Order No. 72-1.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on May 10, 1978.




Executive Officer



SITE MAP

BOB'S PLAYA RIVIERA
North Shore of Salton Sea - Imperial County
N $\frac{1}{2}$, NW $\frac{1}{4}$ of Section 4, T9S, R11E, SBB&M
U.S.G.S. Durmid 7.5 min. Topographic Map

Order No. 78-48



ATTACHMENT "A"

BOB'S PLAYA RIVIERA
North Shore of Salton Sea - Imperial County