

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

ORDER NO. 84-46

**WASTE DISCHARGE REQUIREMENTS
FOR
INDIAN WELLS R.V. ROUND UP
West of Indio - Riverside County**

The California Regional Water Quality Control Board, Colorado River Basin Region, finds that:

1. W.D. Associates (hereinafter also referred to as the discharger), 3600 Segerstrom Avenue, Santa Ana, California 92704, submitted an updated report of waste discharge, dated January 10, 1984.
2. The discharge from this recreational vehicle park has been subject to waste discharge requirements adopted in Board Order No. 77-92. This Order is updated for a separation of ownership of the mobile home park from the RV park.
3. The discharger is discharging a maximum of 53,000 gallons-per-day of domestic sewage from a recreational vehicle park consisting of 391 R.V. spaces, three laundry rooms, and eight restrooms. Wastewater is discharged into septic tank/seepage pit disposal systems, located in the S $\frac{1}{2}$ of the NW $\frac{1}{4}$ of the SW $\frac{1}{4}$ of Section 28, T5S, R7E, SBB&M.
4. The discharger is reserving areas of sufficient size for possible future 100 percent replacement of the seepage pits.
5. There are no domestic wells within 200 feet of the discharge facilities described in Findings No. 2 and 3 (above).
6. Wastewater from three swimming pools and two hot pools is periodically discharged into separate seepage pits.
7. The Water Quality Control Plan for the West Colorado River Basin was adopted on April 10, 1975. The Basin Plan contains water quality objectives for the Coachella Hydrologic Subunit.
8. The beneficial uses of the ground water of the Coachella Hydrologic Subunit are:
 - a. Municipal supply
 - b. Industrial supply
 - c. Agricultural supply
9. The Board has notified the discharger and interested agencies and persons of its intent to update waste discharge requirements for the discharge.

10. The Board in a public meeting heard and considered all comments pertaining to the existing discharge.
11. The Riverside County Planning Department approved a Negative Declaration for this park on March 29, 1977. The Regional Board has reviewed this Negative Declaration. The below waste discharge requirements are designed to assure against any significant adverse effects on water quality.

IT IS HEREBY ORDERED, the discharger shall comply with the following:

A. Discharge Specifications

1. Neither the treatment nor the discharge of wastewater shall create a pollution or a nuisance as defined in Division 7 of the California Water Code.
2. No wastewater other than domestic sewage and swimming and hot pool wastewater shall be discharged at this location.
3. Wastewater discharged subsurface shall be retained underground with no surfacing.
4. Adequate measures shall be taken to assure that flood or surface drainage waters do not erode or otherwise render portions of the discharge facilities inoperable.
5. Septic tank cleanings shall be discharged only by a duly authorized service.
6. Swimming and hot pool wastewater shall not be discharged into a sewage disposal system.

B. Provisions


1. Sufficient land area shall be reserved for possible future 100 percent replacement of the seepage pits, until such time as this park is connected to a municipal sewerage system.
2. Upon request from this Board's Executive Officer, the discharger shall furnish technical and/or monitoring reports on the treatment and discharge of wastes.
3. Prior to any modifications in this facility which would result in material change in the quality or quantity of wastewater discharged, or any material change in location of discharge, the discharger shall report in writing to the Regional Board.

4. Prior to any change of ownership of this recreational vehicle park, the discharger shall:

- a. Specify as a condition of transfer that the area specified in Provision B.1 (above) remain servient to the park for the purpose of providing additional subsurface sewage disposal capacity, until such time as this park is connected to a municipal sewerage system.
- b. Transmit a copy of this Order to the succeeding owner or operator, and file a copy of the transmittal letter with this Board.

5. This Order supersedes Board Order No. 77-92.

I, Arthur Swajian, Executive Officer, do hereby certify the foregoing is a full, true and correct copy of an Order adopted by the California Regional Water Quality Control Board, Colorado River Basin Region, on May 16, 1984.



Executive Officer

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION**

**MONITORING AND REPORTING PROGRAM NO. 84-46
FOR
INDIAN WELLS R.V. ROUND UP
West of Indio - Riverside County**

Location: Portion of the S $\frac{1}{2}$, NW $\frac{1}{4}$, SW $\frac{1}{4}$ of Section 28, T5S, R7E, SBB&M

MONITORING

This discharger shall submit an annual status report on the following:

1. Number of spaces, restrooms and laundry rooms presently connected to the sewerage system.
2. List any proposed changes in the sewage disposal facilities during the upcoming year.

REPORTING

1. Annual reports are to be submitted by January 15th of each year to:

California Regional Water Quality Control Board
Colorado River Basin Region
73-271 Highway 111, Suite 21
Palm Desert, CA 92260


2. Report immediately any surfacing of wastewater or other failures of the system by telephone and follow-up by letter.

Ordered By:

Arthur Swajian
Executive Officer

July 23, 1987
Date

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD - 7



Scale:
1"=2,000'

SITE MAP
INDIAN WELLS R.V. ROUND UP
 West of Indio - Riverside County
 Portion of S $\frac{1}{2}$, NW $\frac{1}{4}$, SW $\frac{1}{4}$ of Section 28, T5S, R7E, SBB&M
 USGS La Quinta 7.5 min. Topographic Map