CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN

WDID NO.: 7A1310570011
ORDER NO.: R7-2003-0064
NPDES NO : CA0104841
REPORTING FREQUENCY: MONTHLY

MONITORING AND REPORTING PROGRAM
FOR DATE GARDENS MOBILE HOME PARK
MONTH January
YEAR 2004

TYPE OF SAMPLE:	EFFLUENT						
CONSTITUENTS	Flow	Sus. Solids	20°C BOD_5	pH	E. Coli	Chlorine	TDS
FREQUENCY	Daily	Monthly	Monthly	Monthly	5 Samples/Mo.	Daily	Monthly
DESCRIPTION		24-Hr. Comp.	24-Hr. Comp.	Grab	Grab	Grab	Grab
UNITS	mgd	mg/L	mg/L	pH UNITS	MPN/100mL	mg/L	mg/L
REQUIREMENTS							
30-DAY MEAN	0.021	30	30	6.0-9.0	126	0.01	2000
7-DAY MEAN		45	45	6.0-9.0			2500
MAXIMUM					400	0.02	
DATE OF SAMPLE							
1	0.018124						
2	0.01418						
3	0.017248						
4	0.010359						
5	0.015085						
6	0.016416						
7	0.01884						
8	0.014835						
9	0.018453						
10	0.019515						
11	0.017488						
12	0.018864						
13	0.015147						
14	0.018823						
15	0.018544						
16	0.016912						
17	0.018308						
18	0.017642						
19	0.01588						
20	0.018815						
21	0.015773						
22	0.016442						
23	0.01742						
24	0.014772						
25	0.019388						1292
26	0.01823	8.5	8	6.82			
27	0.016781						
28	0.016887						
29	0.014245						
30	0.019527						
31	0.01788						
30-DAY MEAN	0.017821						
7-DAY MEAN	0.124747						
MAXIMUM	0.019527						

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: Rocky Vandergrift

RECEIVED
FEB 13 2004
REGION 7

MONTHLY REPORT

TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE

RECEIVED: 1-26-04 945AM ANALYSIS:

SAMPLED FROM CLIENT: DISTRICT

DATE GARDENS

SAMPLED BY: ROD
DATE/TIME: 1-26-04
TYPE OF SAMPLE: RAW
CHLORINE RESIDUE: 0
SITE CODE: 21-2
SAMPLE SITE: EFFLUENT

TOTAL COLIFORM = PRESENCE
FECAL COLIFORM = PRESENCE
E COLI = PRESENCE

DILUTION: 1.0, 0.1, 0.01 ML

ANALYST: LLW/MO COLIFORM=>=16000/FECAL=300/ECOLI=170/100ML

DATE START: 1-26-04
DATE COMPLETED: 1-28-04
DATE REPORTED: 1-29-04

TIME START: 1000AM
TIME COMPLETED: 900AM
METHOD: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227
LAB DIRECTOR: LINDA L WEBSTER , PHONE 760-344-2532

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO: M5031

TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE

RECEIVED: 1-27-04 1100AM ANALYSIS:

SAMPLED FROM CLIENT: DISTRICT

DATE GARDENS MOBILE

SAMPLED BY: RV
DATE/TIME: 1-27-04
TYPE OF SAMPLE: RAW
CHLORINE RESIDUE: 0
SITE CODE: 21-2
SAMPLE SITE: EFFLUENT

TOTAL COLIFORM = PRESENCE
FECAL COLIFORM = PRESENCE
E COLI = PRESENCE

DILUTION: 1.0, 0.1, 0.01 ML

ANALYST: LLW/MO COLIFORM=>=16000/FECAL=>=16000/ECOLI=16000/100ML

DATE START: 1-27-04
DATE COMPLETED: 1-29-04
DATE REPORTED: 1-29-04

TIME START: 1100AM
TIME COMPLETED: 930AM
METHOD: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227
LAB DIRECTOR: LINDA L WEBSTER , PHONE 760-344-2532

RECEIVED
FEB 13 2004
REGION 7

BACTERIOLOGICAL ANALYSIS OF WATER ********** LAB NO: M4906 **********
TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE
RECEIVED: 1-5-04 1005AM ANALYSIS:

SAMPLED FROM CLIENT: DISTRICT:

DATE GARDENS

SAMPLED BY: RV
DATE/TIME: 1-5-04 800AM
TYPE OF SAMPLE: RAW
CHLORINE RESIDUE: 0
SITE CODE 21-2
SAMPLE SITE: EFFLUENT

TOTAL COLIFORM = PRESENCE
FECAL COLIFORM = PRESENCE
E COLI = PRESENCE

DILUTION: 1.0, 0.1, 0.01 ML

ANALYST: LLW/MO COLIFORM=>=16000/FECAL=>=16000/ECOLI=>=16000/100ML
DATE START: 1-5-04 TIME START: 1000AM
DATE COMPLETED: 1-7-04 TIME COMPLETED: 930AM
DATE REPORTED: 1-7-04 METHOD NAME: 9221B/E/F
ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227
LAB DIRECTOR, LINDA L WEBSTER, PHONE 760-344-2532

****

RECEIVED
FEB 13 2004
REGION 7

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO: M4944
TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE
RECEIVED: 1-12-04 1000AM ANALYSIS:

SAMPLED FROM CLIENT: DISTRICT

DATE GARDENS

SAMPLED BY: RV
DATE/TIME: 1-12-04 815AM
TYPE OF SAMPLE: RAW
CHLORINE RESIDUE: 0
SAMPLE SITE: EFFLUENT

SITE CODE: 21-2

TOTAL COLIFORM = PRESENCE
FECAL COLIFORM = PRESENCE
E COLI = PRESENCE

DILUTION: 1.0, 0.1, 0.01 ML

COLIFORM=>=16000/FECAL=>=16000/ECOLI=>=16000/100ML

ANALYST: LLW/MO
DATE START: 1-12-04
TIME START: 1100AM
DATE COMPLETED: 1-14-04
TIME COMPLETED: 930AM
DATE REPORTED: 1-15-04
METHOD: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227
LAB DIRECTOR: LINDA L WEBSTER , PHONE 760-344-2532

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO: M5010
TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE
RECEIVED: 1-22-04 1015AM ANALYSIS:

SAMPLED FROM CLIENT: DISTRICT

DATE GARDENS

SAMPLED BY: RV
DATE/TIME: 1-22-04
TYPE OF SAMPLE: RAW
CHLORINE RESIDUE: 0
SAMPLE SITE: EFFLUENT

SITE CODE: 21-2

TOTAL COLIFORM = PRESENCE
FECAL COLIFORM = PRESENCE
E COLI = PRESENCE

DILUTION: 1.0, 0.1, 0.01 ML

COLIFORM=>=16000/FECAL=9000/ECOLI=5000/100ML

ANALYST: LLW/MO
DATE START: 1-22-04
TIME START: 1030AM
DATE COMPLETED: 1-24-04
TIME COMPLETED: 1000AM
DATE REPORTED: 1-26-04
METHOD: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227
LAB DIRECTOR: LINDA L WEBSTER , PHONE 760-344-2532

RECEIVED
FEB 13 2004
REGION 7