COLORADO RIVER BASIN REGION
MONITORING AND REPORTING PROGRAM FOR:
DATE GARDENS MOBILE HOME PARK

WDID NO.: 7A131067011
ORDER NO.: 97-113
NPDES NO.: CA0104841
REPORTING FREQUENCY.: MONTHLY/QUARTERLY

MONTH: August
YEAR: 2003
QUARTER:
INFLUENT/RECEIVING WATER

Constituents	BOD	Sus.Solids	DO. Oxygen	PH	DO. Oxygen	PH
Sample	Influent	Influent	Rec. water	Rec. water	Rec. water	Rec. water
Frequency	Quarterly	Quarterly	Monthly	Monthly	Monthly	Monthly
Description	24Hr.Comp	24Hr.Comp	Upstream	Upstream	Downstream	Downstream
Units	mg/L	mg/L	mg/L	PH Units	mg/L	PH Units
Requirements						
30 Day Mean					Min. 5.0	5.0 - 9.0
7 Day Mean						
Maximum						
Date of Sample						
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
11			6.20	8.09	6.40	8.12
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
31						
MONTHLY MEAN	#DIV/0!	#DIV/0!	6.20	8.09	6.40	8.12

I declare under the penalty of law that I have personally examined and am familiar with the information submitted in this document, and that based on my inquiry of those individuals immediately responsible for obtaining the information,. I believe that the information is true, accurate, and complete. I'm aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE: R. Vanderwyst

RECEIVED
SEP 10 2003
REGION 7

CALIFORNIA REGIONALWATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION
MONITORING AND REPORTING PROGRAM FOR:
Date Gardens Mobile Home Park

WDID NO.: 7A131067011
ORDER NO.: 97-113
NPDES NO.: CA0104841
REPORTING FREQUENCY.: MONTHLY

MONTH: August 2003

EFFLUENT

Constituents	FLOW	BOD	SUS.SOLIDS	SETT.MATT.	Ph	TDS
Sample						
Frequency	Daily	Monthly	Monthly	Monthly	Monthly	Monthly
Description		24 Hr.Comp	24 Hr.Comp	Grab	Grab	
Units	MGD	mg/L	mg/L	ml/L	Ph Units	
Requirements						
30 Day Mean		30	30	0.3		2000
7 Day Mean		45	45	0.6		2500
Maximum					6.0 - 9.0	
Date of Sample						
1	0.001281					
2	0.001467					
3	0.001439					
4	0.001040					
5	0.000850					
6	0.001144					
7	0.001421					
8	0.001298					
9	0.001521					
10	0.001350					
11	0.000053	7.0	7.0	0.10	7.04	870
12	0.000461					
13	0.000268					
14	0.000426					
15	0.000956					
16	0.002601					
17	0.003129	10.0	9.0			
18	0.001080			0.10	7.27	1084
19	0.001164					
20	0.001640					
21	0.001753					
22	0.002105					
23	0.002396					
24	0.002140					
25	0.002011					
26	0.001664					
27	0.002899					
28	0.002904					
29	0.003223					
30	0.002301					
31	0.001652					
MONTHLY MEAN	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]	[illegible]

I declare under the penalty of law that I have personally examined and am familiar with the information submitted in this document, and that based on my inquiry of those individuals immediately responsible for obtaining the information.. I believe that the information is true, accurate, and complete. I'm aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Grab at peak flow

SIGNATURE: R. Vandergrift

RECEIVED
SEP 10 2003
REGION 7

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO: M4106

TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE

RECEIVED: 8-11-03 220PM ANALYSIS:

SAMPLED FROM CLIENT:

DATE GARDENS

DISTRICT

SAMPLED BY: ?

DATE/TIME: 8-11-03

TYPE OF SAMPLE: RAW

SITE CODE: 21-2

CHLORINE RESIDUE: 0

SAMPLE SITE: EFF

TOTAL COLIFORM = PRESENCE
FECAL COLIFORM = PRESENCE
E COLI = PRESENCE

DILUTION: 1.0, 0.1, 0.01 ML

ANALYST: LLW/MO COLIFORM=>=16000/FECAL=>=16000/ECOLI=>=16000/100ML

DATE START: 8-11-03 TIME START: 230PM

DATE COMPLETED: 8-13-03 TIME COMPLETED 1200PM

DATE REPORTED: 8-14-03 METHOD: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227

LAB DIRECTOR: LINDA L WEBSTER , PHONE 760-344-2532

RECEIVED

SEP 10 2003

REGION 7

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO: M4080
TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE

RECEIVED: 8-4-03 140PM ANALYSIS:

SAMPLED FROM CLIENT: DISTRICT:

DATE GARDENS

SAMPLED BY: ?
DATE/TIME: 8-4-03 8
TYPE OF SAMPLE: RAW
CHLORINE RESIDUE: 0
SITE CODE 21-2 SAMPLE SITE: EFFLUENT

DILUTION: 1.0, 0.1, 0.01 ML

TOTAL COLIFORM = PRESENCE
FECAL COLIFORM = PRESENCE
E COLI = PRESENCE

ANALYST: LLW/MO COLIFORM=>=16000/FECAL=>=16000/ECOLI=>=16000/100ML
DATE START: 8-4-03 TIME START: 200PM
DATE COMPLETED: 8-6-03 TIME COMPLETED: 1100AM
DATE REPORTED: 8-12-03 METHOD NAME: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227
LAB DIRECTOR, LINDA L WEBSTER, PHONE 760-344-2532

RECEIVED
SEP 10 2003
REGION 7

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO: M4184
TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE
RECEIVED 8-18-03 250PM ANALYSIS:

SAMPLED FROM CLIENT: DISTRICT:

DATE GARDENS

SAMPLED BY: ?
DATE/TIME: 8-18-03
TYPE OF SAMPLE: RAW
CHLORINE RESIDUE: 0
SAMPLE SITE: EFFLUENT

SITE CODE 21-2

TOTAL COLIFORM - PRESENCE
FECAL COLIFORM - PRESENCE
E COLI - PRESENCE

DILUTION: 1.0, 0.1, 0.01 ML

ANALYST LLW/MO COLIFORM=>=16000/FECAL=>=16000/ECOLI=>=16000/100ML
DATE START: 8-18-03 TIME START: 300PM
DATE COMPLETED 8-20-03 TIME COMPLETED 100PM
DATE REPORTED: 8-21-03 METHOD NAME 9221B/E/F
ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227
LAB DIRECTOR, LINDA L WEBSTER, PHONE 760-344-2532

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO: M4186
TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE
RECEIVED 8-25-03 1250PM ANALYSIS:

SAMPLED FROM CLIENT: DISTRICT

DATE GARDENS

SAMPLED BY: ?
DATE/TIME: 8-25-03
TYPE OF SAMPLE: RAW
CHLORINE RESIDUE: 0
SAMPLE SITE: EFF

SITE CODE: 21-2

TOTAL COLIFORM = PRESENCE
FECAL COLIFORM = PRESENCE
E COLI = PRESENCE

DILUTION: 1.0, 0.1, 0.01 ML

ANALYST: LLW/MO COLIFORM=<=16000/FECAL=>=16000/ECOLI=>=16000/100ML
DATE START: 8-25-03 TIME START: 100PM
DATE COMPLETED: 8-27-03 TIME COMPLETED 100PM
DATE REPORTED: 8-28-03 METHOD: 9221B/E/F
ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227
LAB DIRECTOR: LINDA L WEBSTER, PHONE 760-344-2532

RECEIVED
SEP 10 2003
REGION 7