CALIFORNIA REGIONALWATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION
MONITORING AND REPORTING PROGRAM FOR:
Date Gardens Mobile Home Park

WDID NO.: 7A131067011
ORDER NO.: 87-113
NPDES NO.: CA0104841

MONTH: September
2003

REPORTING FREQUENCY.: MONTHLY

EFFLUENT

Constituents	FLOW	BOD	SUS.SOLIDS	SETT.MATT.	Ph	TDS
Sample						
Frequency	Daily	Monthly	Monthly	Monthly	Monthly	Monthly
Description		24 Hr.Comp	24 Hr.Comp	Grab	Grab	
Units	MGD	mg/L	mg/L	ml/L	Ph Units	
Requirements						
30 Day Mean		30	30	0.3		2000
7 Day Mean		45	45	0.5		2500
Maximum					6.0 - 9.0	
Date of Sample						
1	0.001504					
2	0.001796					
3	0.00133					
4	0.005339					
5	0.004165					
6	0.003643					
7	0.001954					
8	0.001311	N/D	13.5	N/D	7.18	848
9	0.001521					
10	0.001792					
11	0.003609					
12	0.002580					
13	0.004023					
14	0.001929					
15	0.003730					
16	0.008278					
17	0.001254					
18	0.077129					
19	0.035162					
20	0.041842					
21	0.0017530					
22	0.002105					
23	0.002396					
24	0.008604					
25	0.007274					
26	0.001664					
27	0.001578					
28	0.006344					
29	0.004727					
30	0.001449					
31	.0086					
MONTHLY MEAN	0.006480	N/D	13.5	N/D	7.18	848

I declare under the penalty of law that I have personally examined and am familiar with the information submitted in this document, and that based on my inquiry of those individuals immediately responsible for obtaining the information, I believe that the information is true, accurate, and complete. I'm aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Grab at peak flow

SIGNATURE: R Vandergriff

RECEIVED
OCT - 6 2003
REGION 7

COLORADO RIVER BASIN REGION
MONITORING AND REPORTING PROGRAM FOR:
DATE GARDENS MOBILE HOME PARK

WDID NO.: 7A131067011
ORDER NO.: 97-113
NPDES NO.: CA0104841
REPORTING FREQUENCY.: MONTHLY/QUARTERLY

MONTH: September
YEAR: 2003
QUARTER:
INFLUENT/RECEIVING WATER

Constituents	BOD	Sus.Solids	DO. Oxygen	PH	DO. Oxygen	PH
Sample	Influent	Influent	Rec. water	Rec. water	Rec. water	Rec. water
Frequency	Quarterly	Quarterly	Monthly	Monthly	Monthly	Monthly
Description	24Hr.Comp	24Hr.Comp	Upstream	Upstream	Downstream	Downstream
Units	mg/L	mg/L	mg/L	PH Units	mg/L	PH Units
Requirements						
30 Day Mean					Min. 5.0	6.0 - 9.0
7 Day Mean						
Maximum						
Date of Sample						
1						
2						
3						
4						
5						
6						
7						
8	156	56	7.40	8.07	7.40	7.95
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
31						
MONTHLY MEAN	156	56	7.40	8.07	7.40	7.95

I declare under the penalty of law that I have personally examined and am familiar with the information submitted in this document, and that based on my inquiry of those individuals immediately responsible for obtaining the information.. I believe that the information is true, accurate, and complete. I'm aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

RECEIVED
OCT - 6 2003
REGION 7

SIGNATURE: R. Vandergriff

BACTERIOLOGICAL ANALYSIS OF WATER

TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE

RECEIVED: 9-16-03 800AM ANALYSIS:

SAMPLED FROM CLIENT: DISTRICT:

DATE GARDENS

SAMPLED BY: RV
DATE/TIME: 9-16-03 730AM
TYPE OF SAMPLE: RAW
CHLORINE RESIDUE: 0
SAMPLE SITE: EFF

SITE CODE 21-2

TOTAL COLIFORM = PRESENCE
FECAL COLIFORM = PRESENCE
E COLI = PRESENCE

DILUTION: 1.0, 0.1, 0.01 ML

ANALYST: LLW/MO COLIFORM=>=16000/FECAL=>=16000/ECOLI=>=16000/100ML

DATE START: 9-16-03 TIME START: 900AM
DATE COMPLETED: 9-18-03 TIME COMPLETED: 930AM
DATE REPORTED: 9-18-03 METHOD NAME: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227
LAB DIRECTOR, LINDA L WEBSTER, PHONE 760-344-2532

BACTERIOLOGICAL ANALYSIS OF WATER

TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE

RECEIVED: 9-15-03 150PM ANALYSIS:

SAMPLED FROM CLIENT: DISTRICT

DATE GARDENS

SAMPLED BY: ROD
DATE/TIME: 9-15-03
TYPE OF SAMPLE: RAW
CHLORINE RESIDUE: 0
SAMPLE SITE: EFF

SITE CODE: 21-2

TOTAL COLIFORM = PRESENCE
FECAL COLIFORM = PRESENCE
E COLI = PRESENCE

DILUTION: 1.0, 0.1, 0.01 ML

ANALYST: LLW/MO COLIFORM=>=16000/FECAL=>=16000/ECOLI=>=16000/100ML

DATE START: 9-15-03 TIME START: 200PM
DATE COMPLETED: 9-17-03 TIME COMPLETED: 1200PAM
DATE REPORTED: 9-18-03 METHOD: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227
LAB DIRECTOR: LINDA L WEBSTER, PHONE 760-344-2532

SIR SPEEDY PRINTING • SIGNAL HILL, CA • (562) 426-4048

RECEIVED
OCT - 6 2003
REGION 7

*** BACTERIOLOGICAL ANALYSIS OF WATER ******* LAB NO. M4351 *********

TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE

RECEIVED: 9-23-03 110PM ANALYSIS:

SAMPLED FROM CLIENT: DISTRICT:

DATE GARDENS MOBILE PARK

SAMPLED BY: ROD

DATE/TIME: 9-23-03

TYPE OF SAMPLE: RAW

CHLORINE RESIDUE: 0

SITE CODE 21-2

SAMPLE SITE: EFFLUENT

TOTAL COLIFORM = PRESENCE

FECAL COLIFORM = PRESENCE

E COLI = PRESENCE

DILUTION: 1.0, 0.1, 0.01 ML

ANALYST: LLW/MO COLIFORM=>=16000/FECAL=>=16000/ECOLI=>=16000/100ML

DATE START: 9-23-03 TIME START: 115PM

DATE COMPLETED: 9-25-03 TIME COMPLETED: 1100AM

DATE REPORTED: 9-25-03 METHOD NAME: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227

LAB DIRECTOR, LINDA L WEBSTER, PHONE 760-344-2532

****

RECEIVED

OCT - 6 2003

REGION 7

BACTERIOLOGICAL ANALYSIS OF WATER ******* LAB NO: M4231 **********

TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE

RECEIVED: 9-2-03 145PM ANALYSIS: _____

SAMPLED FROM CLIENT: DISTRICT:

DATE GARDENS

SAMPLED BY: ROD

DATE/TIME: 9-2-03

TYPE OF SAMPLE: RAW

CHLORINE RESIDUE: 0

SITE CODE 21-2

SAMPLE SITE: EFF

TOTAL COLIFORM = PRESENCE DILUTION: 1.0, 0.1, 0.01 ML

FECAL COLIFORM = PRESENCE

E COLI = PRESENCE

COLIFORM=>=16000/FECAL=>=16000/ECOLI=>=16000/100ML

ANALYST: LLW/MO

DATE START: 9-2-03 TIME START: 200PM

DATE COMPLETED: 9-4-03 TIME COMPLETED: 1100AM

DATE REPORTED: 9-5-03 METHOD NAME: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227

LAB DIRECTOR, LINDA L WEBSTER, PHONE 760-344-2532

****

OCT - 6 2003

REGION 7

BACTERIOLOGICAL ANALYSIS OF WATER ******* LAB NO. M4262 **********

TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE

RECEIVED: 9-8-03 1230PM ANALYSIS:

SAMPLED FROM CLIENT: DISTRICT

DATE GARDENS

SAMPLED BY: RV

DATE/TIME: 9-8-03

TYPE OF SAMPLE: RAW

CHLORINE RESIDUE: 0

SITE CODE: 21-2

SAMPLE SITE: EFF

TOTAL COLIFORM = PRESENCE

FECAL COLIFORM = PRESENCE

E COLI = PRESENCE

DILUTION: 1.0, 0.1, 0.01 ML

ANALYST: LLW/MO COLIFORM=130/FECAL=40/ECOLI=20/100ML

DATE START: 9-8-03 TIME START: 100PM

DATE COMPLETED: 9-11-03 TIME COMPLETED: 1200PM

DATE REPORTED: 9-11-03 METHOD: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227

LAB DIRECTOR: LINDA L WEBSTER , PHONE 760-344-2532

****

RECEIVED

OCT - 6 2003

REGION 7

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO: M4262

TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE

RECEIVED: 9-8-03 - 1230PM ANALYSIS:

SAMPLED FROM CLIENT: DISTRICT

DATE GARDENS

SAMPLED BY: RV

DATE/TIME: 9-8-03

TYPE OF SAMPLE: RAW

CHLORINE RESIDUE: 0

SITE CODE: 21-2

SAMPLE SITE: EFF

TOTAL COLIFORM = PRESENCE

FECAL COLIFORM = PRESENCE

E COLI = PRESENCE

DILUTION: 1.0, 0.1, 0.01 ML

ANALYST: LLW/MO COLIFORM=130/FECAL=40/ECOLI=20/100ML

DATE START: 9-8-03 TIME START: 100PM

DATE COMPLETED: 9-11-03 TIME COMPLETED: 1200PM

DATE REPORTED: 9-11-03 METHOD: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227

LAB DIRECTOR: LINDA L WEBSTER , PHONE 760-344-2532

RECEIVED

OCT - 6 2003

REGION 7