CALIFO A REGIONAL WATER QUALITY CONTRO OARD
COLORADO RIVER BASIN

WDID NO.: **7A1310570011**
ORDER NO.: **R7-2003-0054**
NPDES NO.: **CA0104841**
REPORTING FREQUENCY: **MONTHLY**

MONITORING AND REPORTING PROGRAM
FOR DATE GARDENS MOBILE HOME PARK
MONTH JULY
YEAR 2004

TYPE OF SAMPLE:	EFFLUENT						
CONSTITUENTS	Flow	Sus. Solids	20°C BOD_5	pH	E. Coli	Chlorine	TDS
FREQUENCY	Daily	Monthly	Monthly	Monthly	5 Samples/Mo.	Daily	Monthly
DESCRIPTION		24-Hr. Comp.	24-Hr. Comp.	Grab	Grab	Grab	Grab
UNITS	mgd	mg/L	mg/L	pH UNITS	MPN/100mL	mg/L	mg/L
REQUIREMENTS							
30-DAY MEAN	0.021	30	30	6.0-9.0	126	0.01	2000
7-DAY MEAN		45	45	6.0-9.0			2500
MAXIMUM					400	0.02	
DATE OF SAMPLE							
1	0.008314						
2							
3	0.015403						
4							
5							
6	0.027148						
7							
8	0.016315						
9							
10	0.015433						
11							
12							
13	0.03211						
14							
15	0.015812						
16							
17	0.004457						
18							
19	0.004718	19	3	7.9			1120
20	0.004672						
21							
22	0.008356						
23							
24	0.004487						
25							
26							
27	0.007326						
28							
29	0.008818						
30	0.007549						
31	0.00944						
30-DAY MEAN	0.005958						
7-DAY MEAN	0.041713						
MAXIMUM	0.00944						

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who [illegible] the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my [illegible] I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Rocky Vandergrift

RECEIVED
AUG 6 2004
REGION-7

MONTHLY REPORT

DATE/TIME: 7-19-04
TYPE OF SAMPLE: RAW
CHLORINE RESIDUE: UV
SAMPLE SITE: FINAL EFFLUENT

SITE CODE 21-2

TOTAL COLIFORM = ABSENCE
FECAL COLIFORM = ABSENCE
E COLI = ABSENCE

DILUTION: 1.0, 0.1, 0.01 ML

COLIFORM=<20/FECAL=<20/ECOLI=<20/100ML

ANALYST: LLW/MO
DATE START: 7-19-04 TIME START: 1200PM
DATE COMPLETED: 7-21-04 TIME COMPLETED: 900AM
DATE REPORTED: 7-21-04 METHOD NAME: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227
LAB DIRECTOR, LINDA L WEBSTER, PHONE 760-344-2532

****

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO: M6852
TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE
RECEIVED: 7-28-04 1110AM ANALYSIS:
SAMPLED FROM CLIENT: DISTRICT

DATE GARDENS MOBILE PARK

SAMPLED BY: MO
DATE/TIME: 7-28-04 842AM
TYPE OF SAMPLE: POTABLE
CHLORINE RESIDUE: 3.0
SAMPLE SITE: TAP

SITE CODE: 21

TOTAL COLIFORM ABSENCE

ANALYST: LLW/MO
DATE START: 7-28-04 TIME START: 1115AM
DATE COMPLETED: 7-29-04 TIME COMPLETED: 1115AM
DATE REPORTED: 7-29-04 METHOD: 9223B

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227
LAB DIRECTOR, LINDA L WEBSTER, PHONE 760-344-2532

****

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO: M6843
TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE
RECEIVED: 7-26-04 115PM ANALYSIS:
SAMPLED FROM CLIENT: DISTRICT: RV

DATE GARDENS MOBILE PARK

SAMPLED BY: 7-26-04
DATE/TIME: RAW
TYPE OF SAMPLE: UV
CHLORINE RESIDUE: FINAL EFFLUENT
SAMPLE SITE:

SITE CODE 21-2

TOTAL COLIFORM = ABSENCE
FECAL COLIFORM = ABSENCE
E COLI = ABSENCE

DILUTION: 1.0, 0.1, 0.01 ML

COLIFORM=<20/FECAL=<20/ECOLI=<20/100ML

ANALYST: LLW/MO
DATE START: 7-26-04 TIME START: 130PM
DATE COMPLETED: 7-29-04 TIME COMPLETED: 1030AM
DATE REPORTED: 7-29-04 METHOD NAME: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227
LAB DIRECTOR, LINDA L WEBSTER, PHONE 760-344-2532

****

RECEIVED
AUG 06 2004
REGION 7

BACTERIOLOGICAL ANALYSIS OF WATER LAB
TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE M6743
RECEIVED: 7-6-04 1205PM ANALYSIS:
SAMPLED FROM CLIENT. DISTRICT:
DATE GARDENS SAMPLED BY: RV
DATE/TIME: 7-6-04
TYPE OF SAMPLE: RAW
CHLORINE RESIDUE: UV
SITE CODE 21-2 SAMPLE SITE: FINAL EFFLUENT

TOTAL COLIFORM = ABSENCE DILUTION: 1.0, 0.1, 0.01 ML
FECAL COLIFORM = ABSENCE
E COLI = ABSENCE
ANALYST LLW/MO COLIFORM=<20/FECAL=<20/ECOLI=<20/100ML
DATE START. 7-6-04 TIME START: 1215PM
DATE COMPLETED: 7-9-04 TIME COMPLETED: 1130AM
DATE REPORTED: 7-9-04 METHOD NAME: 9221B/E/F
ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227
LAB DIRECTOR LINDA L WEBSTER, PHONE 760-344-2532

****

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO:
TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE M6757
RECEIVED: 7-12-04 1130AM ANALYSIS:
SAMPLED FROM CLIENT: DISTRICT
DATE GARDENS SAMPLED BY: RV
DATE/TIME: 7-12-04 900AM
TYPE OF SAMPLE: RAW
CHLORINE RESIDUE: UV
SITE CODE: 21-1 SAMPLE SITE: FINAL EFFLUENT

TOTAL COLIFORM PRESENCE DILUTION: 1.0, 0.1, 0.01 ML
FECAL COLIFORM = PRESENCE
E COLI = ABSENCE
ANALYST. LLW/MO COLIFORM=20/FECAL=20/ECOLI=<20/100ML
DATE START: 7-12-04 TIME START. 1130AM
TIME COMPLETED: 730AM

RECEIVED
AUG 6 2004
REGION 7

****

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO:
TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE M6846
RECEIVED: 7-27-04 940AM ANALYSIS:
SAMPLED FROM CLIENT: DISTRICT
DATE GARDENS SAMPLED BY: ROD
DATE/TIME: 7-27-04
TYPE OF SAMPLE: RAW
CHLORINE RESIDUE: UV
SITE CODE: 21-2 SAMPLE SITE: FINAL EFFLUENT

TOTAL COLIFORM PRESENCE
FECAL COLIFORM = ABSENCE
E COLI = ABSENCE DILUTION: 1.0, 0.1, 0.01 ML
ANALYST: LLW/MO COLIFORM=20/FECAL=20/ECOLI=<20/100ML

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO: M6846
TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE
RECEIVED: 7-27-04 940AM ANALYSIS:
SAMPLED FROM CLIENT: DISTRICT
DATE GARDENS

SAMPLED BY: ROD
DATE/TIME: 7-27-04
TYPE OF SAMPLE: RAW
CHLORINE RESIDUE: UV
SITE CODE: 31-2
SAMPLE SITE FINAL EFFLUENT

TOTAL COLIFORM PRESENCE
FECAL COLIFORM = ABSENCE
E COLI = ABSENCE
DILUTION: 1.0, 0.1, 0.01 ML

ANALYST: LLW/MO COLIFORM=20/FECAL=<20/ECOLI=<20/100ML
DATE START: 7-27-04 TIME START: 1000AM
DATE COMPLETED: 7-30-04 TIME COMPLETED: 800AM
DATE REPORTED: 7-30-04 METHOD: 9221B/E/F
ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227
LAB DIRECTOR: LINDA L WEBSTER, PHONE 760-344-2532

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO: M6845-3
TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE
RECEIVED: 7-27-04 850AM ANALYSIS:
SAMPLED FROM CLIENT: DISTRICT:
CITY OF CALEXICO WWTP

SAMPLED BY: JL
DATE/TIME: 7-27-04 750AM
TYPE OF SAMPLE: RAW
CHLORINE RESIDUE: UV
SITE CODE 192-3
SAMPLE SITE: UP22.4 DOWN 41.2KVA

TOTAL COLIFORM = PRESENCE
FECAL COLIFORM = PRESENCE
E COLI = PRESENCE
DILUTION: 1.0, 0.1, 0.01 ML

ANALYST: LLW/MO COLIFORM=5000/FECAL=3000/ECOLI=[illegible]/100ML
DATE START: 7-27-04 TIME START: 900AM
DATE COMPLETED: 7-30-04 TIME COMPLETED: 800AM
DATE REPORTED: 7-30-04 METHOD NAME: 9221B/E/F
ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227
LAB DIRECTOR: LINDA L WEBSTER, PHONE 760-344-2532

ATT. Jose Cortez

Date Gardens WWTP
7-27-04

RECEIVED
SEP 02 2004
REGION 7