CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN

WDID NO.: **7A1310570011**
ORDER NO.: **R7-2003-0054**
NPDES NO.: **CA0104841**
REPORTING FREQUENCY: **MONTHLY**

MONITORING AND REPORTING PROGRAM
FOR DATE GARDENS MOBILE HOME PARK
MONTH February
YEAR 2006

TYPE OF SAMPLE:	EFFLUENT						
CONSTITUENTS	Flow	Sus. Solids	20°C BOD_5	pH	E. Coli	Chlorine	TDS
FREQUENCY	Daily	Monthly	Monthly	Monthly	5 Samples/Mo.	Daily	Monthly
DESCRIPTION		24-Hr. Comp.	24-Hr. Comp.	Grab	Grab	Grab	Grab
UNITS	mgd	mg/L	mg/L	pH UNITS	MPN/100mL	mg/L	mg/L
REQUIREMENTS							
30-DAY MEAN	0.021	30	30	6.0-9.0	126	0.01	2000
7-DAY MEAN		45	45	6.0-9.0			2500
MAXIMUM					400	0.02	
DATE OF SAMPLE							
1	0.01185						
2	0.01102						
3	0.010955						
4	0.011385						
5	0.010208						
6	0.011578	44	7.4	7.14	70		910
7	0.010667						
8	0.011525						
9	0.011185						
10	0.010962						
11	0.011862						
12	0.009648						
13	0.009581				170		
14	0.011868						
15	0.012008						
16	0.011216						
17	0.011468						
18	0.010595						
19	0.01142						
20	0.011105						
21	0.011569				<20		
22	0.009985						
23	0.010301						
24	0.010422						
25	0.011555						
26	0.01078						
27	0.011045				<20		
28	0.011588				<20		
29							
30							
31							
30-DAY MEAN	0.011048						
7-DAY MEAN	0.077337						
MAXIMUM	0.012008						

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: R. Vandergrift

MONTHLY REPORT

RECEIVED
MAR 14 2006
REGION 7

BACTERIOLOGICAL ANALYSIS OF WATER LAB N M9922
TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE
RECEIVED: 2-27-06 1040AM ANALYSIS:
DISTRICT:
SAMPLED FROM CLIENT:
DATE GARDENS

SAMPLED BY: JASON
DATE/TIME: 2-27-06
TYPE OF SAMPLE: RAW
CHLORINE: UV
SAMPLE SITE: FINAL EFFLUENT

SITE CODE 21-2

TOTAL COLIFORM = ABSENCE
FECAL COLIFORM = ABSENCE
E COLI = ABSENCE
DILUTION: 1.0, 0.1, 0.01 ML

COLIFORM=<20/FECAL=<20/ECOLI=<20/100ML

ANALYST: LLW/MO
DATE START: 2-27-06
DATE COMPLETED: 3-1-06
DATE REPORTED: 3-1-06
TIME START: 1100AM
TIME COMPLETED: 700AM
METHOD NAME: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227
LAB DIRECTOR, LINDA L WEBSTER, PHONE 760-344-2532

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO: M9945
TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE
RECEIVED: 2-28-06 1235PM ANALYSIS:
DISTRICT
SAMPLED FROM CLIENT:
DATE GARDENS

SAMPLED BY: JASON
DATE/TIME: 2-28-06 1130AM
TYPE OF SAMPLE: RAW
CHLORINE: UV
SAMPLE SITE: FINAL EFFLUENT

SITE CODE: 21-2

TOTAL COLIFORM ABSENCE
FECAL COLIFORM = ABSENCE
E COLI = ABSENCE
DILUTION: 1.0, 0.1, 0.01 ML

COLIFORM=<20/FECAL=<20/ECOLI=<20/100ML

ANALYST: LLW/MO
DATE START: 2-28-06
DATE COMPLETED: 3-2-06
DATE REPORTED: 3-2-06
TIME START: 100PM
TIME COMPLETED: 200PM
METHOD: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227
LAB DIRECTOR: LINDA L WEBSTER, PHONE 760-344-2532

DATE 6. Feb 06

RECEIVED
MAR 14 2006
REGION 7

BACTERIOLOGICAL ANALYSIS OF WATER LAB NO: M9863

TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE

RECEIVED: 2-21-06 745AM ANALYSIS:

SAMPLED FROM CLIENT: DISTRICT

DATE GARDENS

SAMPLED BY: ROD

DATE/TIME: 2-21-06

TYPE OF SAMPLE: RAW

CHLORINE: UV

SITE CODE: 21-2

SAMPLE SITE: FINAL EFFLUENT

TOTAL COLIFORM ABSENCE

FECAL COLIFORM = ABSENCE

E COLI = ABSENCE

DILUTION: 1.0, 0.1, 0.01 ML

ANALYST: LLW/MO COLIFORM=<20/FECAL=<20/ECOLI=<20/100ML

DATE START: 2-21-06 TIME START: 830AM

DATE COMPLETED: 2-23-06 TIME COMPLETED: 730AM

DATE REPORTED: 2-23-06 METHOD: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227

LAB DIRECTOR: LINDA L WEBSTER , PHONE 760-344-2532

RECEIVED

1 4 2006

REGION 7

BACTERIOLOGICAL ANALYSIS OF WATER
TESTED AT ATS LABORATORIES, BRAWLEY, CA DATE LAB NO: M9824

RECEIVED: 2-13-06 815AM ANALYSIS:

SAMPLED FROM CLIENT: DISTRICT:

DATE GARDENS

SAMPLED BY: JASON
DATE/TIME: 2-13-06
TYPE OF SAMPLE: RAW
CHLORINE: UV
SAMPLE SITE: FINAL EFFLUENT

SITE CODE 21-2

TOTAL COLIFORM = PRESENCE
FECAL COLIFORM = PRESENCE
E COLI = PRESENCE

DILUTION: 1.0, 0.1, 0.01 ML

COLIFORM=800/FECAL=170/ECOLI=110/100ML

ANALYST: LLW/MO

DATE START: 2-13-06 TIME START: 900AM
DATE COMPLETED: 2-16-06 TIME COMPLETED: 600AM
DATE REPORTED: 2-16-06 METHOD NAME: 9221B/E/F

ATS LABORATORIES 104 S 8TH ST., BRAWLEY, CA 92227
LAB DIRECTOR, LINDA L WEBSTER, PHONE 760-344-2532

RECEIVED
1 4 2006
REGION 7

5-5-06

ATTENTION Jose Carter

From - Rocky WTS

FEB. 06 DATE 6. BAC-T

&

March 06 DATE 6. BAC-T

***** BACTERIOLOGICAL ANALYSIS OF WATER ****\