

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN

WDID NO.: 7A1310570011
ORDER NO.: R7-2003-0054
NPDES NO.: CA0104841
REPORTING FREQUENCY: MONTHLY

MONITORING AND REPORTING PROGRAM
FOR DATE GARDENS MOBILE HOME PARK
MONTH MAY
YEAR 2006

TYPE OF SAMPLE:	EFFLUENT						
CONSTITUENTS	Flow	Sus. Solids	20°C BOD ₅	pH	E. Coli	Chlorine	TDS
FREQUENCY	Daily	Monthly	Monthly	Monthly	5 Samples/Mo.	Daily	Monthly
DESCRIPTION		24-Hr. Comp.	24-Hr. Comp.	Grab	Grab	Grab	Grab
UNITS	mgd	mg/L	mg/L	pH UNITS	MPN/100mL	mg/L	mg/L
REQUIREMENTS							
30-DAY MEAN	0.021	30	30	6.0-9.0	126	0.01	2000
7-DAY MEAN		45	45	6.0-9.0			2500
MAXIMUM					400	0.02	
DATE OF SAMPLE							
1	0.0098						
2	0.0093						
3	0.0094	1.3	3.1	7.1		0	824.0
4	0.0093				2		
5	0.0092						
6	0.0094						
7	0.0093						
8	0.0098						
9	0.0099				2		
10	0.0093						
11	0.0095						
12	0.0094						
13	0.0098						
14	0.0096						
15	0.0089				2		
16	0.0093						
17	0.0088				2		
18	0.0084					0	
19	0.0086						
20	0.0094						
21	0.0090						
22	0.0098						
23	0.0098						
24	0.0099						
25	0.0097						
26	0.0098						
27	0.0093						
28	0.0096						
29	0.0098						
30	0.0098						
31	0.0093				170		
30-DAY MEAN	0.0094	1.3	3.1	7.1	5	0	824.0
7-DAY MEAN							
MAXIMUM	0.0099	1.3	3.1	7.1	170	0	824.0

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: Rocky Anderson

RECEIVED

JUN 14 2006

REASON 7

Page 1 of 2

MONTHLY REPORT



Imperial Valley Environmental Laboratory

331 West 2nd Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1072
Sample ID: M1072
Sample Site: Effluent
Collected by: Hector O
Date Sampled and Time: 05-04-06, 2:00pm
Temperature: 25° Celcius

Received by: Patty Hardin
Date Received: 05-04-06
Time Received: 2:57pm
Test Start Time: 3:07pm
Chlorine Residual: 0
Date Test Ended: 05-05-06
Test End Time: 2:30pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
05-05-06	Total Coliform -	MPN by MTF	<2	MPN- 100mL. Water
05-05-06	Fecal Coliform -	MPN by MTF	<2	MPN- 100mL. Water
05-05-06	E. Coli -	MPN by MTF	<2	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED
JUN 15 2006
REGION 7



Imperial Valley Environmental Laboratory

331 West 2nd Street
 Calexico CA, 92231
 (Tel) 760-357-8764
 (Fax) 760-357-8765
 ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1075
 Sample ID: M1075
 Sample Site: Effluent
 Collected by: Hector O
 Date Sampled and Time: 05-09-06, 10:00am
 Temperature: 7° Celcius

Received by: Patty Hardin
 Date Received: 05-09-06
 Time Received: 11:25am
 Test Start Time: 11:35am
 Chlorine Residual: 0
 Date Test Ended: 05-11-06
 Test End Time: 11:45am

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
05-11-06	Total Coliform -	MPN by MTF	<2	MPN- 100mL. Water
05-11-06	Fecal Coliform -	MPN by MTF	<2	MPN- 100mL. Water
05-11-06	E. Coli -	MPN by MTF	<2	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED

JUN 1 5 2006

REGION 7



Imperial Valley Environmental Laboratory
 331 West 2nd Street
 Calexico CA, 92231
 (Tel) 760-357-8764
 (Fax) 760-357-8765
 ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1084
 Sample ID: M1084
 Sample Site: Effluent
 Collected by: Hector O
 Date Sampled and Time: 05-15-06, 3:17pm
 Temperature: 28° Celcius

Received by: Patty Hardin
 Date Received: 05-15-06
 Time Received: 4:20pm
 Test Start Time: 4:30pm
 Chlorine Residual: 0
 Date Test Ended: 05-17-06
 Test End Time: 4:15pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
05-17-06	Total Coliform -	MPN by MTF	300	MPN- 100mL. Water
05-17-06	Fecal Coliform -	MPN by MTF	<2	MPN- 100mL. Water
05-17-06	E. Coli -	MPN by MTF	<2	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED

JUN 1 4 2006

REGION 7



Imperial Valley Environmental Laboratory

331 West 2nd Street
 Calexico CA, 92231
 (Tel) 760-357-8764
 (Fax) 760-357-8765

ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1105

Sample ID: M1105

Sample Site: Effluent

Collected by: Hector O

Date Sampled and Time: 05-31-06, 12:00pm

Temperature: 25° Celcius

Received by: Patty Hardin

Date Received: 05-31-06

Time Received: 1:20pm

Test Start Time: 1:30pm

Chlorine Residual: 0

Date Test Ended: 06-03-06

Test End Time: 1:37pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
06-03-06	Total Coliform --	MPN by MTF	170	MPN- 100mL. Water
06-03-06	Fecal Coliform -	MPN by MTF	170	MPN- 100mL. Water
06-03-06	E. Coli -	MPN by MTF	170	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED

JUN 1 4 2006

REGION 7