

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN**

WDID NO.: 7A1310570011
 ORDER NO.: R7-2003-0054
 NPDES NO.: CA0104841
 REPORTING FREQUENCY: MONTHLY

**MONITORING AND REPORTING PROGRAM
 FOR DATE GARDENS MOBILE HOME PARK**
 MONTH March
 YEAR 2007

TYPE OF SAMPLE:	EFFLUENT						
CONSTITUENTS	Flow	Sus. Solids	20°C BOD ₅	pH	E. Coli	Chlorine	TDS
FREQUENCY	Daily	Monthly	Monthly	Monthly	5 Samples/Mo.	Daily	Monthly
DESCRIPTION		24-Hr. Comp.	24-Hr. Comp.	Grab	Grab	Grab	Grab
UNITS	mgd	mg/L	mg/L	pH UNITS	MPN/100mL	mg/L	mg/L
REQUIREMENTS							
30-DAY MEAN	0.021	30	30	6.0-9.0	126	0.01	2000
7-DAY MEAN		45	45	6.0-9.0			2500
MAXIMUM					400	0.02	
DATE OF SAMPLE							
1	0.0085						
2	0.0087						
3	0.0089						
4	0.0087						
5	0.0077						
6	0.0075						
7	0.0076						
8	0.0074						
9	0.0068						
10	0.0060						
11	0.0098						
12	0.0099						
13	0.0093				2		
14	0.0077						
15	0.0074						
16	0.0074						
17	0.0071						
18	0.0079						
19	0.0075				130		
20	0.0072	1.3	5.0	7.14	80	0	818.0
21	0.0083				80		
22	0.0075						
23	0.0078						
24	0.0074						
25	0.0073						
26	0.0078						
27	0.0088				50		
28	0.0086						
29	0.0081						
30	0.0084						
31	0.0080						
30-DAY MEAN	0.0080	1.3	5.0	7.14	38	0	818.0
7-DAY MEAN							
MAXIMUM	0.0099						

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: *R. Vardanyan*

Page 1 of 2

RECEIVED
 APR 12 2007
 MONTHLY REPORT
 REGION 7



Imperial Valley Environmental Laboratory
501 E. Third Street
Calxico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1557
Sample ID: M1557R
Sample Site: Effluent
Collected by: Hector O
Date Sampled and Time: 03-19-07, 1:20pm
Temperature: 12° Celcius

Received by: Patty Hardin
Date Received: 03-19-07
Time Received: 2:38pm
Test Start Time: 2:48pm
Chlorine Residual: 0
Date Test Ended: 03-21-07
Test End Time: 1:02pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
03-21-07	Total Coliform -	MPN by MTF	130	MPN- 100mL. Water
03-21-07	Fecal Coliform -	MPN by MTF	130	MPN- 100mL. Water
03-21-07	E. Coli -	MPN by MTF	130	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED
APR 12 2007
REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1560
Sample ID: M1560-3R
Sample Site: Effluent
Collected by: Hector O
Date Sampled and Time: 03-20-07, 1:22pm
Temperature: 10° Celcius

Received by: Patty Hardin
Date Received: 03-20-07
Time Received: 3:10pm
Test Start Time: 3:20pm
Chlorine Residual: 0
Date Test Ended: 03-23-07
Test End Time: 2:47pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
03-23-07	Total Coliform --	MPN by MTF	130	MPN- 100mL. Water
03-23-07	Fecal Coliform -	MPN by MTF	80	MPN- 100mL. Water
03-23-07	E. Coli -	MPN by MTF	80	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED

APR 12 2007

REGION 7


Imperial Valley Environmental Laboratory

501 E. Third Street
 Calexico CA, 92231
 (Tel) 760-357-8764
 (Fax) 760-357-8765
 ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1567
 Sample ID: M1567R
 Sample Site: Effluent
 Collected by: Hector O
 Date Sampled and Time: 03-21-07, 1:30pm
 Temperature: 27° Celcius

Received by: Patty Hardin
 Date Received: 03-21-07
 Time Received: 3:35pm
 Test Start Time: 3:45pm
 Chlorine Residual: 0
 Date Test Ended: 03-24-07
 Test End Time: 2:32pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
03-24-07	Total Coliform --	MPN by MTF	80	MPN- 100mL. Water
03-24-07	Fecal Coliform --	MPN by MTF	80	MPN- 100mL. Water
03-24-07	E. Coli --	MPN by MTF	80	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED
 APR 12 2007
 REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
Calxico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1574
Sample ID: M1574R
Sample Site: Effluent
Collected by: Hector O
Date Sampled and Time: 03-27-07, 12:30pm
Temperature: 25° Celcius

Received by: Patty Hardin
Date Received: 03-27-07
Time Received: 2:31pm
Test Start Time: 2:41pm
Chlorine Residual: 0
Date Test Ended: 03-29-07
Test End Time: 1:45pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
03-29-07	Total Coliform -	MPN by MTF	50	MPN- 100mL. Water
03-29-07	Fecal Coliform -	MPN by MTF	50	MPN- 100mL. Water
03-29-07	E. Coli -	MPN by MTF	50	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED
APR 12 2007
REGION 7



Imperial Valley Environmental Laboratory
 501 E. Third Street
 Calexico CA, 92231
 (Tel) 760-357-8764
 (Fax) 760-357-8765
 ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1547
 Sample ID: M1547R
 Sample Site: Effluent
 Collected by: Hector O
 Date Sampled and Time: 03-13-07, 1:10pm
 Temperature: 16° Celcius

Received by: Patty Hardin
 Date Received: 03-13-07
 Time Received: 2:30pm
 Test Start Time: 2:40pm
 Chlorine Residual: 0
 Date Test Ended: 03-15-07
 Test End Time: 2:27pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
03-15-07	Total Coliform -	MPN by MTF	<2	MPN- 100mL. Water
03-15-07	Fecal Coliform -	MPN by MTF	<2	MPN- 100mL. Water
03-15-07	E. Coli -	MPN by MTF	<2	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED
 APR 12 2007
 REGION 7