

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
 COLORADO RIVER BASIN

WDID NO.: 7A1310570011
 ORDER NO.: R7-2003-0054
 NPDES NO.: CA0104841
 REPORTING FREQUENCY: MONTHLY

MONITORING AND REPORTING PROGRAM
 FOR DATE GARDENS MOBILE HOME PARK
 MONTH JUNE
 YEAR 2007

TYPE OF SAMPLE:	EFFLUENT						
CONSTITUENTS	Flow	Sus. Solids	20°C BOD ₅	pH	E. Coli	Chlorine	TDS
FREQUENCY	Daily	Monthly	Monthly	Monthly	5 Samples/Mo.	Daily	Monthly
DESCRIPTION		24-Hr. Comp.	24-Hr. Comp.	Grab	Grab	Grab	Grab
UNITS	mgd	mg/L	mg/L	pH UNITS	MPN/100mL	mg/L	mg/L
REQUIREMENTS							
30-DAY MEAN	0.021	30	30	6.0-9.0	126	0.01	2000
7-DAY MEAN		45	45	6.0-9.0			2500
MAXIMUM					400	0.02	
DATE OF SAMPLE							
1	0.0078						
2	0.0075						
3	0.0074						
4	0.0079	✓	✓	✓	4	✓	✓
5	0.0075	7.4	3.7	7.5	2	0	860.0
6	0.0069						
7	0.0058				8		
8	0.0069						
9	0.0087						
10	0.0098						
11	0.0078						
12	0.0079						
13	0.0070				2		
14	0.0087				240		
15	0.0081						
16	0.0074						
17	0.0085				51 ✓		
18	0.0080				51256 on		
19	0.0087				26		
20	0.0085						
21	0.0079						
22	0.0083						
23	0.0087						
24	0.0096						
25	0.0084						
26	0.0084						
27	0.0087						
28	0.0086						
29	0.0084						
30	0.0080						
30-DAY MEAN	0.0092	7.4	3.7	7.5	8	0	860.0
7-DAY MEAN							
MAXIMUM	0.0099	7.4	3.7	7.5	240	0	860.0

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: R. Anderson

RECEIVED

JUL 10 2007

REGION 7

07/09/2007

Mr. Jose Cortez
C.R.W.Q.C.B.
73-720 Fred Waring Drive Suite 100
Palm Desert, Ca. 92260

Re: 2007 Second Quarter Monitoring Report for the Date Gardens.

Dear Mr. Cortez,

I am pleased to report that for the state that for the Second Quarter of 2007, we had no violations to report. Please feel free to contact me at 760 427- 4235 if you have any questions or comments regarding this report.

Sincerely,



Mr. Rocky Vandergriff.
Contract Chief Operator
Date Gardens RV Park

RECEIVED

JUL 10 2007

REGION 7

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
 COLORADO RIVER BASIN

18

ORDER NO.: R7-2003-0054
 NPDES NO.: CA0104841
 REPORTING FREQUENCY: QUARTERLY

MONITORING AND REPORTING PROGRAM
 FOR DATE GARDENS MOBILE HOME PARK
 QUARTER: SECOND
 YEAR: 2007

TYPE OF SAMPLE:	INFLUENT		RECEIVING WATER - R1 (UPSTREAM)			
	20°C BOD ₅	Sus. Solids	DO	Hydrogen Ion	Chlorine	E. Coli
FREQUENCY	Quarterly	Quarterly	Quarterly	Quarterly	Quarterly	Quarterly
DESCRIPTION	24-Hr. Comp.	24-Hr. Comp.	Grab	Grab	Grab	Grab
UNITS	mg/L	mg/L	mg/L	pH Units	mg/L	MPN/100mL
REQUIREMENTS						
30-DAY MEAN						
7-DAY MEAN						
MAXIMUM						
DATE OF SAMPLE						
1						
2						
3						
4						
5	750.0	78.0				
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20			7.5	7.7	0	1600.0
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
31						
QUARTER MEAN	750	78.0	7.5	7.7	0	1600.0
MAXIMUM	750	78.0	7.5	7.7	0	1600.0

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: R. Nardone

RECEIVED

JUL 10 2007

REGION 7

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN

WDID NO.: 7A1310570011
ORDER NO.: R7-2003-0054
NPDES NO.: CA0104841
REPORTING FREQUENCY: QUARTERLY

MONITORING AND REPORTING PROGRAM
FOR DATE GARDENS MOBILE HOME PARK
QUARTER: SECOND
YEAR: 2007

RECEIVING WATER - R2 (DOWNSTREAM)					EFFLUENT	
CONSTITUENTS	DO	Hydrogen Ion	Chlorine	E. Coli	20°C BOD ₅	Sus. Solids
FREQUENCY	Quarterly	Quarterly	Quarterly	Quarterly		
DESCRIPTION	Grab	Grab	Grab	Grab	% Removal	% Removal
UNITS	mg/L	pH Units	mg/L	MPN/100mL		
REQUIREMENTS						
30-DAY MEAN					%	%
MINIMUM	5.0	6.0			85	85
MAXIMUM		9.0	0.02			
DATE OF SAMPLE						
1						
2						
3						
4						
5					99	90
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20	5.0	7.5	0			
21						
22						
23						
24						
25						
26						
27						
28				2		
29						
30						
31						
QUARTER MEAN					99	90
MAXIMUM						

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: R. N. [Signature]

RECEIVED
JUL 17 2007
QUARTERLY REPORT
REGION 7

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN

WDID NO.: 7A1310570011
ORDER NO.: R7-2003-0054
NPDES NO.: CA0104841
REPORTING FREQUENCY: QUARTERLY

MONITORING AND REPORTING PROGRAM
FOR DATE GARDENS MOBILE HOME PARK
QUARTER: SECOND
YEAR: 2007

1. Is there receiving water at Station R-1? Yes No
If the answer is no proceed to Station R-2 Section, otherwise continue with the following questions.
PLEASE CIRCLE THE APPROPRIATE ANSWER

Station R-1 Section (The following questions refer to Station R-1)

- 1. Is there the presence of floating or suspended matter present? Yes
- 2. Is there discoloration present? Yes
- 3. Is there aquatic life present? Yes
- 4. Is there visible film, sheen or coating present? Yes
- 5. Is there fungi, slime or objectionable growths present? Yes
- 6. Is there potential nuisance conditions present? Yes

No
No
No
No
No
No

Station R-2 Section (The following questions refer to Station R-2)

- Is there the presence of floating or suspended matter present? Yes
- Is there discoloration present? Yes
- Is there aquatic life present? Yes
- Is there visible film, sheen or coating present? Yes
- Is there fungi, slime or objectionable growths present? Yes
- Is there potential nuisance conditions present? Yes

No
No
No
No
No
No

Any additional comments.

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: R. Wardenoff

RECEIVED

JUL 10 2007

REGION 7


Imperial Valley Environmental Laboratory

501 E. Third Street
 Calexico CA, 92231
 (Tel) 760-357-8764
 (Fax) 760-357-8765
 ELAP Certification # 2524

Client: Date Gardens RV. WWTP

Date Reported: 06-13-07

Contact : Rocky V.

Date Sampled: 06-05-07

Date Received: 06-05-07

Sample Type: Water

Log Number: 1494

Sample ID: Effluent (1494-2), Influent (1494-1)

Analytical Results


Analysis	Effluent	Influent	Units	Method	DLR	Analysis
						Date
BOD	3.7	750.0	mg/L	SM 5210B	1	06-11-07
Tot. Suspended Solids	7.4	78.0	mg/L	SM 2540D	1	06-08-07
Total Dissolved Solids	860.0	-----	mg/L	SM 2540C	1	06-08-07
pH	7.45	-----	units	SM 4500HB	1	06-05-07

Miguel E. Ortega, Laboratory Director

RECEIVED

JUL 16 2007

REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
 Calexico CA, 92231
 (Tel) 760-357-8764
 (Fax) 760-357-8765
 ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1705
 Sample ID: M1705R
 Sample Site: Effluent
 Collected by: Hector O
 Date Sampled and Time: 06-04-07, 9:32am
 Temperature: 23° Celcius

Received by: Patty Hardin
 Date Received: 06-04-07
 Time Received: 11:00am
 Test Start Time: 11:10am
 Chlorine Residual: 0
 Date Test Ended: 06-07-07
 Test End Time: 11:03am

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
06-07-07	Total Coliform --	MPN by MTF	4	MPN- 100mL. Water
06-07-07	Fecal Coliform -	MPN by MTF	4	MPN- 100mL. Water
06-07-07	E. Coli -	MPN by MTF	4	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED

JUL 10 2007

REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1710
Sample ID: M1710R
Sample Site: Effluent
Collected by: Hector O
Date Sampled and Time: 06-05-07, 2:15pm
Temperature: 8° Celcius

Received by: Patty Hardin
Date Received: 06-05-07
Time Received: 2:35pm
Test Start Time: 3:00pm
Chlorine Residual: 0
Date Test Ended: 06-05-07
Test End Time: 2:00pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
06-05-07	Total Coliform -	MPN by MTF	<2	MPN- 100mL. Water
06-05-07	Fecal Coliform -	MPN by MTF	<2	MPN- 100mL. Water
06-05-07	E. Coli -	MPN by MTF	<2	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED
JUL 10 2007
REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
 Calexico CA, 92231
 (Tel) 760-357-8764
 (Fax) 760-357-8765
 ELAP Certification # 2524

Client: Date Gardens RV.


Contact: Rocky V.

Log Number: M1717
 Sample ID: M1717R
 Sample Site: Effluent
 Collected by: Hector O
 Date Sampled and Time: 06-07-07, 11:30am
 Temperature: 1° Celcius

Received by: Patty Hardin
 Date Received: 06-07-07
 Time Received: 1:10pm
 Test Start Time: 1:37pm
 Chlorine Residual: 0
 Date Test Ended: 06-10-07
 Test End Time: 12:30pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
06-10-07	Total Coliform --	MPN by MTF	13	MPN- 100mL. Water
06-10-07	Fecal Coliform -	MPN by MTF	8	MPN- 100mL. Water
06-10-07	E. Coli -	MPN by MTF	8	MPN- 100mL. Water


 Miguel E. Ortega, Laboratory Director

RECEIVED
 JUL 10 2007
 REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
 Calexico CA, 92231
 (Tel) 760-357-8764
 (Fax) 760-357-8765
 ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1728
 Sample ID: M1728R
 Sample Site: Effluent
 Collected by: Hector O
 Date Sampled and Time: 06-13-07, 2:10pm
 Temperature: 5° Celcius

Received by: Patty Hardin
 Date Received: 06-13-07
 Time Received: 3:00pm
 Test Start Time: 3:25pm
 Chlorine Residual: 0
 Date Test Ended: 06-15-07
 Test End Time: 1:33pm

Analytical Results


Date	Final Result	Test Name	Count	Volume Tested
06-15-07	Total Coliform --	MPN by MTF	<2	MPN- 100mL. Water
06-15-07	Fecal Coliform -	MPN by MTF	<2	MPN- 100mL. Water
06-15-07	E. Coli -	MPN by MTF	<2	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED

JUL 10 2007

REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1732
Sample ID: M1732R
Sample Site: Effluent
Collected by: Hector O
Date Sampled and Time: 06-14-07, 12:51pm
Temperature: 38° Celcius

Received by: Patty Hardin
Date Received: 06-14-07
Time Received: 2:05pm
Test Start Time: 2:15pm
Chlorine Residual: 0
Date Test Ended: 06-17-07
Test End Time: 1:35pm

Analytical Results


Date	Final Result	Test Name	Count	Volume Tested
06-17-07	Total Coliform --	MPN by MTF	240	MPN- 100mL. Water
06-17-07	Fecal Coliform -	MPN by MTF	240	MPN- 100mL. Water
06-17-07	E. Coli -	MPN by MTF	240	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED

JUL 10 2007

REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
 Calexico CA, 92231
 (Tel) 760-357-8764
 (Fax) 760-357-8765
 ELAP Certification # 2524

Client: Date Gardens RV. WWTP

Contact : Rocky V.

Log Number: 1524

Sample ID: R-1 (1524-1)

Date Reported: 06-26-07

Date Sampled: 06-20-07

Date Received: 06-20-07

Sample Type: Water

Analytical Results


Analysis	R-1	Units	Method	DLR	Analysis
					Date
Dissolved Oxygen	7.52	mg/L	SM 4500OG	1	06-20-07
Chlorine	0.2	mg/L	SM 4500Clb	0.1	06-20-07
pH	7.73	units	SM 4500HB	1	06-20-07

Miguel E. Ortega, Laboratory Director

RECEIVED

JUL 1 2007

REGION 7



Imperial Valley Environmental Laboratory
 501 E. Third Street
 Calexico CA, 92231
 (Tel) 760-357-8764
 (Fax) 760-357-8765
 ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1745
 Sample ID: M1745-1R
 Sample Site: R-1
 Collected by: Hector O
 Date Sampled and Time: 06-20-07, 11:00am
 Temperature: 5° Celcius

Received by: Patty Hardin
 Date Received: 06-20-07
 Time Received: 12:50pm
 Test Start Time: 1:35pm
 Chlorine Residual: 0
 Date Test Ended: 06-22-07
 Test End Time: 12:38pm

Analytical Results


Date	Final Result	Test Name	Count	Volume Tested
06-22-07	Total Coliform --	MPN by MTF	≥1600	MPN- 100mL. Water
06-22-07	Fecal Coliform -	MPN by MTF	≥1600	MPN- 100mL. Water
06-22-07	E. Coli -	MPN by MTF	≥1600	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED

JUL 16 2007

REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
 Calexico CA, 92231
 (Tel) 760-357-8764
 (Fax) 760-357-8763
 ELAP Certification # 2524

Client: Date Gardens RV, WWTP

Contact: Rocky V.

Log Number: 1524

Sample ID: R-2 (1524-2)

Date Reported: 06-26-07

Date Sampled: 06-20-07

Date Received: 06-20-07

Sample Type: Water

Analytical Results

Analysis	R-2	Units	Method	Analysis	
				ELR	Date
Dissolved Oxygen	5.00	mg/l	SM 4500OG	1	06-20-07
Chlorine	0.2	mg/L	SM 4500Clb	0.1	06-20-07
pH	7.50	unit's	SM 4500HB	1	06-20-07

Miguel E. Ortega, Laboratory Director

RECEIVED

JUL 10 2007

REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
Calxico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M1758
Sample ID: M1758R
Sample Site: R-2
Collected by: Hector O
Date Sampled and Time: 06-28-07, 12:00pm
Temperature: 31° Celcius

Received by: Patty Hardin
Date Received: 06-28-07
Time Received: 1:25pm
Test Start Time: 1:35pm
Chlorine Residual: 0
Date Test Ended: 06-30-07
Test End Time: 12:00pm

Analytical Results

<u>Date</u>	<u>Final Result</u>	<u>Test Name</u>	<u>Count</u>	<u>Volume Tested</u>
06-30-07	Total Coliform -	MPN by MTF	<2	MPN- 100mL. Water
06-30-07	Fecal Coliform -	MPN by MTF	<2	MPN- 100mL. Water
06-30-07	E. Coli -	MPN by MTF	<2	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED

JUL 1 2007

REGION 7