

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN

MONITORING AND REPORTING PROGRAM
FOR DATE GARDENS MOBILE HOME PARK

WDID NO.: 7A1310570011

ORDER NO.: R7-2003-0054

NPDES NO.: CA0104841

REPORTING FREQUENCY: MONTHLY

MONTH January
YEAR 2008

TYPE OF SAMPLE:	EFFLUENT						
CONSTITUENTS	Flow	Sus. Solids	20°C BOD ₅	pH	E. Coli	Chlorine	TDS
FREQUENCY	Daily	Monthly	Monthly	Monthly	5 Samples/Mo.	Daily	Monthly
DESCRIPTION		24-Hr. Comp.	24-Hr. Comp.	Grab	Grab	Grab	Grab
UNITS	mgd	mg/L	mg/L	pH UNITS	MPN/100mL	mg/L	mg/L
REQUIREMENTS					126	0.01	2000
30-DAY MEAN	0.021	30	30	6.0-9.0			2500
7-DAY MEAN		45	45	6.0-9.0			
MAXIMUM					400	0.02	
DATE OF SAMPLE							
1	0.0067						
2	0.0068				4		
3	0.0059						
4	0.0054						
5	0.0069						
6	0.0066						
7	0.0071						
8	0.0073						
9	0.0078				2		
10	0.0073						
11	0.0046						
12	0.0087						
13	0.0084						
14	0.0088				130		
15	0.0086						
16	0.0056						
17	0.0067						
18	0.0081						
19	0.0083						
20	0.0085						
21	0.0089						
22	0.0081	3.60	6.30	6.72	2	0	968.0
23	0.0078						
24	0.0081				2		
25	0.0091						
26	0.0088						
27	0.0085						
28	0.0063						
29	0.0069						
30	0.0079						
31	0.0085						
30-DAY MEAN	0.0075	3.60	6.30	6.72	5	0	968.0
7-DAY MEAN		3.60	6.30	6.72		0	968.0
MAXIMUM	0.0091	3.60	6.30	6.72	130	0	968.0

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: Rocky Stenberg

RECEIVED

FEB 05 2008



Imperial Valley Environmental Laboratory
 501 E. Third Street
 Calexico CA, 92231
 (Tel) 760-357-8764
 (Fax) 760-357-8765
 ELAP Certification # 2524

Client: Date Gardens RV. WWTP

Contact : Rocky V.

Log Number: 1813

Sample ID: Effluent (1813-2)

Date Reported: 01-29-08

Date Sampled: 01-22-08

Date Received: 01-22-08

Sample Type: Water

Analytical Results

Analysis	Effluent	Units	Method	DLR	Analysis
					Date
BOD	6.30	mg/L	SM 5210B	1	01-28-08
Tot. Suspended Solids	3.60	mg/l.	SM 2540D	1	01-26-08
Total Dissolved Solids	968.0	mg/L	SM 2540C	1	01-26-08
pH	6.72	units	SM 4500HB	1	01-22-08
Chlorine	ND	mg/L	EPA 330.5	0.2	01-22-08

Miguel E. Ortega, Laboratory Director

RECEIVED

FEB 07 2008

REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M2119
Sample ID: M2119R
Sample Site: Effluent
Collected by: Hector O
Date Sampled and Time: 01-03-08, 12:10pm
Temperature: 7° Celcius

Received by: Patty Hardin
Date Received: 01-03-08
Time Received: 1:55pm
Test Start Time: 2:20pm
Chlorine Residual: 0
Date Test Ended: 01-05-08
Test End Time: 1:30pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
01-05-08	Total Coliform --	MPN by MTF	4	MPN- 100mL. Water
01-05-08	Fecal Coliform -	MPN by MTF	4	MPN- 100mL. Water
01-05-08	E. Coli -	MPN by MTF	4	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED
FEB 07 2008
REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
 Calexico CA, 92231
 (Tel) 760-357-8764
 (Fax) 760-357-8765
 ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M2129
 Sample ID: M2129R
 Sample Site: Effluent
 Collected by: Hector O
 Date Sampled and Time: 01-09-08, 12:15pm
 Temperature: 3° Celcius

Received by: Patty Hardin
 Date Received: 01-09-08
 Time Received: 1:50pm
 Test Start Time: 2:20pm
 Chlorine Residual: 0
 Date Test Ended: 01-13-08
 Test End Time: 1:35pm

Analytical Results


Date	Final Result	Test Name	Count	Volume Tested
01-13-08	Total Coliform -	MPN by MTF	13	MPN- 100mL. Water
01-13-08	Fecal Coliform -	MPN by MTF	<2	MPN- 100mL. Water
01-13-08	E. Coli -	MPN by MTF	<2	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED

FEB 07 2008

REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
 Calexico CA, 92231
 (Tel) 760-357-8764
 (Fax) 760-357-8765
 ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M2135
 Sample ID: M2135R
 Sample Site: Effluent
 Collected by: Hector O
 Date Sampled and Time: 01-14-08, 12:30pm
 Temperature: 4° Celcius

Received by: Patty Hardin
 Date Received: 01-14-08
 Time Received: 2:10pm
 Test Start Time: 2:35pm
 Chlorine Residual: 0
 Date Test Ended: 01-16-08
 Test End Time: 1:05pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
01-16-08	Total Coliform -	MPN by MTF	130	MPN- 100mL. Water
01-16-08	Fecal Coliform -	MPN by MTF	130	MPN- 100mL. Water
01-16-08	E. Coli -	MPN by MTF	130	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED

FEB 05 2008

REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M2149
Sample ID: M2149R
Sample Site: Effluent
Collected by: Hector O
Date Sampled and Time: 01-22-08, 9:30am
Temperature: 1° Celcius

Received by: Patty Hardin
Date Received: 01-22-08
Time Received: 11:23am
Test Start Time: 11:55am
Chlorine Residual: 0
Date Test Ended: 01-24-08
Test End Time: 10:50am

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
01-24-08	Total Coliform --	MPN by MTF	<2	MPN- 100mL. Water
01-24-08	Fecal Coliform -	MPN by MTF	<2	MPN- 100mL. Water
01-24-08	E. Coli -	MPN by MTF	<2	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED
FEB 03 2008
REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M2156
Sample ID: M2156R
Sample Site: Effluent
Collected by: Hector O
Date Sampled and Time: 01-24-08, 11:00am
Temperature: 2° Celcius

Received by: Patty Hardin
Date Received: 01-24-08
Time Received: 3:14pm
Test Start Time: 3:40pm
Chlorine Residual: 0
Date Test Ended: 01-26-08
Test End Time: 1:30pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
01-26-08	Total Coliform -	MPN by MTF	<2	MPN- 100mL. Water
01-26-08	Fecal Coliform -	MPN by MTF	<2	MPN- 100mL. Water
01-26-08	E. Coli -	MPN by MTF	<2	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director

RECEIVED

FEB 07 2008

REGION 7