

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN

WDID NO.: 7A1310570011
ORDER NO.: R7-2003-0054
NPDES NO.: CA0104841
REPORTING FREQUENCY: MONTHLY

**MONITORING AND REPORTING PROGRAM
FOR DATE GARDENS MOBILE HOME PARK**

MONTH March
YEAR 2008

TYPE OF SAMPLE:	EFFLUENT						
CONSTITUENTS	Flow	Sus. Solids	20°C BOD ₅	pH	E. Coli	Chlorine	TDS
FREQUENCY	Daily	Monthly	Monthly	Monthly	5 Samples/Mo.	Daily	Monthly
DESCRIPTION		24-Hr. Comp.	24-Hr. Comp.	Grab	Grab	Grab	Grab
UNITS	mgd	mg/L	mg/L	pH UNITS	MPN/100mL	mg/L	mg/L
REQUIREMENTS							
30-DAY MEAN	0.021	30	30	6.0-9.0	126	0.01	2000
7-DAY MEAN		45	45	6.0-9.0			2500
MAXIMUM					400	0.02	
DATE OF SAMPLE							
1	0.0091						
2	0.0096						
3	0.0091						
4	0.0090				2		
5	0.0078						
6	0.0074				2		
7	0.0071						
8	0.0072						
9	0.0073						
10	0.0071						
11	0.0075				30		
12	0.0076						
13	0.0071						
14	0.0081						
15	0.0083						
16	0.0086						
17	0.0081						
18	0.0087	4.3	5.0	6.6	80	0	746.0
19	0.0056						
20	0.0059						
21	0.0057						
22	0.0083						
23	0.0084						
24	0.0059						
25	0.0077				1600		
26	0.0073						
27	0.0069						
28	0.0060						
29	0.0072						
30	0.0073						
31	0.0054						
30-DAY MEAN	0.0075	4.3	5.0	6.6	27	0	746.0
7-DAY MEAN		4.3	5.0	6.6			
MAXIMUM	0.0096				1600		

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: *Rochy Anderson*

RECEIVED

APR 10 2008

REGION 7

01
M3

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN

18

ORDER NO.: R7-2003-0054
NPDES NO.: CA0104841
REPORTING FREQUENCY: QUARTERLY

**MONITORING AND REPORTING PROGRAM
FOR DATE GARDENS MOBILE HOME PARK**

QUARTER : FIRST
YEAR : 2008

TYPE OF SAMPLE:	INFLUENT		RECEIVING WATER - R1 (UPSTREAM)			
	20°C BOD ₅	Sus. Solids	DO	Hydrogen Ion	Chlorine	E. Coli
FREQUENCY	Quarterly	Quarterly	Quarterly	Quarterly	Quarterly	Quarterly
DESCRIPTION	24-Hr. Comp.	24-Hr. Comp.	Grab	Grab	Grab	Grab
UNITS	mg/L	mg/L	mg/L	pH Units	mg/L	MPN/100mL
REQUIREMENTS						
30-DAY MEAN						
7-DAY MEAN						
MAXIMUM						
DATE OF SAMPLE						
1						
2						
3						
4						
5						
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17	✓	✓				
18	210.0	263.0	7.0	7.8	0.0	1600.0
19						
20						
21						
22						
23						
24						
25						
26						
27						
28						
29						
30						
31						
QUARTER MEAN	210.0	263.0	7.0	7.8	0.0	1600.0
MAXIMUM						

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: Rocky Anderson

RECEIVED

APR 10 2008

REGION 7

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN

WDID NO.: 7A1310570011
ORDER NO.: R7-2003-0054
NPDES NO.: CA0104841
REPORTING FREQUENCY: QUARTERLY

**MONITORING AND REPORTING PROGRAM
FOR DATE GARDENS MOBILE HOME PARK**
QUARTER: FIRST
YEAR: 2008

TYPE OF SAMPLE:	RECEIVING WATER - R2 (DOWNSTREAM)					EFFLUENT	
CONSTITUENTS	DO	Hydrogen Ion	Chlorine	E. Coli		20°C BOD ₅	Sus. Solids
FREQUENCY	Quarterly	Quarterly	Quarterly	Quarterly			
DESCRIPTION	Grab	Grab	Grab	Grab		% Removal	% Removal
UNITS	mg/L	pH Units	mg/L	MPN/100mL			
REQUIREMENTS							
30-DAY MEAN						%	%
MINIMUM	5.0	6.0					
MAXIMUM		9.0	0.02				
DATE OF SAMPLE							
1							
2							
3							
4							
5							
6							
7							
8							
9							
10							
11							
12							
13							
14							
15							
16							
17							
18	7.6	7.4	0.0	1600.0		98	98
19							
20							
21							
22							
23							
24							
25							
26							
27							
28							
29							
30							
31							
QUARTER MEAN	7.6	7.4	0.0	1600.0		98	98
MAXIMUM	7.6	7.4	0.0	1600.0		98	98

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

RECEIVED

APR 10 2008

REGION 7

Signature: _____

Rocky Starbuck

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN

WDID NO.: 7A1310570011
ORDER NO.: R7-2003-0054
NPDES NO.: CA0104841
REPORTING FREQUENCY: QUARTERLY

MONITORING AND REPORTING PROGRAM
FOR DATE GARDENS MOBILE HOME PARK
QUARTER: FIRST
YEAR: 2008

1. Is there receiving water at Station R-1?

Yes

No

If the answer is no proceed to Station R-2 Section, otherwise continue with the following questions.
PLEASE CIRCLE THE APPROPRIATE ANSWER

Station R-1 Section (The following questions refer to Station R-1)

- 1. Is there the presence of floating or suspended matter present?
- 2. Is there discoloration present?
- 3. Is there aquatic life present?
- 4. Is there visible film, sheen or coating present?
- 5. Is there fungi, slime or objectionable growths present?
- 6. Is there potential nuisance conditions present?

Yes
Yes
Yes
Yes
Yes
Yes

No
No
No
No
No
No

Station R-2 Section (The following questions refer to Station R-2)

- Is there the presence of floating or suspended matter present?
- Is there discoloration present?
- Is there aquatic life present?
- Is there visible film, sheen or coating present?
- Is there fungi, slime or objectionable growths present?
- Is there potential nuisance conditions present?

Yes
Yes
Yes
Yes
Yes
Yes

No
No
No
No
No
No

Any additional comments.

N/A

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: *Rocky Gardner*

RECEIVED
APR 10 2008
REGION 7



Imperial Valley Environmental Laboratory
 501 E. Third Street
 Calexico CA, 92231
 (Tel) 760-357-8764
 (Fax) 760-357-8765
 ELAP Certification # 2524

Client: Date Gardens RV. WWTP

Date Reported: 03-28-08

Contact : Rocky V.

Date Sampled: 03-18-08

Date Received: 03-18-08

Log Number: 1907

Sample Type: Water

Sample ID: Effluent (1907-1), Influent (1907-1)

Analytical Results


Analysis	Effluent	Influent	Units	Method	DLR	Analysis Date
BOD	5.04	210.0	mg/L	SM 5210B	1	03-24-08
Tot. Suspended Solids	4.30	263.0	mg/L	SM 2540D	1	03-21-08
Total Dissolved Solids	746.0	-----	mg/L	SM 2540C	1	03-21-08
pH	6.60	-----	units	SM 4500HB	1	03-18-08
Chlorine	<0.02	-----	mg/L	EPA 330.5	0.02	03-18-08

Miguel E. Ortega, Laboratory Director

RECEIVED

APR 10 2008

REGION 7



Imperial Valley Environmental Laboratory

501 E. Third Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV. WWTP

Contact : Rocky V.

Log Number: 1921

Sample ID: R-1 (1921-1), R-2 (1921-2)

Date Reported: 03-31-08

Date Sampled: 03-25-08

Date Received: 03-25-08

Sample Type: Water

Analytical Results

<u>Analysis</u>	<u>R-1</u>	<u>R-2</u>	<u>Units</u>	<u>Method</u>	<u>DLR</u>	<u>Analysis Date</u>
Dissolved Oxygen	7.04	7.59	mg/L	SM 4500OG	1	03-25-08
pH	7.79	7.37	units	SM 4500HB	1	03-25-08
Chlorine	<0.02	0.02	mg/L	EPA 330.5	0.02	03-25-08

Miguel E. Ortega, Laboratory Director



Imperial Valley Environmental Laboratory

501 E. Third Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M2257
Sample ID: M2257-2R
Sample Site: R-1
Collected by: Hector O
Date Sampled and Time: 03-25-08, 12:15pm
Temperature: 1° Celcius

Received by: Patty Hardin
Date Received: 03-25-08
Time Received: 2:06pm
Test Start Time: 2:25pm
Chlorine Residual: 0
Date Test Ended: 03-27-08
Test End Time: 2:00pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
03-27-08	Total Coliform --	MPN by MTF	≥1600	MPN- 100mL. Water
03-27-08	Fecal Coliform --	MPN by MTF	≥1600	MPN- 100mL. Water
03-27-08	E. Coli --	MPN by MTF	≥1600	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director



Imperial Valley Environmental Laboratory

501 E. Third Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765

ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M2257
Sample ID: M2257-3R
Sample Site: R-2
Collected by: Hector O
Date Sampled and Time: 03-25-08, 12:20pm
Temperature: 1° Celcius

Received by: Patty Hardin
Date Received: 03-25-08
Time Received: 2:06pm
Test Start Time: 2:25pm
Chlorine Residual: 0
Date Test Ended: 03-27-08
Test End Time: 2:00pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
03-27-08	Total Coliform --	MPN by MTF	≥1600	MPN- 100mL. Water
03-27-08	Fecal Coliform --	MPN by MTF	≥1600	MPN- 100mL. Water
03-27-08	E. Coli --	MPN by MTF	≥1600	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director



Imperial Valley Environmental Laboratory

501 E. Third Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M2219
Sample ID: M2219R
Sample Site: Effluent
Collected by: Hector O
Date Sampled and Time: 03-04-08, 11:45am
Temperature: 1° Celcius

Received by: Patty Hardin
Date Received: 03-04-08
Time Received: 1:06pm
Test Start Time: 1:35pm
Chlorine Residual: 0
Date Test Ended: 03-06-08
Test End Time: 11:45am

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
03-06-08	Total Coliform --	MPN by MTF	<2	MPN- 100mL. Water
03-06-08	Fecal Coliform --	MPN by MTF	<2	MPN- 100mL. Water
03-06-08	E. Coli --	MPN by MTF	<2	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director



Imperial Valley Environmental Laboratory

501 E. Third Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M2225
Sample ID: M2225R
Sample Site: Effluent
Collected by: Hector O
Date Sampled and Time: 03-06-08, 11:00am
Temperature: 2° Celcius

Received by: Patty Hardin
Date Received: 03-06-08
Time Received: 12:35pm
Test Start Time: 1:00pm
Chlorine Residual: 0
Date Test Ended: 03-08-08
Test End Time: 12:00pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
03-08-08	Total Coliform --	MPN by MTF	<2	MPN- 100mL. Water
03-08-08	Fecal Coliform -	MPN by MTF	<2	MPN- 100mL. Water
03-08-08	E. Coli -	MPN by MTF	<2	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director



Imperial Valley Environmental Laboratory

501 E. Third Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M2230

Sample ID: M2230R

Sample Site: Effluent

Collected by: Hector O

Date Sampled and Time: 03-11-08, 8:45am

Temperature: 1° Celcius

Received by: Patty Hardin

Date Received: 03-11-08

Time Received: 11:10am

Test Start Time: 11:35am

Chlorine Residual: 0

Date Test Ended: 03-14-08

Test End Time: 11:00am

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
03-14-08	Total Coliform --	MPN by MTF	30	MPN- 100mL. Water
03-14-08	Fecal Coliform -	MPN by MTF	30	MPN- 100mL. Water
03-14-08	E. Coli -	MPN by MTF	30	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director



Imperial Valley Environmental Laboratory
501 E. Third Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M2244

Sample ID: M2244R

Sample Site: Effluent

Collected by: Hector O

Date Sampled and Time: 03-18-08, 1:20pm

Temperature: 46° Celcius

Received by: Patty Hardin

Date Received: 03-18-08

Time Received: 2:30pm

Test Start Time: 2:40pm

Chlorine Residual: 0

Date Test Ended: 03-20-08

Test End Time: 2:30pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
03-20-08	Total Coliform --	MPN by MTF	80	MPN- 100mL. Water
03-20-08	Fecal Coliform -	MPN by MTF	80	MPN- 100mL. Water
03-20-08	E. Coli -	MPN by MTF	80	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director



Imperial Valley Environmental Laboratory

501 E. Third Street
Calexico CA, 92231
(Tel) 760-357-8764
(Fax) 760-357-8765
ELAP Certification # 2524

Client: Date Gardens RV.

Contact: Rocky V.

Log Number: M2257
Sample ID: M2257-1R
Sample Site: Effluent
Collected by: Hector O
Date Sampled and Time: 03-25-08, 12:00pm
Temperature: 1° Celcius

Received by: Patty Hardin
Date Received: 03-25-08
Time Received: 2:06pm
Test Start Time: 2:30pm
Chlorine Residual: 0
Date Test Ended: 03-27-08
Test End Time: 2:10pm

Analytical Results

Date	Final Result	Test Name	Count	Volume Tested
03-27-08	Total Coliform --	MPN by MTF	1600	MPN- 100mL. Water
03-27-08	Fecal Coliform -	MPN by MTF	1600	MPN- 100mL. Water
03-27-08	E. Coli --	MPN by MTF	1600	MPN- 100mL. Water

Miguel E. Ortega, Laboratory Director