Date Gardens Mobile Home Park
Wastewater Treatment Plant
1020 West Evan Hewes Highway
El Centro California 9224

1/11//2011

Mr. John Carmona
C.R.W.Q.C.B.
73-720 Fred Waring Drive Suite 100
Palm Desert, Ca. 92260

Rocky Vandergriff
1020 West Evan Hewes
El Centro CA. 92243

Re: December 2010 self-monitoring report for Date Gardens Movile Home Park.

Dear Mr. Carmona,

I am pleased to state that plant maintenance and operations during December were normal and we have no plant upsets or effluent violations to report.

Please feel free to contact me if you have any questions.

Sincerely,

Rocky Vandergriff.
Date Gardens Wastewater Plant Operator.

RECEIVED
JAN 21 2011
REGION 12
Q4

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

WDID NO. 7A 13 1057 011
ORDER NO. R7-2008-0010
NPDES NO. CA0104841
REPORTING FREQUENCY: MONTHLY

MONITORING AND REPORTING PROGRAM
FOR DATE GARDENS MOBILE HOME PARK WWTP
NONTH; December
YEAR: 2010

DESCRIPTION:	INFLUENT		EFF-001 EFFLUENT DISCHARGED TO RICE DRAIN NO. 3							
PARAMETERS:	BOD	TSS	Flow [1]	BOD			TSS			pH
FREQUENCY:	1x/Month	1x/Month	1x/Day	1x/Month			1x/Month			1x/Month
TYPE OF SAMPLE:	Grab ("G")	G	Flow Meter Reading	24-Hr. Composite ("C")	Calculate ("Calc")		C	Calc		G
UNITS:	mg/L	mg/L	MGD	mg/L	lbs/day	MDL	mg/L	lbs/day	MDL	Standard Units
REQUIREMENTS:										
AVERAGE MONTHLY			0.02	30	5.0		30	5.0		
AVERAGE WEEKLY				45	7.5		45	7.5		
MAXIMUM DAILY										
INST. MINIMUM										6.0
INST. MAXIMUM										9.0
DATE OF SAMPLE:										
1			0.0058							
2			0.0056							
3			0.0050							
4			0.0048							
5			0.0046							
6			0.0040							
7			0.0040							
8			0.0056							
9			0.0052							
10			0.0048							
11			0.0042							
12			0.0048							
13			0.0040							
14			0.0038							
15	358.0	520.0	0.0046	5.4	0.2	2.0	75.0	2.8	20.0	7.46
16			0.0048							
17			0.0056							
18			0.0056							
19			0.0058							
20			0.0046							
21			0.0044							
22			0.0047							
23			0.0056							
24			0.0058							
25			0.0048							
26			0.0048							
27			0.0048							
28			0.0058							
29			0.0050							
30			0.0053							
31			0.0049							
AVERAGE MONTHLY	358.0	520.0	0.0049	5.4	0.2	2.0	75.0	2.8	20.0	7.5
WEEKLY (MAXIMUM)			0.0067	5.4	0.2	2.0	75.0	2.8	20.0	7.5
MAXIMUM			0.0067	5.4	0.2	2.0	75.0	2.8	20.0	7.5

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: K.V.

1 Secondary treated wastewater effluent discharged from the facility to Rice Drain No. 3

RECEIVED
JAN 21 2011
REGION 7

Monthly Report

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

WDID NO. **7A 13 1057 011**
ORDER NO. **R7-2008-0010**
NPDES NO. **CA0104841**
REPORTING FREQUENCY: **MONTHLY**

MONITORING AND REPORTING PROGRAM
FOR DATE GARDENS MOBILE HOME PARK WWTP
December
YEAR :2010

DESCRIPTION:	EFF-001 EFFLUENT DISCHARGED TO RICE DRAIN NO. 3						
PARAMETERS:	BOD Removal Eff.	TSS Removal Eff.	E. Coli	Enterococci	Fecal Coliform	Total Dissolved Solids	
FREQUENCY:	1x/Month	1x/Month	5x/Month	5x/Month	5x/Month	1x/Month	
TYPE OF SAMPLE:	Calc	Calc	G	G	G	G	
UNITS:	%	%	MPN/100 ml	MPN/100 ml	MPN/100 ml	mg/L	MDL
REQUIREMENTS:							
AVERAGE MONTHLY	99	98.5	126	33	200		
AVERAGE WEEKLY							
MAXIMUM DAILY							
INST. MINIMUM							
INST. MAXIMUM			400	100	400		
DATE OF SAMPLE:							
1			1	2	2		
2							
3							
4							
5							
6							
7							
8			1	2	2		
9							
10							
11							
12							
13							
14							
15	98.49	85.57	1	2	2	1240	20
16							
17							
18							
19							
20							
21							
22			1	2	2		
23							
24							
25							
26							
27							
28							
29			1	2	2		
30							
31							
AVERAGE MONTHLY	98.49	85.57	1	2	2	1020	20.0
WEEKLY (MAXIMUM)	98.49	85.57	1	2	2	1020	20.0
MAXIMUM	98.49	85.57	1	2	2	1020	20.0

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: _____

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

WDID NO. **7A 13 1057 011**
ORDER NO. **R7-2008-0010**
NPDES NO. **CA0104841**
REPORTING FREQUENCY: **MONTHLY**

MONITORING AND REPORTING PROGRAM
FOR DATE GARDENS MOBILE HOME PARK WWTP
December
YEAR: 2010

OTHER REPORTING - OPERATION AND MAINTENANCE

The Discharger shall report on the inspection, operation and maintenance of the UV disinfection system, including but not limited to, inspection, cleaning, and bulb replacement.
The Discharger shall include documentation of all logbooks (operation and maintenance), chain of custody sheets and sampling activities as stated in Special Provisions VI.C.4.b. (Limitations and Discharge Requirements) and Standard Provisions sections IV and V (Attachment D).

August	Replace difuser in aeration tank
September	Clean and inspect UV system
October	Instalation of new blower
November	Replace Bulb on UV Ligth
December	Change belts to blower

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: _____

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

WDID NO. 7A 13 1057 011
ORDER NO. R7-2008-0010
NPDES NO. CA0104841
REPORTING FREQUENCY: QUARTERLY

MONITORING AND REPORTING PROGRAM
FOR DATE GARDENS MOBILE HOME PARK WWTP
DECEMBER
YEAR: 2010

DESCRIPTION:	RSW-001 UPSTREAM RECEIVING WATER MONITORING OF RICE DRAIN NO. 3 [1]							
PARAMETERS:	Dissolved Oxygen		Hardness		pH	E. Coli	Total Dissolved Solids	
FREQUENCY:	1x/Quarter		1x/Quarter		1x/Quarter	1x/Quarter	1x/Quarter	
TYPE OF SAMPLE:	G		G		G	G	G	
UNITS:	mg/L	MDL	mg/L	MDL	Standard Units	MPN/100 ml	mg/L	MDL
REQUIREMENTS:								
AVERAGE MONTHLY								
MAXIMUM DAILY								
INST. MINIMUM								
ANNUAL AVERAGE								
DATE OF SAMPLE:								
1								
2								
3								
4								
5								
6								
7								
8								
9								
10								
11								
12								
13								
14								
15	9.4	0.1	1830	100	8.03	2420	4900	20
16								
17								
18								
19								
20								
21								
22								
23								
24								
25								
26								
27								
28								
29								
30								
31								
AVERAGE MONTHLY	9.4	0.1	1830	100.0	8.03	2420	4900	20.0
WEEKLY (MAX.)	9.4	0.1	1830	100.0	8.03	2420	4900	20.0
MAXIMUM DAILY	9.4	0.1	1830	100.0	8.03	2420	4900	20.0

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature:

[1] In the event there is no receiving water present at RSW-001, no receiving water monitoring data are required for RSW-001.

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

WDID NO. 7A 13 1057 011
ORDER NO. R7-2008-0010
NPDES NO. CA0104841
REPORTING FREQUENCY: QUARTERLY

MONITORING AND REPORTING PROGRAM
FOR DATE GARDENS MOBILE HOME PARK WWTP
SEPTEMBE_____
YEAR 2010

DESCRIPTION:	RSW-002 DOWNSTREAM RECEIVING WATER MONITORING OF RICE DRAIN NO. 3 [2]								
PARAMETERS:	Dissolved Oxygen		pH	E. Coli	Total Dissolved Solids		Hardness		
FREQUENCY:	1x/Quarter		1x/Quarter	1x/Quarter	1x/Quarter		1x/Quarter		
TYPE OF SAMPLE:	G		G	G	G		G		
UNITS:	mg/L	MDL	Standard Units	MPN/100 ml	mg/L	MDL	mg/L	MDL	
REQUIREMENTS:									
AVERAGE MONTHLY									
MAXIMUM DAILY									
INST. MINIMUM									
ANNUAL AVERAGE									
DATE OF SAMPLE:									
1									
2									
3									
4									
5									
6									
7									
8									
9									
10									
11									
12									
13									
14									
15	9.03	0.1	8.08	1050	5100	20	1630	100	
16									
17									
18									
19									
20									
21									
22									
23									
24									
25									
26									
27									
28									
29									
30									
31									
AVERAGE MONTHLY	9.0	0.1	8.1	1050	5100.0	20.0	1630.0	100.0	
WEEKLY (MAX.)	9.0	0.1	8.1	1050	5100.0	20.0	1630.0	100.0	
MAXIMUM DAILY	9.0	0.1	8.1	1050	5100.0	20.0	1630.0	100.0	

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: _____

[2] In the event there is no receiving water present at RSW-002, no receiving water monitoring data are required for RSW-002.

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
COLORADO RIVER BASIN REGION

WDID NO. 7A 13 1057 011
ORDER NO. R7-2008-0010
NPDES NO. CA0104841
REPORTING FREQUENCY: QUARTERLY

MONITORING AND REPORTING PROGRAM
FOR DATE GARDENS MOBILE HOME PARK WWTP
DECEMBER
YEAR: ____2010

RECEIVING WATER MONITORING (CONT'D.)

1 Is there receiving water present at RSW-001? Yes No
PLEASE CIRCLE THE APPROPRIATE ANSWER
If the answer is No, proceed to section for RSW-002; otherwise, continue with the following questions

Monitoring Location RSW-001 (The following questions refer to RSW-001)
1 Is there floating or suspended matter present?
2 Is there discoloration present?
3 Is there aquatic life present?
4 Is there visible film, sheen, or coating present?
5 Is there fungi, slime, or objectionable growths present?
6 Are there potential nuisance conditions present?

Monitoring Location RSW-002 (The following questions refer to RSW-002)
1 Is there floating or suspended matter present?
2 Is there discoloration present?
3 Is there aquatic life present?
4 Is there visible film, sheen, or coating present?
5 Is there fungi, slime, or objectionable growths present?
6 Are there potential nuisance conditions present?

Any additional comments.

_____
_____
_____
_____

Water Supply Monitoring

The discharger is required to obtain or acquire quarterly Total Dissolved Solids concentrations of the source water, either through monitoring or obtaining the data from the drinking water purveyor. The information will be compiled and summarized in a report, in accordance with Special Provisions VI.V.2.d. of the Limitations and Discharge Requirements.

LIST ANY ATTACHMENTS FOR ADDITIONAL INFORMATION ON SLUDGE OR SIMILAR SOLIDS

I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure qualified personnel properly gather and evaluate the information submitted based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information. The information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware there are significant penalties for submitting false information including the possibility of fine and imprisonment for knowing violations.

Signature: _____

EnviroMatrix Analytical, Inc.

07 December 2010

Date Gardens R.V.
Attn: Rocky Vandergriff
1020 W. Evan Hewes Hwy, Spc 41
El Centro, CA 92243-9551

EMA Log #: 10L0024

Project Name: Effluent Bactis

Enclosed are the results of analyses for samples received by the laboratory on 12/01/10 14:00. Samples were analyzed pursuant to client request utilizing EPA or other ELAP approved methodologies. I certify that this data is in compliance both technically and for completeness.

Dan Verdon
Laboratory Director

CA ELAP Certification #: 2564

4340 Viewridge Avenue, Suite A - San Diego, California 92123 - (858) 560-7717 - Fax (858) 560-7763
Analytical Chemistry Laboratory

Client Name: Date Gardens R.V.
Project Name: Effluent Bactis

EMA Log #: 10L0024

ANALYTICAL REPORT FOR SAMPLES

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Effluent	10L0024-01	Wastewater	12/01/10 09:00	12/01/10 14:00

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Client Name: Date Gardens R.V.
Project Name: Effluent Bactis

EMA Log #: 10L0024

Microbiological Parameters by Standard Methods

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Date Prepared Date Analyzed	Method	Notes
Effluent (10L0024-01) Wastewater	**Sampled: 12/01/10 09:00**	**Received: 12/01/10 14:00**						
Fecal Coliforms	ND	2	MPN/100 ml	1	0120217	12/01/10 15:23 12/03/10 13:26	SM 9221 E	
Total Coliforms	ND	1	"	"	0120216	12/01/10 15:06 12/02/10 15:08	SM9223	
E. Coli	ND	1	"	"	"	12/01/10 15:06 12/02/10 15:08	"	
Enterococcus	ND	2	"	"	0120218	12/01/10 15:23 12/04/10 12:57	SM 9230 A, B	

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Client Name: Date Gardens R.V.
Project Name: Effluent Bactis

EMA Log #: 10L0024

Notes and Definitions

ND	Analyte NOT DETECTED at or above the reporting limit
NR	Not Reported
RPD	Relative Percent Difference

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

CHAIN-OF-CUSTODY RECORD

EnviroMatrix Analytical, Inc.

4340 Viewridge Ave., Ste A - San Diego, CA 92123 - Phone (858) 560-7717 - Fax (858) 560-7763

Page __ of __

DEC 1 '10 14.01

EMA LOG #: 10L0024

Client: Dale Gardens Movil Home Park

Attn: Rocky Vandergriff

Samplers(s): Julio Palacios

Address: 1020 Evan Hewes Hwy

Phone: 760 356 2480 Phone: 760 356 5832

Email: jpalacios@holtville.ca.gov

Billing Address: same

Project ID: Effluent Bactis

Project #: PO #:

Requested Analysis

ID #	Client Sample ID	Sample Date	Sample Time	Sample Matrix	Container # / Type	Oil & Grease □ 413.1 □ 413.2 □ 1664	8015B (TPH) □ Gas □ Diesel □ Ext	624/8260 (VOC) Full BTXE MTBE Oxy Nap	625 / 8270 (SVOC) □ PAH only	608 / 8081 (Organochlorine Pesticides)	608 / 8082 (Polychlorinated Biphenyls)	8141 (Organophosphorus Pesticides)	TBT (Organotin Compounds)	□ pH □ EC □ TSS □ TDS	□ Nitrate □ Nitrite □ TKN □ NH3	CAC Title 22/CAM17 Metals □ TTLC □ STLC	TCLP (RCRA) □ Metals □ Organics	Cd Cr Cu Pb Ni Ag Zn □ Dissolved	Coliform, □ Total (MTF) □ Fecal (MTF)	Colilert, (T+E.Coli) □ P/A □ Enumeration	Enterococcus, □ MTF □ Enterolert	Heterotrophic Plate Count (HPC)	□ BOD □ COD □ Cyanide
1	Effluent	12-01-10	9:00	WW	3														X	X	X		
2																							
3																							
4																							
5																							
6																							
7																							
8																							
9																							
10																							

Matrix Codes: A = Air, DW = Drinking Water, GW = Groundwater, SW = Storm Water
WW = Wastewater, S = Soil, SED = Sediment, SD = Solid, T = Tissue, O = Oil, L = Liquid

Shipped By: □ Courier □ UPS □ FedEx □ USPS □ Client Drop Off □ Other

[1]Turn-Around-Time: □ Same Day □ 24 hr □ 48 hr □ 3 day □ 4 day □ 5 day STD (7 day)

[2]Reporting Requirements: □ Fax □ PDF □ Excel □ Geotracker/EDF □ Hard Copy □ EDT

[2]Sample Disposal: □ By Laboratory □ [2]Return to Client P/U or Delivery □ Archive

Sample Integrity

Correct Containers: Yes No N/A	Containers Properly Preserved: Yes No N/A
Custody Seals Intact: Yes No N/A	Temp @ Receipt: 1°C
COC/Labels Agree: Yes No N/A	Sampled By: Client EMA Autosampler

RELINQUISHED BY	DATE/TIME	RECEIVED BY
Signature: [signature]	12/01/2010	Signature: [signature]
Print: Julio Palacios	10:40	Print: Kristin Huff
Company: Dale Gardens		Company: KHS
Signature: [signature]	12/1/10	Signature: [signature]
Print: Kristin Huff	14:00	Print: Joe Leonard
Company: KHS		Company: EMA
Signature		Signature
Print		Print
Company		Company

Project/Sample Comments:

[1]Additional costs may apply, consult a project manager for details

[2]EMA reserves the right to return any samples that do not match our waste profile.

NOTE: By relinquishing samples to EMA, Inc., client agrees to pay for the services requested on this COC form and any additional analyses performed on this project. Payment for services is due within 30 days from date of invoice. Samples will be disposed of 7 days after report has been finalized unless otherwise noted. All work is subject to EMA's terms and conditions

EnviroMatrix Analytical, Inc.

16 December 2010

Date Gardens R.V.
Attn: Rocky Vandergriff
1020 W. Evan Hewes Hwy, Spc 41
El Centro, CA 92243-9551

EMA Log #: 10L0213

Project Name: Effluent

Enclosed are the results of analyses for samples received by the laboratory on 12/08/10 14:07. Samples were analyzed pursuant to client request utilizing EPA or other ELAP approved methodologies. I certify that this data is in compliance both technically and for completeness.

Dan Verdon
Laboratory Director

CA ELAP Certification #: 2564

4340 Viewridge Avenue, Suite A • San Diego, California 92123 • (858) 560-7717 • Fax (858) 560-7763
Analytical Chemistry Laboratory

Client Name: Date Gardens R.V.
Project Name: Effluent

EMA Log #: 10L0213

ANALYTICAL REPORT FOR SAMPLES

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Effluent	10L0213-01	Wastewater	12/08/10 09:00	12/08/10 14:07
Mixed Liquor	10L0213-02	Wastewater	12/08/10 09:00	12/08/10 14:07

he results in this report apply to the samples analyzed in accordance with the chain of istody document. This analytical report must be reproduced in its entirety.

7603530328

RECEIVED JAN 21 2011 REGION 7

City of Date Gardens WWTP- Effluent

VOC Semi-VOC's

Discharger: Date Gardens Wastewater Treatment Facility
NPDES Number:
WDID Number:
Monitoring Period: Sampled 07-19-2010 08:00am
Measured/Metered Flow (MGD):

Name of Laboratory: IVE LABs/ Positive Labs
ELAP Number: IVE LAB-2524/ Positive Lab 1131
Laboratory Contact Name: Jorge Orlega
Laboratory Phone Number: 760-357-8764
Report Number: 3653 -1 Effluent

No.	Name of Constituent	Monitoring Location	Date Sample Collected	Date Sample Analyzed	USEPA Method	ML (µg/L)	RML (µg/L)	MDL (µg/L)	Analytical Results (µg/L)	Comments
	Volatile Substances:									
1	Acrolein	WWTP	7/19/2010	7/21/2010	EPA 624	5	5	25	ND	Effluent
2	Acrylonitrile	WWTP	7/19/2010	7/21/2010	EPA 624	2	2	5	ND	Effluent
3	Benzene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
4	Bromobenzene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
5	**Bromodichloromethane**	**WWTP**	**7/19/2010**	**7/21/2010**	**EPA 624**	**1**	**1**	**0.5**	**19.4**	**Effluent**
6	Bromoform	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
7	Bromomethane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
8	Carbon tetrachloride	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
9	Chlorobenzene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
10	Chloroethane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.9	ND	Effluent
11	2-Chloroethylvinyl ether	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	1	ND	Effluent
12	**Chloroform**	**WWTP**	**7/19/2010**	**7/21/2010**	**EPA 624**	**1**	**1**	**0.5**	**120**	**Effluent**
13	Chloromethane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
14	**Chlorodibromomethane**	**WWTP**	**7/19/2010**	**7/21/2010**	**EPA 624**	**1**	**1**	**0.6**	**1.62**	**Effluent**
15	1,2-Dichlorobenzene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
16	1,3-Dichlorobenzene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.6	ND	Effluent
17	1,4-Dichlorobenzene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
18	1,1-Dichloroethane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
19	1,2-Dichloroethane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
20	1,1-Dichloroethene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
21	trans-1,2- Dichloroethene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.6	ND	Effluent
22	1,2-Dichloropropane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
23	Dichlorodifluoromethane (FC-12)	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
24	cis-1,3-Dichloroethene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
25	trans-1,3-Dichloropropene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
26	Ethylbenzene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
27	Dichloromethane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	2.5	ND	Effluent
28	1,1,2,2-Tetrachloroethane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
29	Tetrachloroethene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
30	Toluene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
31	1,1,1-Trichloroethane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
32	1,1,2-Trichloroethane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.6	ND	Effluent
33	Trichloroethene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent

Water Treatment Services

Jan 20 11 08:39p

City of Date Gardens WWTP- Effluent

VOC Semi-VOC's

RECEIVED JAN 21 2011 REGION 7

No.	Name of Constituent	Monitoring Location	Date Sample Collected	Date Sample Analyzed	USEPA Method	ML (µg/L)	RML (µg/L)	MDL (µg/L)	Analytical Results (µg/L)	Comments
	Volatile Substances:									
34	Trichlorofluoromethane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
35	Vinyl Chloride	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
36	m,p-Xylene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
37	o-Xylene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	Effluent
	Pesticides - PCBs:									
1	Aldrin	WWTP	7/19/2010	7/26/2010	608	0.01	0.01	0.01	ND	Effluent
2	HCH-alpha	WWTP	7/19/2010	7/26/2010	608	0.01	0.01	0.01	ND	Effluent
3	HCH-beta	WWTP	7/19/2010	7/26/2010	608	0.01	0.01	0.01	ND	Effluent
4	HCH-delta	WWTP	7/19/2010	7/26/2010	608	0.02	0.02	0.02	ND	Effluent
5	HCH-gamma (Lindane)	WWTP	7/19/2010	7/26/2010	608	0.01	0.01	0.01	ND	Effluent
6	Chlordane	WWTP	7/19/2010	7/26/2010	608	0.075	0.075	0.075	ND	Effluent
7	4,4-DDD	WWTP	7/19/2010	7/26/2010	608	0.05	0.05	0.05	ND	Effluent
8	4,4,-DDE	WWTP	7/19/2010	7/26/2010	608	0.05	0.05	0.05	ND	Effluent
9	4,4-DDT	WWTP	7/19/2010	7/26/2010	608	0.05	0.05	0.05	ND	Effluent
10	Dieldrin	WWTP	7/19/2010	7/26/2010	608	0.1	0.1	0.1	ND	Effluent
11	Endosulfan I	WWTP	7/19/2010	7/26/2010	608	0.02	0.02	0.02	ND	Effluent
12	Endosulfan II	WWTP	7/19/2010	7/26/2010	608	0.05	0.05	0.05	ND	Effluent
13	Endosulfan sulfate	WWTP	7/19/2010	7/26/2010	608	0.1	0.1	0.1	ND	Effluent
14	Endrin	WWTP	7/19/2010	7/26/2010	608	0.05	0.05	0.05	ND	Effluent
15	Endrin aldehyde	WWTP	7/19/2010	7/26/2010	608	0.01	0.01	0.01	ND	Effluent
16	Heptachlor	WWTP	7/19/2010	7/26/2010	608	0.01	0.01	0.01	ND	Effluent
17	Heptachlor epoxide	WWTP	7/19/2010	7/26/2010	608	0.2	0.2	0.2	ND	Effluent
18	Toxaphene	WWTP	7/19/2010	7/26/2010	608	0.5	0.5	0.5	ND	Effluent
19	PCB-1061	WWTP	7/19/2010	7/26/2010	608	0.5	0.5	0.4	ND	Effluent
20	PCB 1221	WWTP	7/19/2010	7/26/2010	608	0.5	0.5	0.4	ND	Effluent
21	PCB 1232	WWTP	7/19/2010	7/26/2010	608	0.5	0.5	0.4	ND	Effluent
22	PCB 1242	WWTP	7/19/2010	7/26/2010	608	0.5	0.5	0.4	ND	Effluent
23	PCB 1248	WWTP	7/19/2010	7/26/2010	608	0.5	0.5	0.4	ND	Effluent
24	PCB 1254	WWTP	7/19/2010	7/26/2010	608	0.5	0.5	0.4	ND	Effluent
25	PCB 1260	WWTP	7/19/2010	7/26/2010	608	0.5	0.5	0.4	ND	Effluent

City of Date Gardens WWTP- Effluent

VOC Semi-VOC's

No.	Name of Constituent	Monitoring Location	Date Sample Collected	Date Sample Analyzed	USEPA Method	ML (µg/L)	RML (µg/L)	MDL (µg/L)	Analytical Results (µg/L)	Comments
	Semi-Volatile Substances:									
1	1,4- Dichlorobenzene	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
2	1,3- Dichlorobenzene	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
3	2-Chlorophenol	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
4	Bis (2-chloroethyl) ether	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
5	Phenol	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
6	N-Nitrosodimethylamine	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
7	2,4- Dichlorophenol	WWTP	7/19/2010	7/27/2010	EPA 625	1	1	5	ND	Effluent
8	Bis(2-chloroethoxy) methane	WWTP	7/19/2010	7/27/2010	EPA 625	1	1	5	ND	Effluent
9	2,4- Dimethylphenol	WWTP	7/19/2010	7/27/2010	EPA 625	1	1	5	ND	Effluent
10	2-Nitrophenol	WWTP	7/19/2010	7/27/2010	EPA 625	1	1	5	ND	Effluent
11	Isophorone	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
12	Nitrobenzene	WWTP	7/19/2010	7/27/2010	EPA 625	1	1	5	ND	Effluent
13	N-Nitrosodi-n-propylamine	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
14	Hexachloroethane	WWTP	7/19/2010	7/27/2010	EPA 625	1	1	5	ND	Effluent
15	Bis(2-chloroisopropyl) ether	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
16	2-Chloronaphthalene	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
17	2,4,6- Trichlorophenol	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
18	Hexachlorocyclopentadiene	WWTP	7/19/2010	7/27/2010	EPA 625	1	1	5	ND	Effluent
19	4-Chloro-3-methylphenol	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
20	Hexachlorobutadiene	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
21	Naphthalene	WWTP	7/19/2010	7/27/2010	EPA 625	1	1	5	ND	Effluent
22	4-Chlorophenyl phenyl ether	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
23	Diethyl phthalate	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
24	Fluorene	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
25	2,4- Dinitrotoluene	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
26	4- Nitrophenol	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
27	2,4- Dinitrophenol	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
28	Acenapthene	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
29	2,6- Dinitrotoluene	WWTP	7/19/2010	7/27/2010	EPA 625	1	1	5	ND	Effluent
30	Acenapthylene	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
31	Dimethyl phthalate	WWTP	7/19/2010	7/27/2010	EPA 625	1	1	5	ND	Effluent
32	Pyrene	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
33	Benzidine	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
34	Fluoranthene	WWTP	7/19/2010	7/27/2010	EPA 625	1	1	5	ND	Effluent
35	Di-n-butyl phthalate	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
36	Anthracene	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
37	Phenanthrene	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
38	Pentachlorophenol	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
39	Hexachlorobenzene	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
40	4-Bromophenylphenylether	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent

City of Date Gardens WWTP- Effluent

VOC Semi-VOC's

No.	Name of Constituent	Monitoring Location	Date Sample Collected	Date Sample Analyzed	USEPA Meihod	ML (ug/L)	RML (ug/L)	MDL (ug/L)	Analytical Results (ug/L)	Comments
	Semi-Volatile Substances, Cont':									
41	N-Nitrosodiphenylamine	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
42	4,6-Dinitro-2-methylphenol	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
43	Benzo(k) fluoranthene-Benzofluroanthen	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
44	Benzo(a)pyrene	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
45	Indeno (1,2,3,cd)-pyrene	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
46	Benzo(g,h,i)perylene	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
47	Dibenzofuran	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
48	Benzo(b)fluoranthene	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
49	Di-n-octyl phthalate	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
50	Bis(2-ethylhexyl)phalate	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
51	Chrysene	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
52	3,3-Dichlorobenzidine	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
53	Benzo(a)anthracene	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
54	Butylbenzylphthalate	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
55	1,2-Dichlorobenzene	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
56	1,2,4-Trichlorobenzene	WWTP	7/19/2010	7/27/2010	EPA 625	5	5	5	ND	Effluent
	Other Constituents:									
1	**pH**	**WWTP**	**7/19/2010**	**7/19/2010**	**SM4500HG**				**6.97**	**Effluent**
2	**Hardness measured as $CaCO_3$, mg/L**	**WWTP**	**7/19/2010**	**7/19/2010**	**SM2340B**				**328.0 mg/L**	**Effluent**
3	**Salinity measured as Total Dissolved Solids (TDS), mg/L**	**WWTP**	**7/19/2010**	**7/22/2010**	**SM2540C**				**1058.0 mg/L**	**Effluent**
4	**Total Suspended Solids (TSS), mg/L**	**WWTP**	**7/19/2010**	**7/22/2010**	**SM2540D**				**2.50 mg/L**	**Effluent**

[2] Phenol by colorimetric technique has a factor of 1

City of Date Gardens WWTP- Effluent

VOC Semi-VOC's

No.	Name of Constituent	Monitoring Location	Date Sample Collected	Date Sample Analyzed	USEPA Method	ML (µg/L)	RML (µg/L)	MDL (µg/L)	Analytical Results (µg/L)	Comments
	Inorganics:									
1	Antimony	WWTP	7/19/2010	7/26/2010	EPA 200.8	6	6	6	ND	Effluent
2	**Arsenic**	**WWTP**	**7/19/2010**	**7/26/2010**	**EPA 200.8**	**2**	**2**	**2**	**2.7**	**Effluent**
3	Beryllium	WWTP	7/19/2010	7/26/2010	EPA 200.8	1	1	0.2	ND	Effluent
4	Cadmium	WWTP	7/19/2010	7/26/2010	EPA 200.8	1	1	0.4	ND	Effluent
5	Chromium III	WWTP	7/19/2010	7/26/2010	EPA 200.8	6	6	1.1	ND	Effluent
6	Chromium VI	WWTP	7/19/2010	7/26/2010	EPA 218.6	1	1	1	ND	Effluent
7	Copper	WWTP	7/19/2010	7/26/2010	EPA 200.8	10	10	2.3	ND	Effluent
8	Cyanide	WWTP	7/19/2010	7/26/2010	EPA 335.2	5	5	5	ND	Effluent
9	Lead	WWTP	7/19/2010	7/26/2010	EPA 200.8	4	4	4	ND	Effluent
10	Mercury	WWTP	7/19/2010	7/26/2010	EPA 245.1	0.73	0.73	0.73	ND	Effluent
11	Nickel	WWTP	7/19/2010	7/26/2010	EPA 200.8	9	9	1.8	ND	Effluent
12	Selenium	WWTP	7/19/2010	7/26/2010	EPA 200.8	5	5	3.7	ND	Effluent
13	Silver	WWTP	7/19/2010	7/26/2010	EPA 200.8	4	4	0.8	ND	Effluent
14	Thallium	WWTP	7/19/2010	7/26/2010	EPA 200.8	4	4	1.5	ND	Effluent
15	**Zinc**	**WWTP**	**7/19/2010**	**7/26/2010**	**EPA 200.8**	**13**	**13**	**2.6**	**55.5**	**Effluent**

7603530328

City of Date Gardens WWTP- RSW-001

VOC Semi-VOC's

Discharger: Date Gardens Wastewater Treatment Facility
NPDES Number:
WDID Number:
Monitoring Period: Sampled 07-19-2010 08:30am
Measured/Metered Flow (MGD):

Name of Laboratory: IVE LABs/ Positive Labs
ELAP Number: IVE LAB-2524/ Positive Lab 1131
Laboratory Contact Name: Jorge Ortega
Laboratory Phone Number: 760-357-8764
Report Number: 3653 -2 RSW-001

No.	Name of Constituent	Monitoring Location	Date Sample Collected	Date Sample Analyzed	USEPA Method	ML (µg/L)	RML (µg/L)	MDL (µg/L)	Analytical Results (µg/L)	Comments
	Volatile Substances:									
1	Acrolein	WWTP	7/19/2010	7/21/2010	EPA 624	5	5	25	ND	RSW-001
2	Acrylonitrile	WWTP	7/19/2010	7/21/2010	EPA 624	2	2	5	ND	RSW-001
3	Benzene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
4	Bromobenzene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
5	Bromodichloromethane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
6	Bromoform	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
7	Bromomethane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
8	Carbon tetrachloride	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
9	Chlorobenzene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
10	Chloroethane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.9	ND	RSW-001
11	2-Chloroethylvinyl ether	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	1	ND	RSW-001
12	Chloroform	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
13	Chloromethane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
14	Chlorodibromomethane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.6	ND	RSW-001
15	1,2-Dichlorobenzene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
16	1,3-Dichlorobenzene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.6	ND	RSW-001
17	1,4-Dichlorobenzene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
18	1,1-Dichloroethane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
19	1,2-Dichloroethane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
20	1,1-Dichloroethene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
21	trans-1,2- Dichloroethene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.6	ND	RSW-001
22	1,2-Dichloropropane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
23	Dichlorodifluoromethane (FC-12)	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
24	cis-1,3-Dichloroethene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
25	trans-1,3-Dichloropropene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
26	Ethylbenzene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
27	Dichloromethane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	2.5	ND	RSW-001
28	1,1,2,2-Tetrachloroethane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
29	Tetrachloroethene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
30	Toluene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
31	1,1,1-Trichloroethane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
32	1,1,2-Trichloroethane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.6	ND	RSW-001
33	Trichloroethene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001

Water Treatment Services

Jan 20 11 08:41p

City of Date Gardens WWTP- RSW-001

VOC Semi-VOC's

No.	Name of Constituent	Monitoring Location	Date Sample Collected	Date Sample Analyzed	USEPA Method	ML (µg/L)	RML (µg/L)	MDL (µg/L)	Analytical Results (µg/L)	Comments
	Volatile Substances:									
34	Trichlorofluoromethane	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
35	Vinyl Chloride	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
36	m,p-Xylene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
37	o-Xylene	WWTP	7/19/2010	7/21/2010	EPA 624	1	1	0.5	ND	RSW-001
	Pesticides - PCBs:									RSW-001
1	Aldrin	WWTP	7/19/2010	7/26/2010	608	0.01	0.01	0.01	ND	RSW-001
2	HCH-alpha	WWTP	7/19/2010	7/26/2010	608	0.01	0.01	0.01	ND	RSW-001
3	HCH-beta	WWTP	7/19/2010	7/26/2010	608	0.01	0.01	0.01	ND	RSW-001
4	HCH-delta	WWTP	7/19/2010	7/26/2010	608	0.02	0.02	0.02	ND	RSW-001
5	HCH-gamma (Lindane)	WWTP	7/19/2010	7/26/2010	608	0.01	0.01	0.01	ND	RSW-001
6	Chlordane	WWTP	7/19/2010	7/26/2010	608	0.075	0.075	0.075	ND	RSW-001
7	4,4-DDD	WWTP	7/19/2010	7/26/2010	608	0.05	0.05	0.05	ND	RSW-001
8	4,4,-DDE	WWTP	7/19/2010	7/26/2010	608	0.05	0.05	0.05	ND	RSW-001
9	4,4-DDT	WWTP	7/19/2010	7/26/2010	608	0.05	0.05	0.05	ND	RSW-001
10	Dieldrin	WWTP	7/19/2010	7/26/2010	608	0.1	0.1	0.1	ND	RSW-001
11	Endosulfan I	WWTP	7/19/2010	7/26/2010	608	0.02	0.02	0.02	ND	RSW-001
12	Endosulfan II	WWTP	7/19/2010	7/26/2010	608	0.05	0.05	0.05	ND	RSW-001
13	Endosulfan sulfate	WWTP	7/19/2010	7/26/2010	608	0.1	0.1	0.1	ND	RSW-001
14	Endrin	WWTP	7/19/2010	7/26/2010	608	0.05	0.05	0.05	ND	RSW-001
15	Endrin aldehyde	WWTP	7/19/2010	7/26/2010	608	0.01	0.01	0.01	ND	RSW-001
16	Heptachlor	WWTP	7/19/2010	7/26/2010	608	0.01	0.01	0.01	ND	RSW-001
17	Heptachlor epoxide	WWTP	7/19/2010	7/26/2010	608	0.2	0.2	0.2	ND	RSW-001
18	Toxaphene	WWTP	7/19/2010	7/26/2010	608	0.5	0.5	0.5	ND	RSW-001
19	PCB-1061	WWTP	7/19/2010	7/26/2010	608	0.5	0.5	0.4	ND	RSW-001
20	PCB 1221	WWTP	7/19/2010	7/26/2010	608	0.5	0.5	0.4	ND	RSW-001
21	PCB 1232	WWTP	7/19/2010	7/26/2010	608	0.5	0.5	0.4	ND	RSW-001
22	PCB 1242	WWTP	7/19/2010	7/26/2010	608	0.5	0.5	0.4	ND	RSW-001
23	PCB 1248	WWTP	7/19/2010	7/26/2010	608	0.5	0.5	0.4	ND	RSW-001
24	PCB 1254	WWTP	7/19/2010	7/26/2010	608	0.5	0.5	0.4	ND	RSW-001
25	PCB 1260	WWTP	7/19/2010	7/26/2010	608	0.5	0.5	0.4	ND	RSW-001

Client Name: Date Gardens R.V.
Project Name: Effluent

EMA Log #: 10L0213

Conventional Chemistry Parameters by Standard/EPA Methods

Analyte	Result	MDL	Reporting Limit	Units	Analyst	Dilution	Batch	Date Prepared / Date Analyzed	Method	Notes
Mixed Liquor (10L0213-02) Wastewater Sampled: 12/08/10 09:00 Received: 12/08/10 14:07										
Total Suspended Solids	**2,410**	1.00	20.0	mg/l	JEL	1	0121318	12/13/10 08:00 12/14/10 12:51	SM2540 D	

results in this report apply to the samples analyzed in accordance with the chain of tody document. This analytical report must be reproduced in its entirety.

RECEIVED
JAN 21 2011
REGION 7

Client Name: Date Gardens R.V.
Project Name: **Effluent**

EMA Log #: 10L0213

Microbiological Parameters by Standard Methods

Analyte	Result	MDL	Reporting Limit	Units	Analyst	Dilution	Batch	Date Prepared / Date Analyzed	Method	Notes
Effluent (10L0213-01) Wastewater Sampled: 12/08/10 09:00 Received: 12/08/10 14:07										
Fecal Coliforms	ND	2.00	2.00	MPN/100 ml	EKF	1	0120920	12/08/10 15:34 12/10/10 13:54	SM 9221 E	
Total Coliforms	ND	1.00	1.00	"	DRG	"	0120919	12/08/10 15:17 12/09/10 15:25	SM9223	
E. Coli	ND	1.00	1.00	"	"	"	"	12/08/10 15:17 12/09/10 15:25	"	
Enterococcus	ND	2.00	2.00	"	EKF	"	0120921	12/08/10 15:34 12/11/10 13:10	SM 9230 A, B	

he results in this report apply to the samples analyzed in accordance with the chain of ustody document. This analytical report must be reproduced in its entirety.

RECEIVED
JAN 2 1 2011

Client Name: Date Gardens R.V.
Project Name: Effluent

EMA Log #: 10L0213

Conventional Chemistry Parameters by Standard/EPA Methods - Quality Control

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch 0121318										
Blank (0121318-BLK1)				Prepared: 12/13/10		Analyzed: 12/14/10				
Total Suspended Solids	ND	20.0	mg/l							
Duplicate (0121318-DUP1)		Source: 10L0195-02		Prepared: 12/13/10		Analyzed: 12/14/10				
Total Suspended Solids	240	20.0	mg/l		254			6	20	
Reference (0121318-SRM1)				Prepared: 12/13/10		Analyzed: 12/14/10				
Total Suspended Solids	58.0	20.0	mg/l	55.6		104	82.2-117.8			

he results in this report apply to the samples analyzed in accordance with the chain of ustody document. This analytical report must be reproduced in its entirety.

RECEIVED
1 7 2011
REGION 7

Client Name: Date Gardens R.V.
Project Name: Effluent

EMA Log #: 10L0213

Notes and Definitions

ND	Analyte NOT DETECTED at or above the reporting limit
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference

he results in this report apply to the samples analyzed in accordance with the chain of ustody document. This analytical report must be reproduced in its entirety.

Page___ of ___

CHAIN-OF-CUSTODY RECORD

– EnviroMatrix Analytical, Inc. –

4340 Viewridge Ave., Ste. A - San Diego, CA 92123 - Phone (858) 560-7717 - Fax (858) 560 7763

EMA LOG#: 10L 0413

Client: Dale Gardens Mobil Home Park
Attn: Rocky Vandegraff
Samplers(s): Julio Palacios
Address: 1020 Evan Hewes Hwy
El Centro CA 92243
Phone: 760 356 5832 Fax: 760 356 2480
Email: jpalacios@holtville.ca.gov
Billing Address: same

Project ID: Effluent
Project #: PO #:

Requested Analysis

ID #	Client Sample ID	Sample Date	Sample Time	Sample Matrix	Container # / Type	Oil & Grease □ 413.1 □ 413.2 □ 1664	8015B (TPH) □ Gas □ Diesel □ Ext	624/8260 (VOC) Full BTXE MTBE Oxy Nap	625 / 8270 (SVOC) □ PAH only	608 / 8081 (Organochlorine Pesticides)	608 / 8082 (Polychlorinated Biphenyls)	8141 (Organophosphorus Pesticides)	TBT (Organotin Compounds)	□ pH □ EC □ TSS □ TDS	□ Nitrate □ Nitrite □ TKN □ NH3	CAC Title 22/CAM17 Metals □ TTLC □ STLC	TCLP (RCRA) □ Metals □ Organics	Cd Cr Cu Pb Ni Ag Zn □ Dissolved	Coliform, □ Total (MTF) □ Fecal (MTF)	Colilert, T+E.Coli □ P/A □ Enumeration	Enterococcus, □ MTF □ Enterolert	Heterotrophic Plate Count (HPC)	□ BOD □ COD □ Cyanide					
1	Effluent	12-08-10	9:00	WW															X	X	X							
2	Mixed liquor	12-08-10	9:00	WW										X														
3																												
4																												
5																												
6																												
7																												
8																												
9																												
10																												

DEC 8'10 14:13

Matrix Codes: A = Air, DW = Drinking Water, GW = Groundwater, SW = Storm Water
WW = Wastewater, S = Soil, SED = Sediment, SD = Solid, T = Tissue, O = Oil, L = Liquid
Shipped By: □ Courier □ UPS □ FedEx □ USPS □ Client Drop Off □ Other
[1]Turn-Around-Time: □ Same Day □ 24 hr □ 48 hr □ 3 day □ 4 day □ 5 day □ STD (7 day)
[2]Reporting Requirements: □ Fax □ PDF □ Excel □ Geotracker/EDF □ Hard Copy □ EDT
[3]Sample Disposal: □ By Laboratory □ [4]Return to Client: P/U or Delivery □ Archive

Sample Integrity	
Correct Containers: Yes No N/A	Containers Properly Preserved: Yes No N/A
Custody Seals Intact: Yes No N/A	Temp @ Receipt: 3°C
COC/Labels Agree: Yes No N/A	Sampled By: Client EMA Autosampler

RELINQUISHED BY	DATE/TIME	RECEIVED BY
Signature: [signature]	12/8/10 10:21	Signature: [signature]
Print: Julio Palacios		Print: Kristin Hutt
Company: Dale Gardens		Company: KNS
Signature: [signature]	12/8/10 10:07	Signature: [signature]
Print: Kristin Hutt		Print: Jonathan Burgos
Company: KNS		Company: EMA
Signature		Signature
Print		Print
Company:		Company:

Project/Sample Comments:

[1]Additional costs may apply, consult a project manager for details.

[2]EMA reserves the right to return any samples that do not match our waste profile.

NOTE: By relinquishing samples to EMA, Inc., client agrees to pay for the services requested on this COC form and any additional analyses performed on this project. Payment for services is due within 30 days from date of invoice. Samples will be disposed of 7 days after report has been finalized unless otherwise noted. All work is subject to EMA's terms and conditions.

EnviroMatrix Analytical, Inc.

10 January 2011

EMA Log #: 10L0371

Date Gardens R.V.
Attn: Rocky Vandergriff
1020 W. Evan Hewes Hwy, Spc 41
El Centro, CA 92243-9551

Project Name: Effluent Monitoring

Enclosed are the results of analyses for samples received by the laboratory on 12/15/10 14:45. Samples were analyzed pursuant to client request utilizing EPA or other ELAP approved methodologies. I certify that this data is in compliance both technically and for completeness.

Dan Verdon
Laboratory Director

CA ELAP Certification #: 2564

4340 Viewridge Avenue, Suite A - San Diego, California 92123 - (858) 560-7717 - Fax (858) 560-7763
Analytical Chemistry Laboratory

Client Name: Date Gardens R.V.
Project Name: Effluent Monitoring

EMA Log #: 10L0371

ANALYTICAL REPORT FOR SAMPLES

Sample ID	Laboratory ID	Matrix	Date Sampled	Date Received
Effluent	10L0371-01	Wastewater	12/15/10 09:00	12/15/10 14:45
Effluent	10L0371-02	Wastewater	12/15/10 09:00	12/15/10 14:45
Effluent	10L0371-03	Wastewater	12/15/10 09:00	12/15/10 14:45
Influent	10L0371-04	Wastewater	12/15/10 09:00	12/15/10 14:45
RSW-001	10L0371-05	Water	12/15/10 09:30	12/15/10 14:45
RSW-002	10L0371-06	Water	12/15/10 09:30	12/15/10 14:45
RSW-001	10L0371-07	Water	12/15/10 09:30	12/15/10 14:45
RSW-001	10L0371-08	Water	12/15/10 09:30	12/15/10 14:45
RSW-002	10L0371-09	Water	12/15/10 09:30	12/15/10 14:45
RSW-002	10L0371-10	Water	12/15/10 09:30	12/15/10 14:45

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.