



EDMUND G. BROWN JR.  
GOVERNOR

MATTHEW RODRIGUEZ  
SECRETARY FOR  
ENVIRONMENTAL PROTECTION

---

## State Water Resources Control Board

Division of Drinking Water

June 9, 2016  
Certified Mail/Return  
7012 3460 0003 1112 7697

Colusa Co. Service Area #2 - Stonyford  
1215 Market Street  
Colusa, CA 95932

Attention: Michael Azevedo

**Subject: Public Water System No. 0600005 – Citation No. 21-16C-015 for failing to monitor and report dual TTHM and HAA5 samples in 2015.**

The Colusa Co. Service Area #2 – Stonyford water system is classified as a community water system. Per Section 64534.2(d)(1), Title 22, of the California Code of Regulations (CCR), Colusa Co. Service Area #2 – Stonyford is required to collect and report one dual sample set annually for total trihalomethanes (TTHM) and haloacetic acids (HAA5) analysis. The water system did not collect and report this sample set for the year 2015.

Therefore, this Citation is hereby issued to the water system for violating the monitoring and reporting requirements per the California Code of Regulations cited above.

Section 116577 of the California Safe Drinking Water Act provides for the department to be reimbursed by the public water system for costs incurred for preparing and issuing a citation. The billing rate is approximately \$153 per hour. You will receive a bill for this cost, typically by September 1<sup>st</sup>, from our Fee Billing Unit in Sacramento.

If you have any questions please call Paul Rowe at (530) 224-4866. You may also contact me directly at (530) 224-4861.

A handwritten signature in black ink, appearing to read "R. Crenshaw".

Reese B. Crenshaw, P.E.  
Valley District Engineer  
DRINKING WATER FIELD  
OPERATIONS BRANCH

Enclosures

---

FELICIA MARCUS, CHAIR | THOMAS HOWARD, EXECUTIVE DIRECTOR

364 Knollcrest Drive, Suite 101, Redding, CA 96002 | [www.waterboards.ca.gov](http://www.waterboards.ca.gov)

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27

STATE WATER RESOURCES CONTROL BOARD  
DIVISION OF DRINKING WATER

**Public Water System:** Colusa Co. Service Area #2 - Stonyford  
**Water System No.:** 0600005

**To:** Colusa Co. Service Area #2 - Stonyford  
Attn: Michael Azevedo  
1215 Market Street  
Colusa, CA 95932

**Issued:** June 9, 2016  
VIA CERTIFIED MAIL

**CITATION NO. 21-16C-015 FOR NONCOMPLIANCE**  
**with Title 22 California Code of Regulations**  
**Section 64534**

Section 116650 of the California Health and Safety Code (CHSC) authorizes the issuance of a citation for failure to comply with a requirement of the California Safe Drinking Water Act (CHSC, Division 104, Part 12, Chapter 4, commencing with Section 116270), or any regulation, standard, permit, or order issued thereunder.

The State Water Resources Control Board, acting by and through its Division of Drinking Water (hereinafter "Division") and the Deputy Director for the Division,

1 hereby issues a citation to Colusa Co. Service Area #2 - Stonyford for failure to  
2 comply with Section 64534.2(d)(1), Title 22, of the California Code of Regulations  
3 (CCR).

4  
5 **APPLICABLE AUTHORITIES**

6 Section 116650 of the CHSC states:

7  
8 *(a) If the department determines that a public water system is in violation*  
9 *of this chapter or any regulation, permit, standard, citation, or order*  
10 *issued or adopted thereunder, the department may issue a citation to*  
11 *the public water system. The citation shall be served upon the public*  
12 *water system personally or by certified mail. Service shall be deemed*  
13 *effective as of the date of personal service or the date of receipt of*  
14 *the certified mail. If a person to whom a citation is directed refuses to*  
15 *accept delivery of the certified mail, the date of service shall be*  
16 *deemed to be the date of mailing.*

17  
18 *(b) Each citation shall be in writing and shall describe the nature of the*  
19 *violation or violations, including a reference to the statutory provision,*  
20 *standard, order, citation, permit, or regulation alleged to have been*  
21 *violated.*

22  
23 *(c) A citation may specify a date for elimination or correction of the*  
24 *condition constituting the violation.*  
25

1           (d) A citation may include the assessment of a penalty as specified in  
2           subdivision (e).

3  
4           (e) The department may assess a penalty in an amount not to exceed  
5           one thousand dollars (\$1,000) per day for each day that a violation  
6           occurred, and for each day that a violation continues to occur. A  
7           separate penalty may be assessed for each violation.  
8

9  
10       Section 64534.2(d)(1), Title 22, of the CCR states in relevant part:

11  
12           (d) By the applicable date specified in Section 64530(d), and in lieu of  
13           TTHM and HAA5 monitoring in subsection (a):

14  
15                   (1) Community and nontransient noncommunity water systems  
16                   shall monitor for TTHM and HAA5 at the frequencies and  
17                   location totals indicated in Table 64534.2-C and in accordance  
18                   with the monitoring plan developed pursuant to Section  
19                   64534.8;

20  
21  
22       **STATEMENT OF FACTS**

23       The Colusa Co. Service Area #2 - Stonyford (Water System) is classified as a  
24       community water system serving approximately 200 people. Per Table 64534.2-C of  
25       the CCR, the Water System is required to collect one dual sample set annually for  
26       total trihalomethanes (TTHM) and haloacetic acids (HAA5) analysis. The Water

1 Water System developed a Stage 2 Disinfection Byproduct Rule (DBPR) monitoring  
2 plan and submitted to the Division in August of 2014. The plan specifies the collection  
3 of one dual sample set annually in the month of August. The Water System failed to  
4 collect and report this sample set in the year 2015.

5

6 **DETERMINATIONS**

7 The Division has determined that the Water System violated Section 64534.2(d)(1),  
8 Title 22, of the CCR, in that the Water System failed to collect and report a dual  
9 sample set of TTHM and HAA5 samples in the year 2015.

10

11 **DIRECTIVES**

12 The Water System is hereby directed to take the following actions:

13

14 1. Comply with Section 64534.2, Title 22, of the CCR in all future monitoring  
15 periods.

16

17 2. The Water System shall provide public notification (by inclusion in the **2016**  
18 **Consumer Confidence Report**) of the failure to collect and report a dual  
19 sample set of TTHM and HAA5 samples in the year 2015. **Within 10 days**  
20 **of providing notification**, the Water System shall submit the enclosed  
21 proof of notification form (Attachment 1).

22

23 All documents required by this Citation to be submitted to the Division shall be  
24 submitted to the following address:

25

26

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26

Reese B. Crenshaw, P. E.  
Valley District Engineer  
Drinking Water Field Operations  
Division of Drinking Water  
State Water Resources Control Board  
364 Knollcrest Drive, Suite 101  
Redding, CA 96002  
(530) 224-4800

Nothing in this Citation relieves the Water System of its obligation to meet the requirements of Health and Safety Code, Division 104, Part 12, Chapter 4 (California Safe Drinking Water Act), or any regulation, permit, standard or order issued or adopted thereunder.

The Division reserves the right to make such modifications to this Citation, as it may deem necessary to protect public health and safety. Such modifications may be issued as amendments to this Citation and shall be effective upon issuance.

**FURTHER ENFORCEMENT ACTION**

The California SDWA authorizes the State Board to: issue citation with assessment of administrative penalties to a public water system for violation or continued violation of the requirements of the California SDWA or any permit, regulation, permit or order issued or adopted thereunder including, but not limited to, failure to correct a violation identified in a citation or compliance order. The California SDWA also authorizes the State Board to take action to suspend or revoke a permit that has been issued to a public water system if the system has violated applicable law or regulations or has

1 failed to comply with an order of the State Board; and to petition the superior court to  
2 take various enforcement measures against a public water system that has failed to  
3 comply with violates an order of the State Board. The State Board does not waive any  
4 further enforcement action by issuance of this citation.

5

6 **PARTIES BOUND**

7 This Citation shall apply to and be binding upon the Water System, its officers,  
8 directors, agents, employees, contractors, successors, and assignees.

9

10 **SEVERABILITY**

11 The directives of this Citation are severable, and the Water System shall comply with  
12 each and every provision thereof notwithstanding the effectiveness of any other  
13 provision.

14

15

16


*R. Crenshaw*

*6/8/16*

17

18 Reese B. Crenshaw, P.E., District Engineer  
19 Valley District  
20 Drinking Water Field Operations Branch

Date



21

22

## CERTIFICATION OF COMPLETION OF PUBLIC NOTIFICATION

This form when completed and returned to the Division of Drinking Water (364 Knollcrest Drive, Suite 101, Redding, CA 96002 or fax to 530-224-4844), serves as certification that public notification to water users was completed as required by the State Water Resources Control Board. Completing public notification and providing the Division with certification is important. Failure to do so will result in additional hourly time charges to your water utility and may result in a formal enforcement action with monetary penalties.

**Public Water System Name** \_\_\_\_\_ Colusa Co. Service Area #2 - Stonyford

**Public Water System No.** \_\_\_\_\_ 0600005

Public notification for the 2015 annual TTHM and HAA5 monitoring failure was performed by the following method(s):

**Check and Complete**

a) \_\_\_\_\_ By including this notice in the 2016 Consumer Confidence Report.

For this method, provide the date (or dates) that the notice was posted \_\_\_\_\_.

I hereby certify that the above information is factual.

\_\_\_\_\_  
Printed Name

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date