

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

STATE OF CALIFORNIA
WATER RESOURCES CONTROL BOARD
DIVISION OF DRINKING WATER

TO: FCPG/ Choinumni Campground
2220 Tulare Street, 6th Floor
Fresno, CA 93721

Water System No. 1000270

Attn: David Chavez

**CITATION FOR VIOLATION OF CALIFORNIA CODE OF REGULATIONS, TITLE 22,
SECTION 64426.1 (b) (2) - TOTAL COLIFORM MAXIMUM CONTAMINANT LEVEL
May, June and August 2014
CITATION NO. 03-23-14C-065
Issued on September 24, 2014**

Section 116650 of the California Health and Safety Code authorizes the issuance of a citation to a public water system for violation the California Safe Drinking Water Act (Health and Safety Code, Division 104, Part 12, Chapter 4, commencing with Section 116270) (hereinafter "California SDWA"), or any regulation, standard, permit or order issued or adopted thereunder.

The State Water Resources Control Board, acting by and through its Division of Drinking Water (hereinafter "Division") and the Deputy Director for the Division (hereinafter "Deputy Director"), hereby issues a citation to the FCPG/Choinumni Campground Water System (hereinafter, Water System) (mailing address: 2220 Tulare Street, 6th floor, Fresno, CA

29 93721) for violation of California Code of Regulations (CCR), Title 22, Section 64426.1
30 subsections (b)(2).

31 **APPLICABLE AUTHORITIES**

32 **Section 116650 of California Health and Safety Code provides:**

33 (a) If the department determines that a public water system is in violation of this chapter or
34 any regulation, permit, standard, citation, or order issued or adopted thereunder, the
35 department may issue a citation to the public water system. The citation shall be served
36 upon the public water system personally or by certified mail. Service shall be deemed
37 effective as of the date of personal service or the date of receipt of the certified mail. If a
38 person to whom a citation is directed refuses to accept delivery of the certified mail, the
39 date of service shall be deemed to be the date of mailing.

40 (b) Each citation shall be in writing and shall describe the nature of the violation or
41 violations, including a reference to the statutory provision, standard, order, citation, permit,
42 or regulation alleged to have been violated.

43 (c) A citation may specify a date for elimination or correction of the condition constituting
44 the violation.

45 (d) A citation may include the assessment of a penalty as specified in subdivision (e).

46 (e) The department may assess a penalty in an amount not to exceed one thousand
47 dollars (\$1,000) per day for each day that a violation occurred, and for each day that a
48 violation continues to occur. A separate penalty may be assessed for each violation.

49 **California Code of Regulations, Title 22, Section 64426.1, subsections (a) and (b)**
50 **provide, in relevant part:**

51 **§64426.1. Total Coliform Maximum Contaminant Level (MCL).**

52 (a) Results of all samples collected in a calendar month pursuant to Sections 64423,
53 64424, and 64425 that are not invalidated by the Department or the laboratory shall be
54 included in determining compliance with the total coliform MCL. Special purpose
55 samples such as those listed in §64421(b) and samples collected by the water
56 supplier during special investigations shall not be used to determine compliance with
57 the total coliform MCL.

58 (b) A public water system is in violation of the total coliform MCL when any of the
59 following occurs:

60 (1) For a public water system which collects at least 40 samples per month, more
61 than 5.0 percent of the samples collected during any month are total coliform-
62 positive; or

63 (2) For a public water system which collects fewer than 40 samples per month,
64 more than one sample collected during any month is total coliform-positive



STATEMENT OF FACTS

65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81

The Water System is operated under Water Supply Permit No. 03-12-08P-043, issued on September 11, 2008. FCPG/Choinumni Campground Water System is a transient non-community water system serving a population that varies seasonally through approximately fifty (50) service connections.

The Water System is required to collect a minimum of one (1) distribution system bacteriological sample per quarter. The bacteriological water analysis results submitted by the Water System reported the presence of total coliform bacteria in two (2) of nine (9) samples in May of 2014, and in four (4) of five (5) samples collected by the Water System in June 2014. Additionally, the Water System reported the presence of total coliform bacteria in two (2) of five (5) samples collected by the Water System in August 2014. None of the positive samples showed the presence of fecal coliform or *E. coli* bacteria.

The following table summarizes the bacteriological monitoring conducted during the months of May, June, July and August of 2014.

Collection Date	Number of Samples	Sample Labeled	Number TC positive	Number E. Coli positive
5/7/2014	1	Routine	1	0
5/8/2014	4	Repeat (including well)	1 (the well)	0
5/15/2014	4	Repeat (including well)	0	0
5/15/2014	5	Well Cycle Test	0	0
6/3/2014	5	Routine (all distribution)	4	0
7/2/2014	4	"Post Cl2" (including well)	0	0
7/15/2014	5	Routine (all distribution)	1	0

7/17/2014	4	Repeat (including well)	0	0
8/5/2014	5	Routine (all distribution)	2	0
8/12/2014	5	Well Cycle Test	0	0
8/29/2014	4	Repeat	0	0

82

83 Due to the above-mentioned total coliform positive samples, the Water System failed the
84 total coliform MCL for the months of May, June and August of 2014. Results for water
85 samples tested for coliform bacteria during 2014 are summarized in Attachment A.
86 Following the second disinfection of the well and distribution system in August 2014, a
87 well cycle test was conducted on August 12, 2014 and all five samples were negative for
88 total coliform bacteria. Additionally, four repeat distribution samples, collected on August
89 29, 2014, were all absent for total coliform bacteria. Although the source of the coliform
90 contamination is not definitively known, it is suspected that it originated in the distribution
91 system. As noted in the most recent sanitary survey inspection report issued January 8,
92 2014, a dual system to provide untreated surface water for irrigation is present in this
93 campground. This presents significant risk should there be any intertie between the
94 potable and non-potable systems. Neither the shutdown test required in the directives of
95 that report, nor a valid cross connection control survey has been conducted. The Water
96 System shall provide as built plans showing the location of potable water pipes and
97 appurtenant facilities as well as the non-potable raw water piping. To ensure no further
98 cross connections are created between the potable and non-potable water systems, the
99 Department will require an annual shut down test to demonstrate no interconnections
100 exist.

101

102 The five routine distribution samples required the month following August 2014, which had
103 two total coliform-positive samples, have not yet been collected.



104

105 The Groundwater Rule adopted by the Department, effective August 18, 2011, requires
106 the collection of a sample for bacteriological evaluation from wells serving the system in
107 response to a coliform positive distribution sample. This requirement was met with each
108 round of repeat sampling.

109

VIOLATION

110 The Drinking Water Field Operations Branch of the State Water Resources Control Board
111 – Division of Drinking Water (hereinafter 'Division') hereby issues a Citation to
112 FCPG/Choinumni Campground Water System (hereinafter 'Water System'), for failure to
113 comply with Section 116555(a)(1) of the CHSC and Section 64426.1(b)(2) of Title 22,
114 California Code of Regulations (CCR). Specifically, the Water System (mailing address:
115 2220 Tulare Street, 6th floor, Fresno, CA 93721) failed to comply with the total coliform
116 Maximum Contaminant Level (MCL) for the months of May, June and August 2014.

117

118

NOTIFICATION REQUIREMENTS

119 Section 64426.1(c) requires a public water system to notify the Department and the
120 consumers of the water system, when a violation of Section 64426.1(b)(1) through (4) the
121 total coliform MCL occurs. Notification to the Department shall be by the end of the
122 business day on which the violation has been determined. If the Department is closed,
123 notification shall be within 24 hours of the determination. The Department was notified on
124 May 12, 2014, in accordance with the above-referenced section.

125

126 A Tier 2 Public Notice for violation of paragraph 64426.1(b) (2) shall be given pursuant to
127 Section 64463.4 and 64465. The Tier 2 Public Notice shall include the mandatory health
128 effects language from Appendix 64465-A for a total coliform MCL failure.

129



130 The Water System shall post the public notice in conspicuous locations within the water
131 system. Section 116450(g) requires that upon receipt of notification from a public water
132 system, schools must notify school employees, students, and parents (if the students are
133 minors), residential rental property owners or managers (including nursing homes and
134 care facilities) must notify their tenants and business property owners, managers or
135 operators must notify employees of businesses located on the property.

136 Notification of the public was conducted on May 9, 2014, advising each consumer of the
137 failure of the total coliform MCL during the month of May 2014. A copy of the notice that
138 was posted for each customer is provided as Attachment B. Proof of Notification using
139 the public notice provided as Attachment C is required for the months of June and August
140 2014.

141 DIRECTIVES

142 The Water System is hereby directed to take the following actions:

143

144 1. By September 30, 2014, the FCPG/Choinumni Campground water system shall
145 provide public notification of the total coliform Maximum Contaminant Level failure
146 for June and August 2014 by posting the notice provided as Attachment C in
147 conspicuous locations throughout the area served by the water system.

148

149 By October 15, 2014, the Water System shall provide proof of public notification of
150 the total coliform MCL violation for June and August 2014 by completing
151 Attachment D and returning it to:

152

153

154

155

156

157

Betsy S. Lichti, Senior Sanitary Engineer
Division of Drinking Water
Drinking Water Field Operations Branch
265 W. Bullard Avenue, Suite 101
Fresno, CA 93704



158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190

2. By October 15, 2014, the Water System shall complete and submit the enclosed “Positive Total Coliform Investigation” form to the Division that describes the incident and all corrective actions taken, and the results of the investigation. The appropriate investigation report is provided as Attachment E.

3. By November 15, 2014, the Water System shall provide as built plans showing the location of potable water pipes and appurtenant facilities as well as the non-potable raw water piping.

4. By November 15, 2014, the Water System shall prepare and submit a protocol for an annual shut down test for review and approval prior to conducting the first test. By November 30, 2014, and each year thereafter, the Water System shall perform a shut down test to demonstrate no interconnections exist between the potable and non-potable water sources.

5. The Water System will be required to maintain an approved Cross-Connection Control Program which shall include the following elements (as applied from Title 17, California Code of Regulations, Section 7584), and as outlined in Attachment F:
 - a. The conducting of surveys to identify water user premises or locations where cross connections are likely to occur,
 - b. The provisions of backflow protection by the Water user at the user’s connection or within the user’s premises or both,
 - c. The provision of at least one person trained in cross-connection control to carry out the cross-connection program,
 - d. The establishment of a procedure or system for annual testing of backflow preventers, and
 - e. The maintenance of records of locations, tests, and repairs of backflow preventers.

191
192
193
194
195

The survey and documentation of a valid Cross Connection Control Program shall be submitted to the Department by November 15, 2014. You may contact the SWRCB-DDW Fresno District for guidance in identifying a cross-connection specialist to conduct the survey.

196
197
198

6. If any additional violations of the total coliform MCL occur, the Water System will be required to install continuous chlorination equipment immediately.

199

PARTIES BOUND

200
201
202

This Citation shall apply to and be binding upon FCPG/Choinumni Campground Water System, its officers, directors, shareholders, agents, employees, contractors, successors, and assignees.

203

SEVERABILITY

204
205
206

The Directives of this Citation are severable, and FCPG/Choinumni Campground Water System shall comply with each and every provision thereof, notwithstanding the effectiveness of any other provision.

207

208

FURTHER ENFORCEMENT ACTION

209
210
211
212
213
214
215
216
217
218
219

The California SDWA authorizes the Division to: issue citation with assessment of administrative penalties to a public water system for violation or continued violation of the requirements of the California SDWA or any permit, regulation, permit or order issued or adopted thereunder including, but not limited to, failure to correct a violation identified in a citation or compliance order. The California SDWA also authorizes the Division to take action to suspend or revoke a permit that has been issued to a public water system if the system has violated applicable law or regulations or has failed to comply with an order of the Division; and to petition the superior court to take various enforcement measures against a public water system that has failed to comply with violates an order of the Division. The Division does not waive any further enforcement action by issuance of this citation.



220

221

9/24/14

Betsy Licht

222

Date

Betsy S. Licht, P.E.,
District Engineer
Division of Drinking Water
State Water Resources Control Board

223

224

225

226

227

228

229

230

231

232

233

234

235

236

237

238

239

240

241

242

243

244

245

246

247

248

249

250

251

252

Attachments:

253

A. Bacteriological Distribution and Source Monitoring Reports

254

B. Completed Public Notice for May 2014

255

C. Public Notice Template for June and August 2014

256

D. Proof of Notification

257


E. Positive Total Coliform Investigation Form

258

F. Cross-Connection Control Guidance for Small Water Systems

259





Bacteriological Distribution Monitoring Report

1000270 **FCPG/Choinumni Campground** *Distribution System Freq: 1/Q*

<i>Sample Date</i>	<i>Time</i>	<i>Location</i>	<i>T Coli</i>	<i>E Coli</i>	<i>F Coli</i>	<i>Type</i>	<i>CL2</i>	<i>Violation</i>	<i>Comment</i>
2/27/2013	14:10	ROU 1	A	A		Routine			
4/16/2013	13:13	rou-2	A	A		Routine			
7/16/2013	13:40	ROU-3	P	A		Routine			
7/18/2013	13:38	ROU-3	A	A		Repeat			
7/18/2013	14:16	3-REP1	A	A		Repeat			
7/18/2013	14:31	3-REP2 Upstream	A	A		Repeat			
7/18/2013	14:45	3-REP3 Downstream	A	A		Repeat			
8/30/2013	7:42	Rou-5	A	A		Routine			
8/30/2013	7:45	Rou 2	A	A		Routine			
8/30/2013	7:50	Rou 1	A	A		Routine			
10/23/2013	13:29	Rou-4	A	A		Routine			
2/10/2014	12:53	Downstream Picnic area	A	A		Routine			
2/10/2014	13:02	Tap @ Lot 54	A	A		Routine			
2/10/2014	13:10	Upstreat @ Lot 15	A	A		Routine			
2/10/2014	13:15	Upstream @ Lot 1	A	A		Routine			
2/10/2014	13:22	Group Campsite	A	A		Routine			
3/12/2014	13:45	Group Campsite-Special	A	A		special	1.2		
3/12/2014	13:53	Ne Campground lot 23 special	A	A		Special	1.2		
3/12/2014	14:02	south campground (Lot 69)	A	A		Routine			
5/7/2014	14:20	Site 2	P	A		Routine			
5/8/2014	13:40	Site 2-SE campground	A	A		Repeat			
5/8/2014	13:48	Upstream @ south	A	A		Repeat			
5/8/2014	13:56	Downstream @ NE campground	A	A		Repeat			
5/8/2014	14:06	Well Source	P	A		Source Repeat		MCL	
5/15/2014	13:18	Well	A	A		Special	0.05		
5/15/2014	13:40	Group Campsite	A	A		Special	0.05		
5/15/2014	14:00	NE Campground	A	A		Special	0.05		
5/15/2014	14:10	South Campground	A	A		Routine	0.05		
6/3/2014	10:16	Group Campsite Special	P	A		Routine			
6/3/2014	10:22	Site 1 - NE Campground Special	A	A		Routine			
6/3/2014	10:28	Site 5 - Center Campground Special	P	A		Routine		MCL	
6/3/2014	10:34	Site 2- SE Campground Special	P	A		Routine			
6/3/2014	10:38	Site 3-South Campground Special	P	A		Routine			
7/2/2014	14:50	Well Special	A	A		Post CL2	0.05		
7/2/2014	15:00	South Campground Special	A	A		Post CL2	0.05		
7/2/2014	15:06	NE Campground Special	A	A		Post CL2	0.05		
7/2/2014	15:12	Group Campsite Special	A	A		Post CL2	0.05		
7/15/2014	10:30	Group Campsite "Routine"	A	A		Routine			
7/15/2014	10:38	NE Campground "Routine"	A	A		Routine			
7/15/2014	10:45	South Campground "Routine"	A	A		Routine			
7/15/2014	10:55	SE Campground "Routine"	P	A		Routine			
7/15/2014	11:10	Center Campground	A	A		Routine			
7/17/2014	11:30	Well	A	A		Source Repeat			

<i>Sample Date</i>	<i>Time</i>	<i>Location</i>	<i>T Coli</i>	<i>E Coli</i>	<i>F Coli</i>	<i>Type</i>	<i>CI2</i>	<i>Violation</i>	<i>Comment</i>
7/17/2014	11:40	Downstream@ NE Campground	A	A		Repeat			
7/17/2014	11:45	Upstream @ South Campground	A	A		Repeat			
7/17/2014	11:50	Site 2 SE Campground	A	A		Repeat			
8/5/2014	10:33	Site 1 - NE Campground - Routine	A	A		Routine			
8/5/2014	10:45	Group Campsite	A	A		Routine			
8/5/2014	11:00	Center Campground	P	A		Routine			
8/5/2014	11:10	Site 2 - SE Campground	P	A		Routine		MCL	
8/5/2014	11:18	Site 3 - South Campground	A	A		Routine			
8/29/2014	8:20	SS #4	A	A		Repeat			
8/29/2014	8:25	SS #1	A	A		Repeat			
8/29/2014	8:30	SS#2	A	A		Repeat			
8/29/2014	8:35	SS #3	A	A		Repeat			

Violation Key

MCL	Exceeds the maximum contaminant level	MR5	Incorrect number of repeat samples as follow-up to a positive sample
MR1	No monthly sample for the report month	MR6	No source sample
MR2	No quarterly sample for the report month	MR7	No summary report submitted
MR3	Incorrect number of routine samples for the report month	MR8	Other comments and/or info
MR4	Did not collect 5 routine samples for previous month's positive sample	MR9	CI2 not reported

Source Bacteriological Monitoring Report

1000270 FCPG/Choinumni Campground

<i>Sample Date</i>	<i>Time</i>	<i>Source</i>	<i>Sample Type</i>	<i>Test Method</i>	<i>T Coli</i>	<i>E Coli</i>	<i>F Coli</i>	<i>HPC</i>	<i>Violation</i>	<i>Comments</i>
8/30/2013	8:00	well	Well	P/A	A	A				
3/12/2014	14:12	well special	Well	P/A	A	A				
5/15/2014	12:45	@ first water	Well	P/A	A	A				
5/15/2014	12:46	@1 min	Well	P/A	A	A				
5/15/2014	12:50	@5 min	Well	P/A	A	A				
5/15/2014	13:00	@15 min	Well	P/A	A	A				
5/15/2014	13:15	@30 min	Well	P/A	A	A				
8/12/2014	8:15	Well - Start up	Well Cycle	MPN	<1.1	<1.1				
8/12/2014	8:16	Well - 1 min	Well Cycle	MPN	<1.1	<1.1				
8/12/2014	8:20	Well - 5 min	Well Cycle	MPN	<1.1	<1.1				
8/12/2014	8:30	Well 15 min	Well Cycle	MPN	<1.1	<1.1				
8/12/2014	8:45	Well - 30 min	Well Cycle	MPN	<1.1	<1.1				

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

FCPG/Choinumni Campgrounds Has Levels of Coliform Bacteria Above the Drinking Water Standard

Our water system recently failed a drinking water standard. Although this incident was not an emergency, as our customers, you have a right to know what you should do, what happened and what we did to correct this situation.

We routinely monitor for drinking water contaminants. We took one samples to test for the presence of coliform bacteria in May 2014. The sample showed the presence of total coliform bacteria. The standard is that no more than one sample per month may show the presence of coliform bacteria.

What should I do?

- **You do not need to boil your water or take other corrective actions.**
- This is not an emergency. If it had been, you would have been notified immediately. Total coliform bacteria are generally not harmful themselves. *Coliforms are bacteria which are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.*
- Usually, coliforms are a sign that there could be a problem with the treatment or distribution system (pipes). Whenever we detect coliform bacteria in any sample, we do follow-up testing to see if other bacteria of greater concern, such as fecal coliform or *E. coli*, are present. **We did not find any of these bacteria in our subsequent testing.**
- People with severely compromised immune systems, infants, and some elderly may be at increased risk. These people should seek advice about drinking water from their health care providers. General guidelines on ways to lessen the risk of infection by microbes are available from EPA's Safe Drinking Water Hotline at 1(800) 426-4791.
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

Due to recent maintenance on the well that serves the Park's day use area and volleyball courts, water test results came back positive. Public Work staff will be treating the affected well and will re-test the water system.

For more information, please contact David Chavez at (559) 600-3004 or Fresno County Public Works and Planning, Parks, 2220 Tulare Street, Suite 600, Fresno, CA 93721.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- SCHOOLS: Must notify school employees, students, and parents (if the students are minors).
- RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS (including nursing homes and care facilities): Must notify tenants.
- BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS: Must notify employees of businesses located on the property.

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

**FCPG Choinumni Park Water System Has Levels of Coliform Bacteria
Above the Drinking Water Standard**

Our water system recently failed a drinking water standard. Although this incident was not an emergency, as our customers, you have a right to know what you should do, what happened and what we did to correct this situation.

We routinely monitor for drinking water contaminants. We took _____ () samples to test for the presence of coliform bacteria during **May, June and August 2014**. _____ of these samples showed the presence of **total coliform bacteria in May**, _____, _____ of these samples showed the presence of **total coliform bacteria in June** and _____ of these samples showed the presence of **total coliform bacteria in August**. The standard is that no more than one sample per month may show the presence of coliform bacteria.

What should I do?

- **You do not need to boil your water or take other corrective actions.**
- This is not an emergency. If it had been, you would have been notified immediately. Total coliform bacteria are generally not harmful themselves. *Coliforms are bacteria which are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.*
- Usually, coliforms are a sign that there could be a problem with the treatment or distribution system (pipes). Whenever we detect coliform bacteria in any sample, we do follow-up testing to see if other bacteria of greater concern, such as fecal coliform or *E. coli*, are present. **We did not find any of these bacteria in our subsequent testing.**
- People with severely compromised immune systems, infants, and some elderly may be at increased risk. These people should seek advice about drinking water from their health care providers. General guidelines on ways to lessen the risk of infection by microbes are available from EPA's Safe Drinking Water Hotline at 1(800) 426-4791.
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

[Describe corrective action]. _____

For more information, please contact _____ [name of contact] at _____ [phone number] or _____ [mailing address].

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS** (including nursing homes and care facilities): Must notify tenants.
- **BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS:** Must notify employees of businesses located on the property.

This notice is being sent to you by FCPG Choinumni Park Water System Date distributed: _____



EDMUND G. BROWN JR.
GOVERNOR



MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board

Division of Drinking Water

ATTACHMENT D

PROOF OF NOTIFICATION

(Return with copy of notice)

As required by Section 116450 of the California Health and Safety Code, I notified all users of water supplied by the **FCPG Choinumni Park** of the failure to meet the **total coliform bacteria MCL** for the months of **May, June and August 2014** as directed by the Department.

Notification was made on _____ by _____
(date)

hand delivered and/or mailed and/or posted written notice.
(circle all that apply)

Signature of Water System Representative

Printed Name

Date

DISCLOSURE: Be advised that Section 116725 and 116730 of the California Health and Safety Code state that any person who knowingly makes any false statement on any report or document submitted for the purpose of compliance with the attached order may be liable for a civil penalty not to exceed five thousand dollars (\$5,000) for separate violation for each day that violation continues. In addition, the violators may be prosecuted in criminal court and upon conviction, be punished by a fine of not more than \$25,000 for each day of violation, or be imprisoned in the county jail not to exceed one year, or by both the fine and imprisonment.

Due: October 15, 2014

Total Coliform MCL Failure: May, June & August 2014

System Number: 1000270

Citation No.: _____