CALIFORNIA
STATE WATER RESOURCES CONTROL BOARD
DIVISION OF DRINKING WATER

TO: PG&E Balch Camp
ATTN: Craig Hunt
P.O. Box 1000
Auberry, CA 93602

CITATION NO. 03-23-15C-033
FOR
VIOLATION OF CALIFORNIA HEALTH AND SAFETY CODE SECTION 116650(a) and TITLE 22, CALIFORNIA CODE OF REGULATIONS, SECTION 64432.1(a)
ANNUAL NITRATE MONITORING AND REPORTING VIOLATION
CALENDAR YEAR 2014
Dated August 11, 2015

The State Water Resources Control Board (hereinafter "Board"), acting by and through its Division of Drinking Water (hereinafter "Division") and the Deputy Director for the Division (hereinafter "Deputy Director"), hereby issues this citation (hereinafter "Citation") pursuant to Section 116650 of the California Health and Safety Code (hereinafter "CHSC") to PG& E Balch Camp for violation of CHSC Section 116550(a) and Title 22, California Code of Regulations (hereinafter "CCR"), Section 64432.1(a).

APPLICABLE AUTHORITIES

CHSC, Section 116555(a)(1) states in relevant part:

(a) Any person who owns a public water system shall ensure that the system does all of the following:

(1) Complies with primary and secondary drinking water standards.

CHSC, Section 116550 states in relevant part:

(a) If the department determines that a public water system is in violation of this chapter or any regulation, permit, standard, citation, or order issued or adopted thereunder, the department may issue a citation to the public water system. The citation shall be served upon the public water system personally or by certified mail. Service shall be deemed effective as of the date of personal service or the date of receipt of the certified mail. If a person to whom a citation is directed refuses to accept delivery of the certified mail, the date of service shall be deemed to be the date of mailing.

(b) Each citation shall be in writing and shall describe the nature of the violation or violations, including a reference to the statutory provision, standard, order, citation, permit, or regulation alleged to have been violated.

(c) A citation may specify a date for elimination or correction of the condition constituting the violation.

(d) A citation may include the assessment of a penalty as specified in subdivision (e).

(e) The department may assess a penalty in an amount not to exceed one thousand dollars ($1,000) per day for each day that a violation occurred, and for each day that a violation continues to occur. A separate penalty may be assessed for each violation.

CCR, Title 22, Section 64431 (hereinafter "Section 64431"), states in relevant part:

Public water systems shall comply with the primary MCLs in Table 64431-A as specified in this article.

Title 22, CCR, Section 64432.1 (a) states in relevant part:

(a) To determine compliance with the MCL for nitrate in Table 64431-A, all public water systems ...shall monitor annually ..."

Table 64431-A
Maximum Contaminant Levels
Inorganic Chemicals

Chemical	*Maximum Contaminant Level, mg/L*
Aluminum	1.
Antimony	0.006
Arsenic	0.010
Asbestos	7 MFL*
Barium	1.
Chemical	*Maximum Contaminant Level, mg/L*
Beryllium	0.004
Cadmium	0.005
Chromium	0.05
Cyanide	0.15
Fluoride	2.0
Hexavalent chromium	0.010
Mercury	0.002
Nickel	0.1
Nitrate (as NO3)	45.
Nitrate+Nitrite (sum as	10.
Nitrite (as nitrogen)	1.
Perchlorate	0.006
Selenium	0.05
Thallium	0.002

* MFL=million fibers per liter; MCL for fibers exceeding 10 um in length.

STATEMENT OF FACTS

The Water System has failed to report a nitrate result for the calendar year 2014 for the following active sources:

TABLE 1

Source Name	Primary Station Code
Balch siphon-Raw	1009129-001

The PG&E Balch water system (hereinafter "Water System") is a transient-non community water system located in Fresno County that supplies water for domestic purposes to

approximately thirty-six (36) individuals through approximately (28) service connections. The Water System is a transient noncommunity public water system as defined in CHSC, section 116275.

The Water System utilizes surface water as its source of domestic water. Title 22, CCR, Division 4, Chapter 15, Article 4, establishes primary drinking water standards and monitoring and reporting requirements for inorganic constituents. All public water systems must comply with the monitoring and reporting requirement for nitrate, as established in Title 22 CCR Section 64432.1, in order to determine if they are in compliance with the maximum contaminant level for nitrate of 45 mg/L.

DETERMINATIONS

Based on the above Statement of Facts, the Division has determined that the Water System has violated CHSC, Section 116550 and Section 64432.1(a) in that the water system failed to report a Nitrate result for the calendar year of 2014.

DIRECTIVES

The Water System is hereby directed to take the following actions:

1. By **August 31, 2015,** the PG&E Balch Camp water system shall provide public notification of the nitrate monitoring and reporting procedural failure by **posting the notice provided as Attachment A in conspicuous locations throughout the area served by the water system for a minimum of seven days.** The Water System is additionally required to use one or more of the following notification methods in order to reach persons not likely to be reached by a public posting: publication in a local newspaper or newsletter distributed to customers,

e-mailing the public notice to water system customers, post the public notice on the internet, or by delivery to each employee or customer.

2. By **September 10, 2015**, the Water System shall provide to the Division proof of notification of the nitrate monitoring and reporting procedural violation using Attachment B. Upon completion of the public notification Attachment B shall be completed and submitted to:

   Betsy S. Lichti, Senior Sanitary Engineer
   Division of Drinking Water
   Drinking Water Field Operations Branch
   265 W. Bullard Avenue, Suite 101
   Fresno, CA 93704

3. The Water system shall ensure that monitoring is conducted annually for nitrate from all its active sources.

4. The Water System shall collect the 2015 annual nitrate sample from each active source by **September 1, 2015**.

5. The Water system shall ensure that the laboratory submits the analytical results to the Division using the Electronic Data Transfer (EDT) no later than the 10th day of the month following completion of the analyses.

PARTIES BOUND

This Citation shall apply to and be binding upon PG&E Balch Camp, its owners, shareholders, officers, directors, agents, employees, contractors, successors, and assignees.

SEVERABILITY

The Directives of this Citation are severable, and Water System shall comply with each and every provision hereof, notwithstanding the effectiveness of any other provision.

FURTHER ENFORCEMENT ACTION

The California SDWA authorizes the Board to: issue a citation with assessment of administrative penalties to a public water system for violation or continued violation of the requirements of the California SDWA or any regulation, permit, standard, citation, or order issued or adopted thereunder including, but not limited to, failure to correct a violation identified in a citation or compliance order. The California SDWA also authorizes the Board to take action to suspend or revoke a permit that has been issued to a public water system if the public water system has violated applicable law or regulations or has failed to comply with an order of the Board; and to petition the superior court to take various enforcement measures against a public water system that has failed to comply with an order of the Board. The Board does not waive any further enforcement action by issuance of this Citation.

8/11/15
Date

Betsy Licht, P.E., District Engineer
Fresno District
State Water Resources Control Board
Division of Drinking Water

Certified Mail No. [7014-3490-0001-7868-8552]

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Nitrate Monitoring Requirements Not Met for PG & E Balch CampWater System

Our water system failed to monitor as required for a drinking water monitoring standard during the year 2014 and, therefore, was in violation of the regulations. Even though this failure was not an emergency, as our customers, you have a right to know what you should do, what happened and what we did to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the year 2014 we did not monitor or test for nitrate and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

- There is nothing you need to do at this time.
- The table below lists the contaminant we did not properly test for during the year 2014, how many samples we are required to take and how often, how many samples we many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
Nitrate	Minimum is One Sample Annually	None	In the 2014 year	_____

If you have health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

Corrective action: _____

For more information, please contact _____ at:

Phone No. (_____) _____ - _____ or Mailing Address _____

_____

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- *SCHOOLS: Must notify school employees, students, and parents (if the students are minors).*
- *RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS (including nursing homes and care facilities): Must notify tenants.*
- *BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS: Must notify employees of businesses located on the property.*

This notice is being sent to you in compliance with the California Domestic Water Quality and Monitoring Regulations as a means of keeping the public informed.

Date Distributed: _____ *Water System No. 1009129*

ATTACHMENT B

PROOF OF NOTIFICATION

(Return with copy of notice)

As required by Section 116450 of the California Health and Safety Code, I notified all users of water supplied by **PG& E Balch Camp** water system of the failure to meet the **monitoring and reporting requirement for Nitrate** for the year 2014 as directed by the Department.

Notification was made on _____ by
(date)

_____ **hand delivered** or **mailed** or **posted** or **other (specify)** _____ written notice.
(*circle all that apply*)

_____
Signature of Water System Representative

_____
Printed Name

_____
Date

DISCLOSURE: Be advised that Section 116725 and 116730 of the California Health and Safety Code state that any person who knowingly makes any false statement on any report or document submitted for the purpose of compliance with the attached order may be liable for a civil penalty not to exceed five thousand dollars ($5,000) for separate violation for each day that violation continues. In addition, the violators may be prosecuted in criminal court and upon conviction, be punished by a fine of not more than $25,000 for each day of violation, or be imprisoned in the county jail not to exceed one year, or by both the fine and imprisonment.

Due to the Department: August 31, 2015
2014 Nitrate M&R Violation
System Number: 1009129
Enforcement Action Number: 03-23-15C-033