



EDMUND G. BROWN JR.
GOVERNOR



MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board

Division of Drinking Water

January 20, 2015

David McIntyre
P.O. Box 218
Caruthers, CA 93609

RE: Caruthers Community Services District – Water System No. 1010039
Ethylene Dibromide MCL Violation – Compliance Order No. 03-23-15R-004

Dear Mr. McIntyre:

On January 20, 2015, the State Water Resources Control Board – Division of Drinking Water (Division) issued Compliance Order No. 03-23-15R-004 to the Caruthers Community Services District (District) for violation of the ethylene dibromide (EDB) maximum contaminant level (MCL). The compliance order is enclosed.

The Compliance Order requires that by no later than **March 31, 2015**, the District must prepare and present to the Division a Corrective Action Plan for improvements to the water system to correct the water quality problem (violation of the EDB MCL). Please note that Division approval is required before proceeding with any changes or additions to your treatment or source of supply. The Compliance Order also requires that the District achieve an EDB running annual average at each compliance point that is less than the EDB MCL, by no later than **July 1, 2017**.


The District must submit a written response to our office by **February 28, 2015**, regarding its intent to comply with the Compliance Order. Arrangements for presenting the Corrective Action Plan can be made by contacting Philip Dutton or me at (559) 447-3300.

Sincerely,

A handwritten signature in cursive script that reads "Betsy Lichti".

Betsy S. Lichti, P.E.
Senior Sanitary Engineer, Fresno District
SOUTHERN CALIFORNIA BRANCH
DRINKING WATER FIELD OPERATIONS

BSL/PD



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

**STATE OF CALIFORNIA
STATE WATER RESOURCES CONTROL BOARD
DIVISION OF DRINKING WATER**

IN RE: **CARUTHERS COMMUNITY SERVICES DISTRICT
WATER SYSTEM NO. 1010039**

TO: **MR. DAVID MCINTYRE, MANAGER
CARUTHERS COMMUNITY SERVICES DISTRICT
P.O. BOX 218
CARUTHERS, CA 93609**

COMPLIANCE ORDER NO. 03-23-15R-004

**FOR NONCOMPLIANCE WITH THE
ETHYLENE DIBROMIDE MAXIMUM CONTAMINANT LEVEL – WELL 04
SECTION 64444, TITLE 22, CALIFORNIA CODE OF REGULATIONS**

Issued on January 20, 2015

Section 116655 of the California Health and Safety Code authorizes the issuance of a compliance order to a public water system for violation of the California Safe Drinking Water Act (Health and Safety Code, Division 104, Part 12, Chapter 4, commencing with Section 116270) (hereinafter “California SDWA”), or any regulation, standard, permit or order issued or adopted thereunder.

The State Water Resources Control Board (hereinafter “State Board”), acting by and through its Division of Drinking Water (hereinafter “Division”) and the Deputy Director for the Division (hereinafter “Deputy Director”), hereby issues a compliance order to the

1 Caruthers Community Services District (hereinafter, "Caruthers CSD" or "District") for
2 violation of California Code of Regulations (hereinafter "CCR"), Section 64444, Maximum
3 Contaminant Levels – Organic Chemicals.

4
5 **APPLICABLE AUTHORITIES**

6
7 **Section 116655, California SDWA, states in relevant part:**

8 (a) Whenever the department determines that any person has violated or is violating this
9 chapter, or any permit, regulation, or standard issued or adopted pursuant to this chapter, the
10 director may issue an order doing any of the following:

- 11 (1) Directing compliance forthwith.
12 (2) Directing compliance in accordance with a time schedule set by the department.
13 (3) Directing that appropriate preventive action be taken in the case of a threatened
14 violation.

15 (b) An order issued pursuant to this section may include, but shall not be limited to, any or
16 all of the following requirements:

- 17 (1) That the existing plant, works, or system be repaired, altered, or added to.
18 (2) That purification or treatment works be installed.
19 (3) That the source of the water supply be changed.
20 (4) That no additional service connection be made to the system.
21 (5) That the water supply, the plant, or the system be monitored.
22 (6) That a report on the condition and operation of the plant, works, system, or water
23 supply be submitted to the department.

24
25 **Section 64444, Title 22, CCR, states in relevant part:**

26 The MCLs of the primary drinking water chemicals shown in Table 64444-A shall not be
27 exceeded in the water supplied to the public.

Table 64444-A
Maximum Contaminant Levels
Organic Chemicals

<i>Chemical</i>	<i>Maximum Contaminant Level (mg/L)</i>
(b) Non-Volatile Synthetic Organic Chemicals (SOCs)	
Alachlor	0.002
Atrazine	0.001
Bentazon	0.018
Benzo(a)pyrene	0.0002
Carbofuran	0.018
Chlordane	0.0001
2,4-D	0.07
Dalapon	0.2
Dibromochloropropane	0.0002
Di(2-ethylhexyl)adipate	0.4
Di(2-ethylhexyl)phthalate	0.004
Dinoseb	0.007
Diquat	0.02
Endothall	0.1
Endrin .	0.002
Ethylene Dibromide	0.00005
Glyphosate	0.7
Heptachlor	0.00001
Heptachlor Epoxide	0.00001
Hexachlorobenzene	0.001
Hexachlorocyclopentadiene	0.05
Lindane.	0.0002
Methoxychlor	0.03
Molinate	0.02
Oxamyl	0.05
Pentachlorophenol	0.001
Picloram	0.5
Polychlorinated Biphenyls	0.0005
Simazine	0.004
Thiobencarb	0.07
Toxaphene	0.003
2,3,7,8-TCDD (Dioxin)	3×10^{-8}
2,4,5-TP (Silvex)	0.05

Additional *Applicable Authorities* are located in Attachment A, which is attached hereto and incorporated by reference.

1 STATEMENT OF FACTS

2
3
4 The Caruthers Community Services District Water System (hereinafter “Water System”) is
5 a publicly owned community water system located in Fresno County that supplies water for
6 domestic purposes to a reported permanent residential population of 2,497 individuals, as
7 reported to the Division, served through 671 residential service connections and ten
8 commercial or industrial service connections. The District operates the Water System under
9 the authority of Permit No. 87-002, issued on January 29, 1987. The permit was amended
10 by Permit Amendment No. 03-90-000, issued on June 12, 1990, for the activation of Well 4
11 and the inactivation of Well 2, due to violations of the DBCP MCL. The Permit was further
12 amended by Permit Amendment No. 03-12-05PA-003, issued on October 3, 2005, for the
13 activation of Well 5.
14

15
16
17 The District utilizes nondisinfected groundwater from three groundwater wells: Wells 03,
18 04, and 05, as its source of domestic water. The District maintains a hydropneumatic
19 pressure tank at each well site to provide distribution system pressure. The District has no
20 storage capacity.
21

22
23 CCR, Title 22, Chapter 15, Article 5.5, establishes primary drinking water standards and
24 monitoring and reporting requirements for organic constituents. Community and
25 nontransient noncommunity water systems must comply with the maximum contaminant
26 level for ethylene dibromide (hereinafter “EDB”) of 0.00005 mg/L, as established in CCR,
27 Section 64444.

1 CCR, Section 64445.1(c)(5)(B), establishes that a system serving fewer than 3,300 persons
2 shall sample quarterly for a minimum of one year, when the level of an organic constituent
3 exceeds an MCL. Further, a system is in violation of an MCL if the running annual average
4 of quarterly samples exceeds that MCL.
5

6
7 A summary of the Water System's recent EDB monitoring is presented in Table 1 below.
8 The Water System was required to begin quarterly monitoring for EDB and
9 dibromochloropropane (hereinafter "DBCP") in Well 03 and Well 05 after monitoring
10 collected on July 31, 2013, resulted in an EDB and DBCP detections above the respective
11 MCLs.
12

13 **Table 1: Recent EDB Monitoring Results (mg/L)**

Sample Quarter	Well 03	Well 04	Well 05
1Q 2014	ND	ND	ND
2Q 2014	0.00006	0.00006	ND
3Q 2014	0.00004	ND	ND
4Q 2014	0.00003	0.00023	ND
4Q 2014 Running Annual Average	0.000034	0.000073	ND

14
15
16
17
18
19 The fourth quarter 2014 RAA for Well 04, calculated using the four 2014 quarterly sample
20 results averaged over a four quarter period, is 0.000073 mg/L, which exceeds the EDB
21 MCL of 0.00005 mg/L. The fourth quarter 2014 RAA for Well 03 is less than the EDB
22 MCL at this time; there has been no detectable EDB in samples reported to the Division for
23 Well 05. A report showing all EDB and DBCP results for the District is provided in
24 Attachment B. No well has had its DBCP RAA violate the DBCP MCL to date.
25
26
27

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

DETERMINATIONS

Based on the above Statement of Facts, the Division has determined that the District has violated the arsenic MCL in water produced by Well 04 during the fourth quarter of 2014, as shown in Table 1 above.

DIRECTIVES

To ensure that the water supplied by the Caruthers Community Services District Water System is at all times safe, wholesome, healthful, and potable, and pursuant to the California SDWA, the District is hereby directed to take the following actions:

1. Comply with CCR, Title 22, Section 64431 in future monitoring periods after conducting upgrades of the physical facility or implementing treatment operations.
2. Provide quarterly public notification of its inability to meet the EDB MCL during any calendar quarter that the four-quarter running annual average exceeds the MCL. Notification procedures and format are provided in Attachment C. An electronic version of Attachment B is available upon request.
3. Provide proof of public notification to the Division following each quarterly notification by the 10th day of the month following notification, using the form provided as Attachment D.

- 1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
4. Continue to collect quarterly samples for EDB from Well 03 and Well 04, as required by CCR, Title 22, Section 644445.1(c)(5)(B). The analytical results shall be reported to the Division electronically by the analyzing laboratory no later than the 10th day following the month in which the analysis was completed.
5. Prepare a Corrective Action Plan identifying improvements to the water system designed to correct the water quality problem (violation of the EDB MCL) and eliminate the need to deliver water to consumers that does not meet primary drinking water standards. The plan shall include a project financing plan and a time schedule for completion of various phases of the project such as design, construction, and startup.
6. Present the Corrective Action Plan required under Directive No. 5, above, to the Division in an office meeting no later than **March 31, 2015**.
7. Submit quarterly progress reports to the Division. The first quarterly progress report shall describe progress made in the second quarter of 2015 and shall be submitted to the Division by **July 10, 2015**, using the form provided as Attachment E.
8. Submit a written response by **February 28, 2015**, indicating its willingness to comply with the directives of this Compliance Order.
9. By no later than **July 1, 2017**, achieve compliance with the EDB maximum contaminant level, with the completion of a project and demonstration that the

1 running annual average is reliably less than the MCL. The Water System shall
2 provide written notification of the date that compliance is achieved, no later than ten
3 days following receipt of the laboratory sampling results.
4

5 All submittals required by this Order shall be addressed to:

6 Betsy S. Lichti, P.E.,
7 Senior Sanitary Engineer
8 State Water Resources Control Board
9 Division of Drinking Water
10 Fresno District
11 265 W. Bullard Avenue, Suite 101
12 Fresno, CA 93704

13 The Division reserves the right to make such modifications to this Order as it may deem
14 necessary to protect public health and safety. Such modifications may be issued as
15 amendments to this Order and shall be effective upon issuance. Nothing in this Compliance
16 Order relieves the Caruthers Community Services District of its obligation to meet the
17 requirements of the California SDWA, or any regulation, standard, permit or order issued
18 thereunder.

19 If the Caruthers Community Services District Water System is unable to perform the tasks
20 specified in this Order for any reason, whether within or beyond its control, and if the
21 Caruthers Community Services District Water System notifies the Division in writing no
22 less than five days in advance of the due date, the Division may extend the time for
23 performance if the Caruthers Community Services District Water System demonstrates that
24 it has used its best efforts to comply with the schedule and other requirements of this Order.
25
26
27

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

PARTIES BOUND

This Compliance Order shall apply to and be binding upon Caruthers Community Services District, its owners, shareholders, officers, directors, agents, employees, contractors, successors, and assignees.

SEVERABILITY

The directives of this Compliance Order are severable, and Caruthers Community Services District Water System shall comply with each and every provision thereof notwithstanding the effectiveness of any provision.

FURTHER ENFORCEMENT ACTION

The California SDWA authorizes the Division to issue citations and compliance orders with assessment of administrative penalties to a public water system for violation or continued violation of the requirements of the California SDWA or any permit, regulation, permit or order issued or adopted thereunder including, but not limited to, failure to correct a violation identified in a citation or compliance order. The California SDWA also authorizes the Division to take action to suspend or revoke a permit that has been issued to a public water system if the system has violated applicable law or regulations or has failed to comply with an order of the Division; and to petition the superior court to take various enforcement measures against a public water system that has failed to comply with an order

of the Division. The Division does not waive any further enforcement action by issuance of
this compliance order.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

1-20-2015
Date


Carl L. Carlucci, P.E.
Supervising Sanitary Engineer
Central California Section
SOUTHERN CALIFORNIA BRANCH
DRINKING WATER FIELD OPERATIONS

CLC/PD

- Attachments:**
Attachment A: Applicable Authorities
Attachment B: EDB and DBCP Monitoring Reports
Attachment C: Public Notification Form
Attachment D: Proof of Notification Form
Attachment E: Quarterly Progress Report Form



Applicable Authorities
Violation of Maximum Contaminant Levels for
Organic Constituents

California Health and Safety Code, Section 116655, states in relevant part:

- (a) Whenever the department determines that any person has violated or is violating this chapter, or any permit, regulation, or standard issued or adopted pursuant to this chapter, the director may issue an order doing any of the following:
- (1) Directing compliance forthwith.
 - (2) Directing compliance in accordance with a time schedule set by the department.
 - (3) Directing that appropriate preventive action be taken in the case of a threatened violation.
- (b) An order issued pursuant to this section may include, but shall not be limited to, any or all of the following requirements:
- (1) That the existing plant, works, or system be repaired, altered, or added to.
 - (2) That purification or treatment works be installed.
 - (3) That the source of the water supply be changed.
 - (4) That no additional service connection be made to the system.
 - (5) That the water supply, the plant, or the system be monitored.
 - (6) That a report on the condition and operation of the plant, works, system, or water supply be submitted to the department.

California Code of Regulations, Title 22, states in relevant part:

§64444. Maximum Contaminant Levels – Organic Chemicals.

The MCLs for the primary drinking water chemicals shown in Table 64444-A shall not be exceeded in the water supplied to the public.

Table 64444-A
Maximum Contaminant Levels
Organic Chemicals

<i>Chemical</i>	<i>Maximum Contaminant Level, mg/L</i>
(a) Volatile Organic Chemicals (VOCs)	
Benzene	0.001
Carbon Tetrachloride	0.0005
1,2-Dichlorobenzene	0.6
1,4-Dichlorobenzene	0.005
1,1-Dichloroethane	0.005
1,2-Dichloroethane	0.0005
1,1-Dichloroethylene	0.006
cis-1,2-Dichloroethylene	0.006
trans-1,2-Dichloroethylene	0.01
Dichloromethane	0.005
1,2-Dichloropropane	0.005

1,3-Dichloropropene	0.0005
Ethylbenzene	0.3
Methyl- <i>tert</i> -butyl ether	0.013
Monochlorobenzene	0.07
Styrene	0.1
1,1,2,2-Tetrachloroethane	0.001
Tetrachloroethylene	0.005
Toluene	0.15
1,2,4-Trichlorobenzene	0.005
1,1,1-Trichloroethane	0.200
1,1,2-Trichloroethane	0.005
Trichloroethylene	0.005
Trichlorofluoromethane	0.15
1,1,2-Trichloro-1,2,2-Trifluoroethane	1.2
Vinyl Chloride	0.0005
Xylenes	1.750*
(b) Non-Volatile Synthetic Organic Chemicals (SOCs)	
Alachlor	0.002
Atrazine	0.001
Bentazon	0.018
Benzo(a)pyrene	0.0002
Carbofuran	0.018
Chlordane	0.0001
2,4-D	0.07
Dalapon	0.2
Dibromochloropropane	0.0002
Di(2-ethylhexyl)adipate	0.4
Di(2-ethylhexyl)phthalate	0.004
Dinoseb	0.007
Diquat	0.02
Endothall	0.1
Endrin	0.002
Ethylene Dibromide	0.00005
Glyphosate	0.7
Heptachlor	0.00001
Heptachlor Epoxide	0.00001
Hexachlorobenzene	0.001
Hexachlorocyclopentadiene	0.05
Lindane	0.0002
Methoxychlor	0.03
Molinate	0.02
Oxamyl	0.05
Pentachlorophenol	0.001
Picloram	0.5
Polychlorinated Biphenyls	0.0005
Simazine	0.004
Thiobencarb	0.07
Toxaphene	0.003
2,3,7,8-TCDD (Dioxin)	3×10^{-8}
2,4,5-TP (Silvex)	0.05

*MCL is for either a single isomer or the sum of the isomers.

§64445. Initial sampling - organic chemicals.

(a) Each community and nontransient-noncommunity water system shall collect four quarterly samples during the year designated by the Department of each compliance period beginning with the compliance period starting January 1, 1993, from each water source at a site prior to any treatment and test for all applicable organic chemicals listed in Table 64444-A. The Department will designate the year based on historical monitoring frequency and laboratory capacity. For surface sources, the samples shall be taken at each water intake. For groundwater sources, the samples shall be taken at each well head. Where multiple intakes or wells draw from the same water supply, the Department will consider sampling of representative sources as a means of complying with this section. Selection of representative sources shall be based on evidence which includes a hydrogeological survey and sampling results. Wells shall be allowed to flow for a minimum of 15 minutes before sampling to insure that the samples reflect the water quality of the source. In place of water source samples, a supplier may collect samples at sites located at the entry points to the distribution system. The samples shall be representative of each source after treatment. The system shall collect each sample at the same sampling site, unless a change is approved by the Department.

(b) For any organic chemical added to Table 64444-A, the water system shall initiate the quarterly monitoring for that chemical in January of the calendar year after the effective date of the MCL.

(c) A water system may request approval from the Department to composite samples from up to five sampling sites, provided that the number of the sites to be composited is less than the ratio of the MCL to the DLR in §64445.1. Approval will be based on a review of three years of historical data, well construction and aquifer information for groundwater, and intake location, similarity of sources, and watershed characteristics for surface water. Compositing shall be done in the laboratory and analyses shall be conducted within 14 days of sample collection.

(1) Systems serving more than 3,300 persons shall composite only from sampling sites within a single system. Systems serving 3,300 persons or less may composite among different systems up to the 5-sample limit.

(2) If any organic chemical is detected in the composite sample, a follow-up sample shall be analyzed within 14 days from each sampling site included in the composite for the contaminants which were detected. The water supplier shall report the results to the Department within 14 days of the follow-up sample collection. If available, duplicates of the original sample taken from each sampling site used in the composite may be used instead of resampling.

(d) A water system may apply to the Department for a monitoring waiver for one or more of the organic chemicals on Table 64444-A in accordance with the following:

(1) A source may be eligible for a waiver if it can be documented that the chemical has not been previously used, manufactured, transported, stored, or disposed of within the watershed or zone of influence and therefore, that the source can be designated nonvulnerable.

(2) If previous use of the chemical locally is unknown or the chemical is known to have been used previously and the source cannot be designated nonvulnerable pursuant to Paragraph (d)(1), it may still be eligible for a waiver based on a review related to susceptibility to contamination. The application to the Department for a waiver based on susceptibility shall include the following:

- (A) previous monitoring results;
- (B) user population characteristics;
- (C) proximity to sources of contamination;
- (D) surrounding land uses;
- (E) degree of protection of the water source;
- (F) environmental persistence and transport of the chemical in water, soil and air;
- (G) elevated nitrate levels at the water supply source; and
- (H) historical system operation and maintenance data including previous Departmental inspection results.

(3) To apply for a monitoring waiver for VOCs, the water system shall have completed the initial four quarters of monitoring pursuant to subsection (a) or three consecutive years of monitoring with no VOCs detected. If granted a waiver for VOC monitoring, a system using groundwater shall collect a minimum of one sample from every sampling site every six years and a system using surface water shall not be required to monitor for the term of the waiver. The term of a VOC waiver shall not exceed three years.

(4) To obtain a monitoring waiver for one or more of the SOC(s), the water system may apply before doing the initial round of monitoring or shall have completed three consecutive years of annual monitoring with no detection of the SOC(s) listed. If the system is granted a waiver for monitoring for one or more SOC(s), no monitoring for the waived SOC(s) shall be required for the term of the waiver, which shall not exceed three years.

(e) For water sources designated by a water supplier as standby sources, the water supplier shall sample each source for any organic chemical added to Table 64444-A once within the three-year period beginning in January of the calendar year after the effective date of the MCL.

(f) Water quality data collected prior to January 1, 1988, for VOCs, or January 1, 1990, for SOC(s), and/or data collected in a manner inconsistent with this section shall not be used in the determination of compliance with the monitoring requirements for organic chemicals.

(g) Data (i.e., a single sample) collected in a manner consistent with this section after January 1, 1998 in which no MTBE is detected, along with a designation of nonvulnerability pursuant to subsection (d), may be used to satisfy the initial monitoring requirements in subsection (a). If the requirements are satisfied in this way by a water system, the system shall begin annual monitoring pursuant to Section 64445.1(b)(1).

(h) Water quality data collected in compliance with the monitoring requirements of this section by a wholesaler agency providing water to a public water system shall be

acceptable for use by that system for compliance with the monitoring requirements of this section.

§64445.1. Monitoring and Compliance – Organic Chemicals.

(a) For the purposes of this article, detection shall be defined by the detection limits for purposes of reporting (DLRs) in Table 64445.1-A:

(b) When organic chemicals are not detected pursuant to Table 64445.1-A.

(1) A water system which has not detected any of the VOCs on Table 64444-A during the initial four quarters of monitoring, shall collect and analyze one sample annually. After a minimum of three years of annual sampling with no detection of a VOC in Table 64444-A, a system using groundwater may reduce the monitoring frequency to one sample during each compliance period. A system using surface water shall continue monitoring annually.

(2) A system serving more than 3,300 persons which has not detected an SOC on Table 64444-A during the initial four quarters of monitoring shall collect a minimum of two quarterly samples for that SOC in one year during the year designated by the Department of each subsequent compliance period. The year will be designated on the basis of historical monitoring frequency and laboratory capacity.

(3) A system serving 3,300 persons or less which has not detected an SOC on Table 64444-A during the initial four quarters of monitoring shall collect a minimum of one sample for that SOC during the year designated by the Department of each subsequent compliance period. The year will be designated on the basis of historical monitoring frequency and laboratory capacity.

(c) When organic chemicals are detected pursuant to Table 64445.1-A.

(1) Prior to proceeding with the requirements of paragraphs (c)(2) through (7), the water supplier may first confirm the analytical result, as follows: Within seven days from the notification of an initial finding from a laboratory reporting the presence of one or more organic chemicals in a water sample, the water supplier shall collect one or two additional sample(s) to confirm the initial finding.

Confirmation of the initial finding shall be shown by the presence of the organic chemical in either the first or second additional sample, and the detected level of the contaminant for compliance purposes shall be the average of the initial and confirmation sample(s). The initial finding shall be disregarded if two additional samples do not show the presence of the organic chemical.

(2) If one or both of the related organic chemicals heptachlor and heptachlor epoxide are detected, subsequent monitoring shall analyze for both chemicals until there has been no detection of either chemical for one compliance period.

(3) A groundwater sampling site at which one or more of the following chemicals has been detected shall be monitored quarterly for vinyl chloride:

trichloroethylene, tetrachloroethylene, 1,2-dichloroethane, 1,1,1-trichloroethane, cis-1,2-dichloroethylene, trans-1,2-dichloroethylene, or 1,1-dichloroethylene. If vinyl chloride is not detected in the first quarterly sample, the sampling site shall be monitored once for vinyl chloride during each compliance period.

(4) If the detected level of organic chemicals for any sampling site does not exceed any shown in Table 64444-A, the water source shall be resampled every three months and the samples analyzed for the detected chemicals. After one year of sampling an approved surface water system or two quarters of sampling a groundwater system, the Department will consider allowing the water supplier to reduce the sampling to once per year upon request, based on a review of previous sampling data. Systems shall monitor during the quarter(s) which previously yielded the highest analytical results.

(5) If the detected level of an organic chemical for any sampling site exceeds that listed in Table 64444-A, the water supplier shall report this information to the Department within 48 hours of receipt of the result. Unless use of the contaminated source is discontinued, the water supplier shall resample the contaminated source and compliance shall be determined as follows:

(A) Water systems serving more than 3,300 persons shall sample monthly for six months and shall submit the results to the Department as specified in §64469. If the average concentration of the initial finding, confirmation sample(s), and six subsequent monthly samples does not exceed the MCL shown in Table 64444-A the water supplier may reduce the sampling frequency to once every three months. If the running annual average or the average concentration of the initial finding, confirmation sample(s), and six subsequent monthly samples exceeds the MCL shown in Table 64444-A, the water system shall be deemed to be in violation of Section 64444.

(B) Water systems serving 3,300 persons or less shall sample quarterly for a minimum of one year and shall submit the results to the Department as specified in §64469. If the running annual average concentration does not exceed the MCL in Table 64444-A, the water supplier may reduce the sampling frequency to once every year during the quarter that previously yielded the highest analytical result. Quarterly monitoring shall resume if any reduced frequency sample result exceeds the MCL. If the running annual average concentration exceeds the MCL in Table 64444-A, the water system shall be deemed to be in violation of §64444.

(C) If any sample would cause the running annual average to exceed the MCL, the water system is immediately in violation. If a system takes more than one sample in a quarter, the average of all the results for that quarter shall be used when calculating the running annual average. If a system fails to complete four consecutive quarters of monitoring, the running annual average shall be based on an average of the available data.

(6) If any resample, other than those taken in accordance with (c)(5) of this section, of a water sampling site shows that the concentration of any organic chemical exceeds a MCL shown in Table 64444-A, the water supplier shall proceed in accordance with (c)(1) and (c)(4), or (c)(5).

(7) If an organic chemical is detected and the concentration exceeds ten times the MCL, the water supplier shall notify the Department within 48 hours of the receipt of the results and the contaminated site shall be resampled within 48 hours to confirm the result. The water supplier shall notify the Department of the result of the confirmation sample(s) within 24 hours of the receipt of the confirmation result(s).

(A) If the average concentration of the original and confirmation sample(s) is less than or equal to ten times the MCL, the water supplier shall proceed in accordance with subsection (c)(5).

(B) If the average concentration of the original and confirmation samples exceeds ten times the MCL, use of the contaminated water source shall immediately be discontinued, if directed by the Department. Such a water source shall not be returned to service without written approval from the Department.

§64463.4. Tier 2 Public Notice

(a) A water system shall give public notice pursuant to this section if any of the following occurs:

- (1) Any violation of the MCL, MRDL, and treatment technique requirements, except:
 - (A) Where a Tier 1 public notice is required under section 64463.1; or
 - (B) Where the Department determines that a Tier 1 public notice is required, based on potential health impacts and persistence of the violations;
- (2) All violations of the monitoring and testing procedure requirements in sections 64421 through 64426.1, article 3 (Primary Standards – Bacteriological Quality), for which the Department determines that a Tier 2 rather than a Tier 3 public notice is required, based on potential health impacts and persistence of the violations;
- (3) Other violations of the monitoring and testing procedure requirements in this chapter, and chapters 15.5, 17 and 17.5, for which the Department determines that a Tier 2 rather than a Tier 3 public notice is required, based on potential health impacts and persistence of the violations; or
- (4) Failure to comply with the terms and conditions of any variance or exemption in place.

(b) A water system shall give the notice as soon as possible within 30 days after it learns of a violation or occurrence specified in subsection (a), except that the water system may request an extension of up to 60 days for providing the notice. This extension would be subject to the Department's written approval based on the violation or occurrence having been resolved and the Department's determination that public health and welfare would in no way be adversely affected. In addition, the water system shall:

- (1) Maintain posted notices in place for as long as the violation or occurrence continues, but in no case less than seven days;
- (2) Repeat the notice every three months as long as the violation or occurrence continues. Subject to the Department's written approval based on its determination that public health would in no way be adversely affected, the water system may be allowed to notice less frequently but in no case less than once per year. No allowance for reduced frequency of notice shall be given in the case of a total coliform MCL violation or violation of a Chapter 17 treatment technique requirement; and
- (3) For turbidity violations pursuant to sections 64652.5(c)(2) and 64653(c), (d) and (f), as applicable, a water system shall consult with the Department as soon as possible within 24 hours after the water system learns of the violation to determine whether a Tier 1 public notice is required. If consultation does not take place within 24 hours, the water system shall give Tier 1 public notice within 48 hours after learning of the violation.

(c) A water system shall deliver the notice, in a manner designed to reach persons served, within the required time period as follows:

(1) Unless otherwise directed by the Department in writing based on its assessment of the violation or occurrence and the potential for adverse effects on public health and welfare, community water systems shall give public notice by:

(A) Mail or direct delivery to each customer receiving a bill including those that provide their drinking water to others (e.g., schools or school systems, apartment building owners, or large private employers), and other service connections to which water is delivered by the water system; and

(B) Use of one or more of the following methods to reach persons not likely to be reached by a mailing or direct delivery (renters, university students, nursing home patients, prison inmates, etc.):

1. Publication in a local newspaper;
2. Posting in conspicuous public places served by the water system, or on the Internet; or
3. Delivery to community organizations.

(2) Unless otherwise directed by the Department in writing based on its assessment of the violation or occurrence and the potential for adverse effects on public health and welfare, noncommunity water systems shall give the public notice by:

(A) Posting in conspicuous locations throughout the area served by the water system; and

(B) Using one or more of the following methods to reach persons not likely to be reached by a public posting:

1. Publication in a local newspaper or newsletter distributed to customers;
2. E-mail message to employees or students;
3. Posting on the Internet or intranet; or
4. Direct delivery to each customer.

§64469 Reporting Requirements

(d) Within 10 days of giving initial or repeat public notice pursuant to Article 18 of this Chapter, except for notice given under 64463.7(d), each water system shall submit a certification to the Department that it has done so, along with a representative copy of each type of public notice given.

DATE: 01/16/15
 REPORT: R-040/2-3

STATE OF CALIFORNIA
 DRINKING WATER PROGRAM

PAGE: 1

DRINKING WATER ANALYSES RESULTS REPORT
 ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
 FOR SAMPLE DATE RANGE OF 19940101 THRU 20150116
 REPORT OF COUNTY: 10 FRESNO

SYSTEM NO: 1010039 NAME: CARUTHERS COMM SERV DIST
 SOURCE NO: 003 NAME: WELL 03

COUNTY: FRESNO
 PSCODE: 1010039-003 CLASS: CMGA STATUS: AU

GROUP IDENTIFICATION	SAMPLE	RESULT *	MCL	DLR	TRIGGER	UNIT
CONSTITUENT IDENTIFICATION	DATE					

S2 REGULATED SOC						
38761 DIBROMOCHLOROPROPANE (DBCP)	02/01/1994	.0300 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	02/06/1995 <	.0000	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	05/15/1995	.0400 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	12/21/1995	.0400 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	03/20/1996	.0100 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	03/11/1998	.0190 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	06/15/1999	.0670 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	03/22/2000 .	.1000 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	04/02/2001 <	.5000 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	04/08/2004 .	.0490 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	12/12/2005 .	.0890 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	07/12/2006	.1800 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	02/13/2007	.0810 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	12/23/2008 <	.0000	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	11/16/2009	.0410 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	12/13/2010 <	.0000	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	07/31/2013 .	.0520 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	01/13/2014 .	.0700 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	06/30/2014 .	.1000 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	07/07/2014 .	.0930 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	10/29/2014 .	.1800 *	.2000	.0100	.0100	UG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER

NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DATE: 01/16/15
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

PAGE: 2

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19940101 THRU 20150116
REPORT OF COUNTY: 10 FRESNO

SYSTEM NO: 1010039 NAME: CARUTHERS COMM SERV DIST
SOURCE NO: 003 NAME: WELL 03

COUNTY: FRESNO
PSCODE: 1010039-003 CLASS: CMGA STATUS: AU

GROUP IDENTIFICATION CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
77651 ETHYLENE DIBROMIDE (EDB)	02/06/1995 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	05/15/1995 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	03/11/1998 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	03/22/2000 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	04/02/2001 <	.5000 *	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	04/08/2004 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	12/12/2005 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	07/12/2006	.0360 *	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	02/13/2007	.0360 *	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	12/23/2008 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	11/16/2009 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	12/13/2010 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	07/31/2013 .	.0460 *	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	01/13/2014 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	06/30/2014 .	.0610 *	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	07/07/2014 .	.0400 *	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	10/29/2014 .	.0330 *	.0500	.0200	.0200	UG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER

NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19940101 THRU 20150116
REPORT OF COUNTY: 10 FRESNO

SYSTEM NO: 1010039 NAME: CARUTHERS COMM SERV DIST COUNTY: FRESNO
SOURCE NO: 004 NAME: WELL 04 PSCODE: 1010039-004 CLASS: CMGA STATUS: AU

GROUP IDENTIFICATION SAMPLE
CONSTITUENT IDENTIFICATION DATE RESULT * MCL DLR TRIGGER UNIT

S2 REGULATED SOC

CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
38761 DIBROMOCHLOROPROPANE (DBCP)	02/01/1994	.0100 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	02/06/1995 <	.0000	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	05/15/1995	.9900 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	06/13/1995	.0600 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	09/07/1995 <	.0000	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	12/20/1995 <	.0000	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	03/19/1996 <	.0000	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	03/11/1998 <	.0000	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	06/15/1999	.0470 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	03/22/2000 <	.0000	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	04/02/2001 <	.5000 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	04/08/2004 .	.1200 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	12/12/2005 <	.0000	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	07/12/2006	.0150 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	12/10/2007 <	.0000	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	12/23/2008 <	.0000	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	11/16/2009	.0300 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	12/13/2010 <	.0000	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	07/31/2013 <	.0000	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	01/13/2014 <	.0000	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	04/22/2014 .	.1500 *	.2000	.0100	.0100	UG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DRINKING WATER ANALYSES RESULTS REPORT
 ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
 FOR SAMPLE DATE RANGE OF 19940101 THRU 20150116
 REPORT OF COUNTY: 10 FRESNO

SYSTEM NO: 1010039 NAME: CARUTHERS COMM SERV DIST
 SOURCE NO: 004 NAME: WELL 04

COUNTY: FRESNO
 PSCODE: 1010039-004 CLASS: CMGA STATUS: AU

GROUP IDENTIFICATION CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
38761 DIBROMOCHLOROPROPANE (DBCP)	07/07/2014 .	.0100 *	.2000	.0100	.0100	UG/L
38761 DIBROMOCHLOROPROPANE (DBCP)	10/29/2014 .	.6500 *	.2000	.0100	.0100	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	02/06/1995 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	05/15/1995	.1700 *	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	09/07/1995 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	03/11/1998 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	03/22/2000 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	04/02/2001 <	.5000 *	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	04/08/2004 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	12/12/2005 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	07/12/2006 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	12/10/2007 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	12/23/2008 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	11/16/2009 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	12/13/2010 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	07/31/2013 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	01/13/2014 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	04/22/2014 .	.0620 *	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	07/07/2014 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	10/29/2014 .	.2300 *	.0500	.0200	.0200	UG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
 NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DRINKING WATER ANALYSES RESULTS REPORT
 ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
 FOR SAMPLE DATE RANGE OF 19940101 THRU 20150116
 REPORT OF COUNTY: 10 FRESNO

SYSTEM NO: 1010039 NAME: CARUTHERS COMM SERV DIST
 SOURCE NO: 005 NAME: WELL 05

COUNTY: FRESNO
 PSCODE: 1010039-005 CLASS: CMGA STATUS: AU

GROUP IDENTIFICATION	CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT *	MCL	DLR	TRIGGER	UNIT

S2	REGULATED SOC						
	38761 DIBROMOCHLOROPROPANE (DBCP)	02/22/2002	< .5000 *	.2000	.0100	.0100	UG/L
	38761 DIBROMOCHLOROPROPANE (DBCP)	02/23/2005	< .0000	.2000	.0100	.0100	UG/L
	38761 DIBROMOCHLOROPROPANE (DBCP)	07/12/2006	< .0000	.2000	.0100	.0100	UG/L
	38761 DIBROMOCHLOROPROPANE (DBCP)	12/10/2007	< .0000	.2000	.0100	.0100	UG/L
	38761 DIBROMOCHLOROPROPANE (DBCP)	11/16/2009	< .0000	.2000	.0100	.0100	UG/L
	38761 DIBROMOCHLOROPROPANE (DBCP)	09/08/2010	.0220 *	.2000	.0100	.0100	UG/L
	38761 DIBROMOCHLOROPROPANE (DBCP)	07/31/2013	.0190 *	.2000	.0100	.0100	UG/L
	38761 DIBROMOCHLOROPROPANE (DBCP)	10/28/2013	.0170 *	.2000	.0100	.0100	UG/L
	38761 DIBROMOCHLOROPROPANE (DBCP)	01/13/2014	< .0000	.2000	.0100	.0100	UG/L
	38761 DIBROMOCHLOROPROPANE (DBCP)	04/22/2014	.0240 *	.2000	.0100	.0100	UG/L
	38761 DIBROMOCHLOROPROPANE (DBCP)	09/25/2014	.0120 *	.2000	.0100	.0100	UG/L
	38761 DIBROMOCHLOROPROPANE (DBCP)	10/29/2014	.0430 *	.2000	.0100	.0100	UG/L
	77651 ETHYLENE DIBROMIDE (EDB)	02/22/2002	< .5000 *	.0500	.0200	.0200	UG/L
	77651 ETHYLENE DIBROMIDE (EDB)	02/23/2005	< .0000	.0500	.0200	.0200	UG/L
	77651 ETHYLENE DIBROMIDE (EDB)	07/12/2006	< .0000	.0500	.0200	.0200	UG/L
	77651 ETHYLENE DIBROMIDE (EDB)	12/10/2007	< .0000	.0500	.0200	.0200	UG/L
	77651 ETHYLENE DIBROMIDE (EDB)	11/16/2009	< .0000	.0500	.0200	.0200	UG/L
	77651 ETHYLENE DIBROMIDE (EDB)	09/08/2010	< .0000	.0500	.0200	.0200	UG/L
	77651 ETHYLENE DIBROMIDE (EDB)	07/31/2013	< .0000	.0500	.0200	.0200	UG/L
	77651 ETHYLENE DIBROMIDE (EDB)	10/28/2013	< .0000	.0500	.0200	.0200	UG/L
	77651 ETHYLENE DIBROMIDE (EDB)	01/13/2014	< .0000	.0500	.0200	.0200	UG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
 NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DATE: 01/16/15
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

PAGE: 2

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19940101 THRU 20150116
REPORT OF COUNTY: 10 FRESNO

SYSTEM NO: 1010039 NAME: CARUTHERS COMM SERV DIST
SOURCE NO: 005 NAME: WELL 05

COUNTY: FRESNO
PSCODE: 1010039-005

CLASS: CMGA STATUS: AU

GROUP IDENTIFICATION CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
77651 ETHYLENE DIBROMIDE (EDB)	04/22/2014 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	09/25/2014 <	.0000	.0500	.0200	.0200	UG/L
77651 ETHYLENE DIBROMIDE (EDB)	10/29/2014 <	.0000	.0500	.0200	.0200	UG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

**Caruthers CSD Has Levels of Ethylene Dibromide (EDB)
Above Drinking Water Standards**

Water produced by our water system failed a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what you should do, what happened, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Results of water samples collected over the last year show an average arsenic concentration of _____ in Well 04. This is above the standard or maximum contaminant level (MCL) of 0.05 ug/L.

What should I do?

- **You do not need to use an alternative (e.g. , bottled) water supply.** However, if you have specific health concerns, consult your doctor.
- *This is not an emergency. If it had been, you would have been notified immediately. However, some people who use water containing EDB in excess of the MCL over many years may experience liver, stomach, reproductive system, or kidney problems, and may have an increased risk of getting cancer.*
- If you have other health issues concerning the consumption of this water, you may wish to consult a doctor.

What happened? What was done?

[Describe corrective action.] _____
 We anticipate resolving the problem within [estimated time frame] _____.
 For more information, please contact _____ [insert name of contact] at
 _____ [insert phone number] or at the following mailing address:
 _____ [insert mailing address].

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS** (including nursing homes and care facilities): Must notify tenants.
- **BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS:** Must notify employees of businesses located on the property.

This notice is being sent to you by
Caruthers CSD – State Water System No. 1010039

Date distributed _____.

Certification of Completion of Public Notification

This form, when completed and returned to the Division of Drinking Water - Fresno District (265 W. Bullard Ave. #101, Fresno, CA 93704 or fax to 559-447-3304), serves as certification that public notification to water users was completed as required by Title 22, California Code of Regulations, Sections 64463-64465.

Public Water System Name: Caruthers CSD

Public Water System No.: 1010039

Public notification for **failure to comply with the** EDB MCL **for the** quarter **of 20** was performed by the following method(s) (check and complete those that apply):

- The notice was mailed to users on: _____
 A copy of the notice is attached.
- The notice was hand delivered to water customers on: _____
 A copy of the notice is attached.
- The notice was published in the local newspaper on: _____
 A copy of the newspaper notice is attached.
- The notice was published in conspicuous places on: _____
 A copy of the notice is attached.
 A list of locations the notice was posted is attached.
- The notice was delivered to community organizations on: _____
 A copy of the notice is attached.
 A list of community organizations the notice was delivered to is attached.

I hereby certify that the above information is factual.

 Printed Name

 Title

 Signature

 Date

Disclosure: Be advised that Section 116725 and 116730 of the California Health and Safety Code state that any person who knowingly makes any false statement on any report or document submitted for the purpose of compliance with the attached order may be liable for a civil penalty not to exceed five thousand dollars (\$5,000) for separate violation each day that the violation continues. In addition, the violators may be prosecuted in criminal court and, upon conviction, be punished by a fine of not more than \$25,000 for each day of violation, or be imprisoned in the county jail not to exceed one year, or by both the fine and imprisonment.

Due to the Division of Drinking Water within 10 days of issuance of notice to customers
 System Number: 1010039
 Enforcement Action No. 03-23-15R-004

Quarterly Progress Report

Water System: Caruthers CSD	Water System No.: 1010039
Compliance Order No.: 03-23-15R-004	Violation: EDB MCL
Calendar Quarter:	Date Prepared:

This form should be prepared and signed by Water System personnel with appropriate authority to implement the directives of the Compliance Order and the Corrective Action Plan. Please attach additional sheets as necessary. The quarterly progress report must be submitted by the 10th day of each subsequent quarter, to the Division of Drinking Water, Fresno District Office.

Summary of Compliance Plan:

Tasks completed in the reporting quarter:

Tasks remaining to complete:

Anticipate compliance date:

Name

Signature

Title

Date

