



EDMUND G. BROWN JR.
GOVERNOR



MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board
Division of Drinking Water

February 6, 2015
Certified Mail/Return
7012 3460 0003 1113 1625

Capay Joint Union Elementary School
7504 Cutting Ave.
Orland, CA 95963

Attention: Jim Scribner, Superintendent / Principal

Subject: Public Water System No. 1100527 – Citation No. 21-15C-009 for Lead and Copper Rule monitoring violation.

It has come to our attention that the Capay Joint Union Elementary School water system has failed to monitor and report triennial lead and copper samples since 2004, according to the Lead and Copper Rule (LCR). Consequently, the Division of Drinking Water has issued the enclosed Citation for Noncompliance (Citation) to the water system. The enclosed Citation includes directives for corrective action and public notification.

Section 116577 of the California Safe Drinking Water Act provides for the division to be reimbursed by the public water system for costs incurred for preparing and issuing a citation. The billing rate is approximately \$128 per hour. At this time, we have spent approximately one hour preparing this violation. You will receive a bill for these costs, typically by September 1st, from the Sacramento office.

If you have any questions please call Paul Rowe at (530) 224-4866 or contact me directly at (530) 224-4861.

A handwritten signature in black ink that reads "R. Crenshaw".

Reese B. Crenshaw, P.E.
Valley District Engineer
DRINKING WATER FIELD
OPERATIONS BRANCH

Enclosures

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26

Citation No. 21-15C-009

STATE WATER RESOURCES CONTROL BOARD
DIVISION OF DRINKING WATER

Public Water System: Capay Joint Union Elementary School
Water System No.: 1100527

To: Capay Joint Union Elementary School
Attn: Jim Scribner, Superintendent / Principal
7504 Cutting Ave.
Orland, CA 95963

Issued: February 6, 2015
VIA CERTIFIED MAIL

CITATION FOR NONCOMPLIANCE
With Title 22 California Code of Regulations
Sections 64675

Section 116650 of the California Health and Safety Code (CHSC) authorizes the issuance of a citation for failure to comply with a requirement of the California Safe Drinking Water Act (CHSC, Division 104, Part 12, Chapter 4, commencing with Section 116270), or any regulation, standard, permit, or order issued thereunder.

1 The State Water Resources Control Board (hereinafter "Board"), acting by and
2 through its Division of Drinking Water (hereinafter "Division") and the Deputy Director
3 for the Division, hereby issues a citation to Capay Joint Union Elementary School for
4 failure to comply with Section 64675.5, Title 22, of the California Code of Regulations
5 (CCR).

6
7 **APPLICABLE AUTHORITIES**

8 Section 116650 of the CHSC states:

9
10 *(a) If the division determines that a public water system is in violation of*
11 *this chapter or any regulation, permit, standard, citation, or order*
12 *issued or adopted thereunder, the division may issue a citation to the*
13 *public water system. The citation shall be served upon the public*
14 *water system personally or by certified mail. Service shall be deemed*
15 *effective as of the date of personal service or the date of receipt of*
16 *the certified mail. If a person to whom a citation is directed refuses to*
17 *accept delivery of the certified mail, the date of service shall be*
18 *deemed to be the date of mailing.*

19
20 *(b) Each citation shall be in writing and shall describe the nature of the*
21 *violation or violations, including a reference to the statutory provision,*
22 *standard, order, citation, permit, or regulation alleged to have been*
23 *violated.*

24
25 *(c) A citation may specify a date for elimination or correction of the*
26 *condition constituting the violation.*

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26

(d) A citation may include the assessment of a penalty as specified in subdivision (e).

(e) The division may assess a penalty in an amount not to exceed one thousand dollars (\$1,000) per day for each day that a violation occurred, and for each day that a violation continues to occur. A separate penalty may be assessed for each violation.

Section 64675.5, Title 22, of the CCR states in relevant part:

(a) A system shall conduct standard tap sampling for two consecutive periods; thereafter, tap sampling frequency may be reduced pursuant to section 64675 (General Requirements for Tap Sampling for Lead and Copper) as follows:

(1) If a system has 90th percentile levels that do not exceed 0.005 mg/L for lead and 0.65 mg/L for copper for two consecutive periods, it may reduce the sampling to once every three years at the reduced number of sites.

STATEMENT OF FACTS

The Capay Joint Union Elementary School (hereinafter "Water System") is classified as a non-transient non-community water system serving approximately 172 people.

1 Because the Water System qualified for a reduced lead and copper sampling
2 frequency in 2004, it was required to collect five (5) samples every three years
3 according to Table 64675-A and section 64675.5 of Title 22. The Water System has
4 failed to collect triennial lead and copper samples since 2004.

5
6 **DETERMINATIONS**

7 The Division has determined that the Water System violated Section 64675.5(a)(1),
8 Title 22, of the CCR, in that the Water System has failed to collect triennial samples
9 since 2004.

10
11 **DIRECTIVES**

12 The Water System is hereby directed to take the following actions:

- 13
14 1. Comply with Section 64675.5, Title 22, of the CCR in all future monitoring
15 periods.
- 16
17 2. Beginning in 2015, conduct **annual** lead and copper monitoring from
18 customer's taps in June, July, August, **or** September, **until the year 2019**.
19 Thereafter, triennial sampling may begin. Samples shall be collected in
20 accordance with the Lead and Copper Rule sampling per Title 22, Section
21 64677. The analytical results must be reported to the Division by the 10th day of
22 the month following the month in which the analyses were completed.
23
24
25 3. The Water System shall provide public notification (by inclusion in the **2014**
26 **Consumer Confidence Report**) of the failure to sample lead and copper, as
27 required by the Lead and Copper regulations.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

All documents required by this Citation to be submitted to the Division shall be submitted to the following address:

Reese B. Crenshaw, P. E.
Valley District Engineer
Drinking Water Field Operations
Division of Drinking Water
State Water Resources Control Board
364 Knollcrest Drive, Suite 101
Redding, CA 96002
(530) 224-4800

Nothing in this Citation relieves the Water System of its obligation to meet the requirements of Health and Safety Code, Division 104, Part 12, Chapter 4 (California Safe Drinking Water Act), or any regulation, permit, standard or order issued or adopted thereunder.

The Division reserves the right to make such modifications to this Citation, as it may deem necessary to protect public health and safety. Such modifications may be issued as amendments to this Citation and shall be effective upon issuance.

FURTHER ENFORCEMENT ACTION

The California SDWA authorizes the Board to: issue citation with assessment of administrative penalties to a public water system for violation or continued violation of the requirements of the California SDWA or any permit, regulation, permit or order issued or adopted thereunder including, but not limited to, failure to correct a violation

1 identified in a citation or compliance order. The California SDWA also authorizes the
2 Board to take action to suspend or revoke a permit that has been issued to a public
3 water system if the system has violated applicable law or regulations or has failed to
4 comply with an order of the Board; and to petition the superior court to take various
5 enforcement measures against a public water system that has failed to comply with
6 violates an order of the Board. The Board does not waive any further enforcement
7 action by issuance of this citation.

8

9 **PARTIES BOUND**

10 This Citation shall apply to and be binding upon the System, its officers, directors,
11 agents, employees, contractors, successors, and assignees.

12

13 **SEVERABILITY**

14 The directives of this Citation are severable, and Capay Joint Union Elementary
15 School shall comply with each and every provision thereof notwithstanding the
16 effectiveness of any other provision.

17

18

19 R. Crenshaw
20 Reese B. Crenshaw, P.E., District Engineer
21 Valley District
22 Drinking Water Field Operations Branch

2/5/15
Date

23

