



EDMUND G. BROWN JR.
GOVERNOR

MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board
Division of Drinking Water

June 17, 2015

Steve Perez, General Manager
Rosamond Community Services District
3179 35th Street West
Rosamond, CA 93560

RE: ROSAMOND COMMUNITY SERVICES DISTRICT- WATER SYSTEM NO.1510018, COMPLIANCE ORDER FOR VIOLATION OF MAXIMUM CONTAMINANT LEVEL (MCL) FOR HEXAVALENT CHROMIUM

Dear Mr. Perez:

Enclosed is Compliance Order No. 03-19-15R-013 that the State Water Resources Control Board-Division of Drinking Water (Division) is issuing to the Rosamond Community Services District Water System (hereinafter Water System) for a violation of the California Safe Drinking Water Act. The Water System has been serving water to consumers that fails the primary maximum contaminant level (MCL) for hexavalent chromium of 0.010 milligrams-per-liter. As discussed in the compliance order, the Water System shall develop and implement a plan to resolve the MCL violation and ensure that water served to consumers meets all drinking water standards.

Please note that a written response to the Compliance Order is required by September 30, 2015 containing a plan and time schedule to correct the water quality problem as described in the Compliance Order. Failure to comply with deadlines and orders specified in the Compliance Order may result in further enforcement action by the Division. Until the Division determines that the Water System is in compliance with the hexavalent chromium MCL, you must continue to provide quarterly public notification for hexavalent chromium and also conduct quarterly monitoring of Well 05, Well 08, and Well 09 for hexavalent chromium. After providing quarterly public notification, a copy of the public notice along with a completed *Certification of Completion of Public Notification* form should be submitted to the State Water Resources Control Board, Division of Drinking Water Office at 4925 Commerce Drive, Suite 120, Bakersfield, CA 93309. Your written response to the compliance order should be also submitted to Bakersfield office. Failure to comply will result in additional enforcement action by the Division.

If you have any questions regarding this matter, please contact me at (661) 335-7318 or Carl Carlucci, Supervising Sanitary Engineer at (559) 447-3132.

Sincerely,

Jaswinder S. Dhaliwal, P.E.
Senior Sanitary Engineer, Tehachapi District
Southern California Branch
DRINKING WATER FIELD OPERATIONS

Enclosure: Compliance Order No. 03-19-15R-013

CC: Kern County Department of Environment Health

FELICIA MARCUS, CHAIR | THOMAS HOWARD, EXECUTIVE DIRECTOR

1
2 CALIFORNIA
3 STATE WATER RESOURCES CONTROL BOARD
4 DIVISION OF DRINKING WATER

5 TO: Rosamond Community Services District Water System; System No. 1510018
6 ATTN: Steve Perez, General Manager
7 Rosamond Community Services District
8 3179 35th Street West
9 Rosamond, CA 93560

10 CERTIFIED MAIL

11 COMPLIANCE ORDER NO. 03-19-15R-013
12 FOR
13 VIOLATION OF HEALTH AND SAFETY CODE SECTION 116655 (a)(1)
14 AND THE PRIMARY DRINKING WATER STANDARD FOR HEXAVALENT CHROMIUM
15 Dated June 17, 2015

16 The State Water Resources Control Board (hereinafter "Board"), acting by and through its
17 Division of Drinking Water (hereinafter "Division") and the Deputy Director for the Division
18 (hereinafter "Deputy Director"), hereby issues this compliance order (hereinafter "Order")
19 pursuant to Section 116655 of the California Health and Safety Code (hereinafter "CHSC") to
20 Rosamond Community Services District for violation of CHSC section 116555(a)(1) and Title
21 22, California Code of Regulations (hereinafter "CCR"), Section 64431.

22
23 APPLICABLE AUTHORITIES

24 **CHSC, Section 116555(a)(1) states in relevant part:**

- 25 (a) Any person who owns a public water system shall ensure that the system does all of the
26 following:
27 (1) Complies with primary and secondary drinking water standards.

CHSC, Section 116655 states in relevant part:

(a) Whenever the department determines that any person has violated or is violating this chapter, or any permit, regulation, or standard issued or adopted pursuant to this chapter, the director may issue an order doing any of the following:

- (1) Directing compliance forthwith.
- (2) Directing compliance in accordance with a time schedule set by the department.
- (3) Directing that appropriate preventive action be taken in the case of a threatened violation.

(b) An order issued pursuant to this section may include, but shall not be limited to, any or all of the following requirements:

- (1) That the existing plant, works, or system be repaired, altered, or added to.
- (2) That purification or treatment works be installed.
- (3) That the source of the water supply be changed.
- (4) That no additional service connection be made to the system.
- (5) That the water supply, the plant, or the system be monitored.
- (6) That a report on the condition and operation of the plant, works, system, or water supply be submitted to the department.

Title 22, CCR, Section 64431 (hereinafter “Section 64431”), states in relevant part:

Public water systems shall comply with the primary MCLs in table 64431-A as specified in this article.

**Table 64431-A
Maximum Contaminant Levels
Inorganic Chemicals**

<i>Chemical</i>	<i>Maximum Contaminant Level, mg/L</i>
Aluminum	1.
Antimony	0.006
Arsenic	0.010
Asbestos	7 MFL*
Barium	1.
<i>Chemical</i>	<i>Maximum Contaminant Level, mg/L</i>
Beryllium	0.004
Cadmium	0.005
Chromium	0.05
Cyanide	0.15
Fluoride	2.0
Hexavalent chromium	0.010
Mercury	0.002
Nickel	0.1
Nitrate (as NO ₃)	45.
Nitrate+Nitrite (sum as nitrogen)	10.

<i>Chemical</i>	<i>Maximum Contaminant Level, mg/L</i>
Nitrite (as nitrogen)	1.
Perchlorate	0.006
Selenium	0.05
Thallium	0.002

* MFL=million fibers per liter; MCL for fibers exceeding 10 um in length.

Title 22, CCR Section 64432 (hereinafter "Section 64432") provides in relevant part:

Section 64432

...

(g) If the level of any inorganic chemical, except for nitrate, nitrite, nitrate plus nitrite, or perchlorate, exceeds the MCL, the water supplier shall do one of the following:

(1) Inform the Department within 48 hours and monitor quarterly beginning in the next quarter after the exceedance occurred; or

(2) Inform the Department within seven days from the receipt of the analysis and, as confirmation, collect one additional sample within 14 days from receipt of the analysis. If the average of the two samples collected exceeds the MCL, this information shall be reported to the Department within 48 hours and the water supplier shall monitor quarterly beginning in the next quarter after the exceedance occurred.

(h) If the concentration of an inorganic chemical exceeds ten times the MCL, within 48 hours of receipt of the result the water supplier shall notify the Department and resample as confirmation. The water supplier shall notify the Department of the result(s) of the confirmation sample(s) within 24 hours of receipt of the confirmation result(s).

(1) If the average concentration of the original and confirmation sample(s) is less than or equal to ten times the MCL, the water supplier shall monitor quarterly beginning in the quarter following the quarter in which the exceedance occurred.

(2) If the average concentration of the original and confirmation sample(s) exceeds ten times the MCL, the water supplier shall, if directed by the Department;

(A) Immediately discontinue use of the contaminated water source; and

(B) Not return the source to service without written approval from the Department.

(i) Compliance with the MCLs shall be determined by a running annual average; if any one sample would cause the annual average to exceed the MCL, the system is immediately in violation. If a system takes more than one sample in a quarter, the average of all the results for that quarter shall be used when calculating the running annual average. If a system fails to

1
2 complete four consecutive quarters of monitoring, the running annual average shall be based
3 on an average of the available data.

4 **STATEMENT OF FACTS**

5 The Division is informed by the Rosamond Community Services District Water System
6 (hereinafter "Water System") and believes that the Water System is a community water
7 system located in Rosamond, Kern County that supplies water for domestic purposes to
8 approximately 16,618 individuals through approximately 4,748 service connections. The
9 Water System operates under Domestic Water Supply Permit No. 03-19-02P-006, issued by
10 the California Department of Health Services on August 6, 2002. The Water System is a
11 community public water system as defined in CHSC, section 116275.
12

13
14 The Water System utilizes three groundwater wells (Well 05; PS Code: 1510018-006, Well 08;
15 PS Code: 1510018-009, and Well 09; PS Code: 1510018-002). The Water System also has
16 an intertie with Antelope Valley East Kern Water Agency to purchase treated surface water
17 (PS Code: 1510018-010). Title 22, CCR, Division 4, Chapter 15, Article 4, establishes primary
18 drinking water standards and monitoring and reporting requirements for inorganic
19 constituents. Community and nontransient noncommunity water systems must comply with
20 the maximum contaminant level for hexavalent chromium of 0.010 mg/L, as established in
21 Title 22 CCR Section 64431. The State of California adopted a primary MCL for hexavalent
22 chromium of 0.010 mg/L, which became effective July 1, 2014. As part of the MCL
23 implementation, the Water System was requested by the Division to complete initial
24 monitoring for hexavalent chromium monitoring by collecting samples from Well Nos. 05, 08,
25 and 09 between July 1, 2014 and January 1, 2015, and have the samples analyzed for
26
27

1
2 hexavalent chromium by using an approved method and with a detection limit of 0.001 mg/L
3 for purposes of reporting (DLR).
4

5 By a letter dated October 21, 2014, the Water System requested grandfathering of hexavalent
6 chromium results for samples collected between July 1, 2012 and July 1, 2014. A copy of the
7 letter is provided as part of **Attachment A**. The 2013 hexavalent chromium results that have
8 been submitted to the Division are summarized in the Table 1 below:
9

10 **Table 1: (2013) Hexavalent Chromium Monitoring Results**

Sample Date	Well 05 (1510018-006)	Well 08 (1510018-009)	Well 09 (1510018-002)
May 14, 2013	No Sample	0.012 mg/L	0.016 mg/L
October 22, 2013	0.011 mg/L	0.013 mg/L	0.014 mg/L

14 Samples collected on September 16, 2014, from Well 05, Well 08, and Well 09 showed
15 hexavalent chromium concentrations of 0.012, 0.012, 0.016 mg/L, respectively. Therefore, in
16 accordance with Section 64431 (g), the Water System was required to begin quarterly
17 hexavalent chromium monitoring of the wells, unless it chose to submit additional samples,
18 which it did not do. Section 64431 (i) provides that compliance with the hexavalent chromium
19 MCL is based on a "running annual average" (RAA) of the quarterly monitoring samples,
20 computed each quarter. Further, Section 64431 (i) states: "if any one sample would cause the
21 annual average to exceed the MCL, the system is immediately in violation."
22

23
24 Based on the results reported to the Division, the Water System collected quarterly hexavalent
25 chromium samples from Well Nos. 05, 08, and 09 on September 16, 2014, February 17, 2015,
26 and May 19, 2015 with some exceptions. The Water System failed to collect hexavalent
27

1
2 chromium samples from Well Nos. 05, 08, and 09 during the fourth quarter of 2014. A
3 summary of the Water System's quarterly hexavalent chromium monitoring for 2014 and 2015
4 is presented in Table 2 below. All results are as reported to the Division by the laboratory that
5 performed the analysis. By a letter dated February 12, 2015 (**Attachment A**), the Division
6 notified the Water System of the monitoring and reporting violation for the 4th quarter of 2014
7 and directed the Water System to continue quarterly hexavalent chromium monitoring of Well
8 Nos. 05, 08, and 09.
9

10 **Table 2: (2014 and 2015) Quarterly Hexavalent Chromium Monitoring Results**

11 Sample Quarter	Well 05 (1510018-006)	Well 08 (1510018-009)	Well 09 (1510018-002)
12 09/16/14 (3 rd Qtr. 2014)	0.012 mg/L	0.012 mg/L	0.016 mg/L
13 (4 th Qtr. 2014)	No Sample M & R Violation	No Sample M & R Violation	No Sample M & R Violation
14 02/17/15 (1 st Qtr. 2015)	No Sample Well Offline	No Sample Well Offline	0.015 mg/L
15 05/19/15 (2 nd Qtr. 2015)	0.012 mg/L	No Sample	0.015 mg/L
16 2nd Qtr. 2015 Running Annual Average (RAA)	0.012 mg/L	0.012 mg/L	0.015 mg/L

17
18 The 2nd quarter of 2015 RAA for Well Nos. 05, 08, and 09 calculated as the 3rd and 4th
19 quarters of 2014, and the 1st and 2nd quarters of 2015 sample results averaged over a four
20 quarter period, is 0.012, 0.012, and 0.015 mg/L, respectively, which exceeds the hexavalent
21 chromium MCL of 0.010 mg/L. The Division has determined that Well Nos. 05, 08, and 09 are
22 in violation of the hexavalent chromium MCL of 0.010 mg/L. Results of samples taken from
23 water produced from Well Nos. 05, 08, and 09 since September 16, 2014 (3rd quarter of
24 2014), show the RAAs for hexavalent chromium in said Wells continue to exceed the
25 hexavalent chromium MCL. By a letter dated June 12, 2015, the Division notified the Water
26 System of its determination of the violation of the hexavalent chromium MCL and directed the
27

1
2 Water System to continue quarterly monitoring for hexavalent chromium, provide Tier 2 public
3 notification to the customers, and submit proof of notification to the Division. A copy of the
4 letter is provided as **Attachment B**.

5
6 **DETERMINATIONS**

7 Based on the above Statement of Facts, the Division has determined that the Water System
8 has violated CHSC, Section 116555 and Section 64431 in that the water produced by Well
9 Nos. 05, 08, and 09, during the 2nd quarter of 2015, exceeded the hexavalent chromium MCL
10 as shown in Table 2 above, and further has determined that said violation has continued from
11 September 16, 2014 (3rd quarter of 2014) and through the date of this Order.
12

13
14 **DIRECTIVES**

15 The Rosamond Community Services District Water System is hereby directed to take the
16 following actions:

- 17
- 18 1. Cease and Desist from failing to comply with Sections 116555(a)(1) and 116555(a)(3)
19 of the CHSC and Section 64431 of the CCR and remain in compliance by ensuring
20 that the Water System's consumers are provided with a reliable and adequate supply
21 of pure, wholesome, healthful, and potable water, in compliance with all applicable
22 primary drinking water standards.
23
 - 24 2. On or before July 10, 2015, submit a written response to the Division indicating its
25 agreement to comply with the directives of this Order and with the Corrective Action
26 Plan addressed herein.
27

- 1
2
3 3. Commencing on the date of service of this Order, provide quarterly public notification
4 in accordance with **Attachment C**, hereto, of Water System's failure to meet the
5 hexavalent chromium MCL during any calendar quarter that the four-quarter running
6 annual average exceeds the MCL.
7
- 8
9 4. Commencing on the date of service of this Order, submit proof of each public
10 notification conducted in compliance with Directive No. 3, herein above, within 10
11 days following each such notification, using the form provided as **Attachment D**,
12 hereto.
13
- 14 5. Commencing on the date of service of this Order collect quarterly samples for
15 hexavalent chromium from Well Nos. 05, 08, and 09, as required by Section 64432(g),
16 and ensure that the analytical results are reported to the Division electronically by the
17 analyzing laboratory no later than the 10th day following the month in which the
18 analysis was completed.
19
- 20 6. Prepare for Division approval a Corrective Action Plan identifying improvements to the
21 water system designed to correct the water quality problem (violation of the hexavalent
22 chromium MCL) and ensure that the Water System delivers water to consumers that
23 meets primary drinking water standards. The plan shall include a time schedule for
24 completion of each of the phases of the project such as design, construction, and
25 startup, and a date as of which the Water System will be in compliance with the
26 hexavalent chromium MCL.
27

- 1
- 2
- 3 7. On or before September 30, 2015, present the Corrective Action Plan required under
- 4 Directive No. 6, above, to the Division in person at the Division's offices located at
- 5 4925 Commerce Drive, Suite 120, Bakersfield, CA 93309.
- 6
- 7
- 8 8. Timely perform the Division approved Corrective Action Plan and each and every
- 9 element of said plan according to the time schedule set forth therein.
- 10
- 11 9. On or before January 1, 2016, and every three months thereafter, submit a report to
- 12 the Division in the form provided as **Attachment E**, hereto, showing actions taken
- 13 during the previous calendar three months to comply with the Corrective Action Plan.
- 14
- 15 10. Not later than ten (10) days following the date of compliance with the hexavalent
- 16 chromium MCL, demonstrate to the Division that the water delivered by Water System
- 17 complies with the hexavalent chromium MCL.
- 18
- 19 11. Notify the Division in writing no later than five (5) days prior to the deadline for
- 20 performance of any Directive set forth herein if Water System anticipates it will not
- 21 timely meet such performance deadline.
- 22

23 All submittals required by this Order shall be addressed to:

24 Jaswinder S. Dhaliwal, P.E., Senior Sanitary Engineer
25 State Water Resources Control Board
26 Division of Drinking Water, Tehachapi District
4925 Commerce Drive, Suite 120
Bakersfield, CA 93309

1
2
3 As used in this Order, the date of issuance shall be the date of this Order; and the date of
4 service shall be the date of service of this Order, personal or by certified mail, on the Water
5 System.

6
7 The Division reserves the right to make such modifications to this Order and/or to issue such
8 further order(s) as it may deem necessary to protect public health and safety. Such
9 modifications may be issued as amendments to this Order and shall be deemed effective
10 upon issuance.

11
12 Nothing in this Order relieves Water System of its obligation to meet the requirements of the
13 California SDWA, or any regulation, standard, permit or order issued thereunder.

14
15 **PARTIES BOUND**

16 This Order shall apply to and be binding upon Water System, its owners, shareholders,
17 officers, directors, agents, employees, contractors, successors, and assignees.

18
19
20 **SEVERABILITY**

21 The Directives of this Order are severable, and Water System shall comply with each and
22 every provision hereof, notwithstanding the effectiveness of any other provision.

FURTHER ENFORCEMENT ACTION

The California SDWA authorizes the Board to: issue a citation with assessment of administrative penalties to a public water system for violation or continued violation of the requirements of the California SDWA or any regulation, permit, standard, citation, or order issued or adopted thereunder including, but not limited to, failure to correct a violation identified in a citation or compliance order. The California SDWA also authorizes the Board to take action to suspend or revoke a permit that has been issued to a public water system if the public water system has violated applicable law or regulations or has failed to comply with an order of the Board; and to petition the superior court to take various enforcement measures against a public water system that has failed to comply with an order of the Board. The Board does not waive any further enforcement action by issuance of this Order.


Carl L. Carlucci, P.E., Chief
Central California Section
State Water Resources Control Board
Division of Drinking Water

6-17-2015
Date

Certified Mail No. 7014 3490 0001 7868 8156



Attachments

- Attachment A: Letter dated February 12, 2015 from the Division
- Attachment B: Letter dated June 12, 2015 from the Division
- Attachment C: Hexavalent Chromium Public Notification Template
- Attachment D: Certification of Public Notification Template
- Attachment E: Quarterly Progress Report Template

CC: Kern County Environmental Health Services Department (w/o attachments)
Board of Directors, Rosamond Community Services District
Juan DelaRosa, Water Quality Supervisor, Rosamond Community Services District

Attachment A

Letter dated February 12, 2015 from the Division



EDUARD G. BROWN JR.
GOVERNOR



MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board
Division of Drinking Water

February 12, 2015
System No. 1510018

Steve Perez, General Manager
Rosamond Community Services District
3179 35th Street West
Rosamond, CA 93560

RE: QUARTERLY MONITORING FOR HEXAVALENT CHROMIUM FOR ROSAMOND COMMUNITY SERVICES DISTRICT WATER SYSTEM

Dear Mr. Perez:

On July 1, 2014, the State of California, State Water Resources Control Board, Division of Drinking Water (hereinafter Division) adopted a maximum contaminant level (MCL) for hexavalent chromium of 0.010 mg/L (milligrams per liter) or 10 µg/L (micrograms per liter). Under the new hexavalent chromium MCL regulation, compliance with the 0.010 mg/L MCL is based on the running annual average (RAA) of the monitoring results for four consecutive quarters. if at any time, the average for fewer than four quarters is such that the MCL is certain to be exceeded regardless of additional sampling results; the source is immediately determined to be out of compliance.

By a letter dated October 21, 2014, Rosamond Community Services District (hereinafter RCSD) requested grandfathering of hexavalent chromium results for samples collected between July 1, 2012 and July 1, 2014. A copy of the letter is **enclosed**. The hexavalent chromium results that have been submitted to the Division are summarized in the table below:

Sample Date	Well 09 (PS Code 1510018-002)	Well 05 (PS Code 1510018-006)	Well 08 (PS Code 1510018-009)
May 14, 2013	16 ug/L	No Sample Collected	12 ug/L
October 22, 2013	14 ug/L	11 ug/L	13 ug/L
September 16, 2014	16 ug/L	12 ug/L	12 ug/L

A review of the water quality data for the three RCSD Well Nos. 05, 08, and 09 shows that all samples collected on May 14, 2013, October 22, 2013, and September 16, 2014, from each well showed hexavalent chromium results exceeding the hexavalent chromium MCL. A report from the Division's water quality database, showing these results is also **enclosed**. It is noted that RCSD failed to collect hexavalent chromium samples from Well Nos. 05, 08, and 09 during the fourth quarter of 2014, after submitting a request to the Division for grandfathering of the hexavalent chromium samples collected between July 1, 2012 and July 1, 2014. This is considered a monitoring and reporting violation.


As shown in the above table, all hexavalent chromium results exceed the hexavalent chromium MCL of 0.010 mg/L; therefore, monitoring for hexavalent chromium for Well 05, Well 08, and Well 09 shall be conducted quarterly for four consecutive quarters, starting with the first quarter of 2015. Failure to conduct the quarterly hexavalent chromium monitoring will constitute a monitoring and reporting violation, resulting in the RCSD receiving an enforcement letter from the Division. After conducting four consecutive quarters of hexavalent monitoring, RCSD may request the Division to re-evaluate the future monitoring frequency for hexavalent chromium, unless the Division determines that RCSD is in violation of the hexavalent chromium MCL at that time.

RCSD should track the RAA Value for each source and be prepared to provide Tier 2 public notification when the calculated RAA value, starting from September 2014 (third quarter of 2014), exceeds 0.010 mg/L, for any of the three RCSD sources. **RCSD must also notify the Division at that time about the hexavalent chromium MCL violation. Tier 2 public notification of the hexavalent chromium MCL violation will be required within 30 days of learning of the violation.** At that time, the Division will be issuing a compliance order to RCSD to document the hexavalent chromium MCL violation. In the compliance order, RCSD will be required to provide a plan and time schedule to comply with the hexavalent chromium MCL.

As a reminder, all chemical water quality monitoring data obtained for each well should continue to be submitted to the Division via electronic data transfer (EDT) using the Primary Station Code assigned to each well.

It is worthwhile to mention that RCSD is already working with the Division and taking steps to be in compliance with the hexavalent chromium. As part of the Rosamond Regional Consolidation Planning Project, RCSD plans to soon drill a test well to find water with low hexavalent chromium. If you have any questions regarding this matter, please contact our office at (661) 335-7315.

Sincerely,



Jaswinder S. Dhaliwal, P.E.
Senior Sanitary Engineer, Tehachapi District
SOUTHERN CALIFORNIA BRANCH
DRINKING WATER FIELD OPERATIONS

Enclosures:

RCSD Letter dated October 21, 2014
Report from Division's Water Quality Database

cc: Kern County Environmental Health Department (w/o enclosures)
Juan De La Rosa, Designated Operator, RCSD

Rosamond Community Services District

BOARD OF DIRECTORS

Greg Wood, President
Rick Webb, Vice-President
Byron Glennan, Director
Kathleen Spoor, Director
Alfred Wallis, Director

OFFICERS

Steve A. Perez
General Manager
Gibson and Gibson
Counsel
Lizette Guerrero
Board Secretary

October 21, 2014

Jesse Dhaliwal, P.E.
Senior Sanitary Engineer
Tehachapi District
Division of Drinking Water
State Water Resources Control Board
4925 Commerce Drive, Suite 120
Bakersfield, CA 93309


Re: Chromium 6 Grandfathering 2013 Hexavalent Chromium Results

Dear Mr. Dhaliwal,

It is the desire of the Rosamond Community Services District to grandfather the 2013 Hexavalent Chromium results and move forward with 3rd quarter testing of Wells 5, 8, and 9.

Please advise if you require additional information in regard to grandfathering our results.

Very Truly Yours,



Steve A. Perez, SDA
General Manager
Rosamond Community Services District



DATE: 02/02/15
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

PAGE: 1

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19940101 THRU 20150202
REPORT OF COUNTY: 15 KERN

SYSTEM NO: 1510018 NAME: ROSAMOND CSD
SOURCE NO: 002 NAME: WELL 09

COUNTY: KERN
PSCODE: 1510018-002 CLASS: CIGD STATUS: AR

GROUP IDENTIFICATION	SAMPLE DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
IO INORGANIC						
01032 CHROMIUM, HEXAVALENT	05/14/2013	16.0000 *				UG/L
01032 CHROMIUM, HEXAVALENT	10/22/2013	14.0000 *				UG/L
01032 CHROMIUM, HEXAVALENT	09/16/2014	16.0000 *	10.0000	1.0000	10.0000	UG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DATE: 02/02/15
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

PAGE: 1

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19940101 THRU 20150202
REPORT OF COUNTY: 15 KERN

SYSTEM NO: 1510018 NAME: ROSAMOND CSD
SOURCE NO: 006 NAME: WELL 05

COUNTY: KERN CLASS: CIGD STATUS: AR
PSCODE: 1510018-006

GROUP IDENTIFICATION
CONSTITUENT IDENTIFICATION

SAMPLE DATE	RESULT *	MCL	DLF	TRIGGER	UNIT
-------------	----------	-----	-----	---------	------

IO INORGANIC

01032 CHROMIUM, HEXAVALENT	10/22/2013 .	11.0000 *			UG/L
01032 CHROMIUM, HEXAVALENT	09/16/2014 .	12.0000 *	10.0000	1.0000	10.0000 UG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DATE: 02/02/15
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

PAGE: 1

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19940101 THRU 20150202
REPORT OF COUNTY: 15 KERN

SYSTEM NO: 1510018 NAME: ROSAMOND CSD
SOURCE NO: 009 NAME: WELL 08

COUNTY: KERN
FSCODE: 1510018-009 CLASS: CLGD STATUS: AR

GROUP IDENTIFICATION	SAMPLE DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
IO INORGANIC						
01032 CHROMIUM, HEXAVALENT	05/14/2013	12.0000 *				UG/L
01032 CHROMIUM, HEXAVALENT	10/22/2013	13.0000 *				UG/L
01032 CHROMIUM, HEXAVALENT	09/16/2014	12.0000 *	10.0000	1.0000	10.0000	UG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

Attachment B

Letter dated June 12, 2015 from the Division



State Water Resources Control Board
 Division of Drinking Water

June 12, 2015
 System No. 1510018

Steve Perez, General Manager
 Rosamond Community Services District
 3179 35th Street West
 Rosamond, CA 93560

RE: PUBLIC NOTIFICATION FOR VIOLATION OF THE MAXIMUM CONTAMINANT LEVEL (MCL) FOR HEXAVALENT CHROMIUM FOR ROSAMOND CSD WATER SYSTEM

Dear Mr. Perez:

By a letter dated February 12, 2015, the State Water Resources Control Board, Division of Drinking Water (hereinafter Division) directed the Rosamond Community Services District (Rosamond CSD) Water System (hereinafter Water System) to conduct quarterly monitoring for hexavalent chromium of Well 05 (PS Code 1510018-006), Well 08 (PS Code 1510018-009) and Well 09 (PS Code 1510018-002), based on results of two grandfathered samples collected in May 2013 and October 2013 and one sample collected in the third quarter of 2014 being above the hexavalent chromium maximum contaminant level (MCL) of 10 ug/L. No quarterly samples were collected during the fourth quarter of 2014). The Water System submitted results for samples collected in the first and second quarters of 2015. The hexavalent chromium results that have been submitted to the Division are summarized in the table below, with the calculated Running Annual Average (RAA).

Enclosed (Enclosure 1) with this letter is a report from the Division's water quality database showing the hexavalent chromium results. Copies of the results from 2015 are enclosed since those results are not showing up in the Division's water quality database. Please ensure that your contract laboratory electronically (via EDT) reports the 2015 results to the Division's water quality database.

Sample Date	Well 05 (PS Code 1510018-006)	Well 08 (PS Code 1510018-009)	Well 09 (PS Code 1510018-002)
09/16/14 (3 rd Qtr. 2014)	12 ug/L	12 ug/L	16 ug/L
4 th Qtr. 2014	No Sample M&R Violation*	No Sample M&R Violation*	No Sample M&R Violation*
02/17/15 (1 st Qtr. 2015)	Well Offline – No Sample	Well Offline – No Sample	15 ug/L
05/19/15 (2 nd Qtr. 2015)	12 ug/L	Well Offline – No Sample	15 ug/L
RAA Value (3 rd Qtr. 2014 to 2 nd Qtr. 2015)	12 ug/L	12 ug/L	15 ug/L

*: Monitoring and Reporting Violation Due to Not Collecting Quarterly Samples

The above table shows the hexavalent chromium RAA values for Wells 05, 08, and 09. The RAA value for each well has been calculated based on the quarterly samples collected during the 3rd quarter of 2014, and the 1st and 2nd quarters of 2015. **The Division has determined that Wells 05, 08, and 09 are in violation of the hexavalent chromium MCL for the second quarter of 2015.** Therefore, the Water System will need to issue Tier 2 public notification to the customers served by the Rosamond CSD Water System. **Enclosed (Enclosure 2) is a copy of the public notice for issuing to the customers of the Water System. The public notice should be issued before July 3, 2015.** Also enclosed (Enclosure 3) is a blank *Certification of Completion of Public Notification* form. Within 10 days of issuing the hexavalent chromium public notice, please forward copies of the public notice and completed *Certification of Completion of Public Notification* form to the Division.

The Division will be soon issuing a compliance order to document the hexavalent chromium MCL violation. In the compliance order, the Water System will be required to provide a plan and time schedule to comply with the hexavalent chromium MCL.

As a reminder, all chemical water quality monitoring data obtained for each well should continue to be submitted to the Division via electronic data transfer (EDT) using the Primary Station Code assigned to each well.

If you have any questions regarding this matter, please contact Dawn Carlton in our office at (661) 335-7324.

Sincerely,



Jaswinder S. Dhaliwal, P.E.
Senior Sanitary Engineer, Tehachapi District
SOUTHERN CALIFORNIA BRANCH
DRINKING WATER FIELD OPERATIONS

Enclosures:

- Enclosure 1: Report from Division's Water Quality Database and Copies of the Results
- Enclosure 2: Tier 2 Public Notice for Hexavalent Chromium MCL Violation
- Enclosure 3: Certification of Completion of Public Notification Form

cc: Kern County Environmental Health Department (w/o enclosures)
Juan De La Rosa, Chief Operator, Rosamond CSD

JSD/dc

Enclosure 1

**Report from Division's Water Quality Database
and
Copies of the Hexavalent Chromium Results**

DATE: 06/11/15
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

PAGE: 1

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 20120101 THRU 20150611
REPORT OF COUNTY: 15 KERN

SYSTEM NO: 1510018 NAME: ROSAMOND CSD
SOURCE NO: 002 NAME: WELL 09

COUNTY: KERN
PSCODE: 1510018-002 CLASS: CLGD STATUS: AR

GROUP IDENTIFICATION
CONSTITUENT IDENTIFICATION

GROUP IDENTIFICATION	CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
IO INORGANIC	01032 CHROMIUM, HEXAVALENT	05/14/2013	16.0000 *				UG/L
	01032 CHROMIUM, HEXAVALENT	10/22/2013	14.0000 *				UG/L
	01032 CHROMIUM, HEXAVALENT	09/16/2014	16.0000 *	10.0000	1.0000	10.0000	UG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DATE: 06/11/15
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

PAGE: 1

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 20120101 THRU 20150611
REPORT OF COUNTY: 15 KERN

SYSTEM NO: 1510018 NAME: ROSAMOND CSD COUNTY: KERN
SOURCE NO: 006 NAME: WELL 05 PSCODE: 1510018-006 CLASS: CLGD STATUS: AR

GROUP IDENTIFICATION	CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
IO INORGANIC	01032 CHROMIUM, HEXAVALENT	10/22/2013	11.0000 *	10.0000	1.0000	10.0000	UG/L
	01032 CHROMIUM, HEXAVALENT	09/16/2014	12.0000 *	10.0000	1.0000	10.0000	UG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DATE: 06/11/15
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

DRINKING WATER ANALYSES RESULTS REPORT

ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 20120101 THRU 20150611
REPORT OF COUNTY: 15 KERN

SYSTEM NO: 1510018 NAME: ROSAMOND CSD COUNTY: KERN
SOURCE NO: 009 NAME: WELL 08 PSCODE: 1510018-009 CLASS: CLGD STATUS: AR

GROUP IDENTIFICATION	CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
IO INORGANIC							
	01032 CHROMIUM, HEXAVALENT	05/14/2013	12.0000 *				UG/L
	01032 CHROMIUM, HEXAVALENT	10/22/2013	13.0000 *				UG/L
	01032 CHROMIUM, HEXAVALENT	09/16/2014	12.0000 *	10.0000	1.0000	10.0000	UG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

Rosamond Community Services District

BOARD OF DIRECTORS

Morrison "Ed" MacKay, President
Alfred Wallis, Vice-President
Byron Glennan
Olaf Landsgaard
Dennis Shingledecker
March 4, 2015

OFFICERS

Steve A. Perez
General Manager
Allison Burns
Legal Counsel, Stradling
Lizette Guerrero
Board Secretary

Jaswinder S. Dhaliwal, P.E.
State Water Resource Control Board
Division of Drinking Water
4925 Commerce Drive, Suite 120
Bakersfield, Ca. 93309

Re: (First Quarter) Chromium (+6) Test results for R.C.S.D. well's.


Mr. Dhaliwal,

Attached is the (First Quarter) chromium (+6) test results for well # 9.
Note wells #5 and #8 were not tested, currently off line due to winter purposes and will be tested in the near future.

If you have any questions or comments please contact this office at (661) 256-3411.

Respectfully,

Rosamond Community Services District



Juan De La Rosa
Water Quality Supervisor

Clinical Laboratory of San Bernardino, Inc.



Rosamond Community Services 3179 35th St. West Rosamond CA, 93560	Project: Drinking Water Sub Project: Project Manager: Juan De La Rosa	Work Order: 15B1463 Received: 05/19/15 17:55 Reported: 06/03/15
---	---	---

Well #5 15E1463-05 (Water) Sample Date: 05/19/15 9:05 Sampler: Juan De La Rosa

Analyte	Method	Result	Rep. Limit	MCL	Units	Prepared	Analyzed	Batch	Qualifier
Metals									
Arsenic (As)	SM3113-B	8.1	2.0	10	ug/L	05/20/15	05/20/15	1521162	
Chromium (+6)	EPA 218.6	12	1.0	10	ug/L	05/19/15	05/22/15	1521155	
Volatile Organic Analyses									
Methyl tert-Butyl Ether	EPA 524.2	ND	3.0	13	ug/L	05/27/15	05/27/15	1522033	
Surrogate: Bromofluorobenzene	EPA 524.2	107 %				05/27/15	05/27/15	1522033	
Surrogate: 1,2-Dichlorobenzene-d4	EPA 524.2	99 %				05/27/15	05/27/15	1522033	

Well #9 15E1463-06 (Water) Sample Date: 05/19/15 10:20 Sampler: Juan De La Rosa

Analyte	Method	Result	Rep. Limit	MCL	Units	Prepared	Analyzed	Batch	Qualifier
Metals									
Arsenic (As)	SM3113-B	6.1	2.0	10	ug/L	05/20/15	05/20/15	1521162	
Chromium (+6)	EPA 218.6	15	1.0	10	ug/L	05/19/15	05/22/15	1521155	
Volatile Organic Analyses									
Methyl tert-Butyl Ether	EPA 524.2	ND	3.0	13	ug/L	05/27/15	05/27/15	1522033	
Surrogate: Bromofluorobenzene	EPA 524.2	92 %				05/27/15	05/27/15	1522033	
Surrogate: 1,2-Dichlorobenzene-d4	EPA 524.2	92 %				05/27/15	05/27/15	1522033	

ND Analyte NOT DETECTED at or above the reporting limit

Robin Glenney
Project Manager



Rosamond Community Services District

BOARD OF DIRECTORS

Morrison "Ed" MacKay, President
 Alfred Wallis, Vice-President
 Byron Glennan
 Olaf Landsgaard
 Dennis Shingledecker

OFFICERS

Steve A. Perez
General Manager
 Allison Burns
Legal Counsel, Stradling
 Lizette Guerrero
Board Secretary

June 4, 2015

Jaswinder S. Dhaliwal, P.E.
 State Water Resource Control Board
 Division of Drinking Water
 4925 Commerce Drive Suite 120
 Bakersfield, Ca. 93309

Re: (Second Quarter) Distribution MTBE Test Results for R.C.S.D. Wells for 2015.

Mr. Dhaliwal,

Attached is the Distribution system MTBE test results for the (Second Quarter) for District well's # 5 and well # 9. Note well # 8 was not tested, and currently off line due to winter purposes. Well's # 6 and # 7 is no longer hooked to the distribution system and will no longer be tested.

If you have any questions or comments please contact this office at (661) 256-3411.

Respectfully,

ROSAMOND COMMUNITY SERVICES DISTRICT

Juan De La Rosa
 Water Quality Supervisor



Enclosure 2

Tier 2 Public Notice for Hexavalent Chromium MCL Violation

Instructions for Tier 2 Chromium MCL Notice Template

Template Attached

Since exceeding the hexavalent chromium maximum contaminant level (MCL) is a Tier 2 violation, you must provide public notice to persons served as soon as practical but within 30 days after you learn of the violation [California Code of Regulations Title 22, Chapter 15, Section 64463.4(b)]. **Each water system required to give public notice must submit the notice to the State Water Resources Control Board, Division of Drinking Water (DDW) for approval prior to distribution or posting, unless otherwise directed by the DDW [64463(b)].**

Notification Methods

You must use the methods summarized in the table below to deliver the notice to consumers. If you mail, post, or hand deliver, print your notice on letterhead, if available.

<i>If You Are a...</i>	<i>You Must Notify Consumers by...</i>	<i>...and By One or More of the Following Methods to Reach Persons Not Likely to be Reached by the Previous Method...</i>
Community Water System [64463.4(c)(1)]	Mail or direct delivery ^(a)	Publication in a local newspaper
		Posting in conspicuous public places served by the water system or on the Internet ^(b)
		Delivery to community organizations
Non-Community Water System [64463.4(c)(2)]	Posting in conspicuous locations throughout the area served by the water system ^(b)	Publication in a local newspaper or newsletter distributed to customers
		Email message to employees or students
		Posting on the Internet or intranet ^(b)
		Direct delivery to each customer

(a) Notice must be distributed to each customer receiving a bill including those that provide their drinking water to others (e.g., schools or school systems, apartment building owners, or large private employers), and other service connections to which water is delivered by the water system.

(b) Notice must be posted in place for as long as the violation or occurrence continues, but in no case less than seven days.

The notice attached is appropriate for the methods described above. However, you may wish to modify it before using it for posting. If you do, you must still include all the required elements and leave the health effects and notification language in italics unchanged. This language is mandatory [64465].

Multilingual Requirement

The notice must (1) be provided in English, Spanish, and the language spoken by any non-English-speaking group exceeding 10 percent of the persons served by the water

system and (2) include a telephone number or address where such individuals may contact the water system for assistance.

If any non-English-speaking group exceeds 1,000 persons served by the water system, but does not exceed 10 percent served, the notice must (1) include information in the appropriate language(s) regarding the importance of the notice and (2) contain the telephone number or address where such individuals may contact the water system to obtain a translated copy of the notice from the water system or assistance in the appropriate language.

Population Served

Make sure it is clear who is served by your water system -- you may need to list the areas you serve.

Corrective Action

In your notice, describe corrective actions you are taking. Do not use overly technical terminology when describing treatment methods. Listed below are some steps commonly taken by water systems with chemical or radiological violations. Use one or more of the following actions, if appropriate, or develop your own:

- "We are working with [local/state agency] to evaluate the water supply and researching options to correct the problem. These options may include treating the water to remove chromium or connecting to [system]'s water supply."
- "We have stopped using the contaminated well. We have increased pumping from other wells, and we are investigating drilling a new well."
- "We will increase the frequency at which we test the water for chromium."
- "We have since taken samples at this location and had them tested. They show that we meet the standards."

After Issuing the Notice

Send a copy of each type of notice and a certification that you have met all the public notice requirements to the DDW within ten days after you issue the notice [64469(d)]. You should also issue a follow-up notice in addition to meeting any repeat notice requirements the DDW sets.

It is recommended that you notify health professionals in the area of the violation. People may call their doctors with questions about how the violation may affect their health, and the doctors should have the information they need to respond appropriately.

It is a good idea to issue a "problem corrected" notice when the violation is resolved.

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

Rosamond Community Services District Has Levels of Hexavalent Chromium Above the Drinking Water Standard

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what you should do, what happened, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Based on the samples collected from Wells 05, 08 and 09 (3rd Quarter of 2014 to 2nd Quarter of 2015), water supplied by Rosamond CSD contained an average of 15 µg/L (0.015 milligrams per liter) of hexavalent chromium. Wells 05, 08, and 09 produce water that is above the hexavalent chromium maximum contaminant level (MCL) of 10.0 µg/L (0.010 mg/L). This standard, set by the State Water Resources Control Board, Division of Drinking Water, is based upon the running annual average of the most recent quarterly hexavalent chromium monitoring.

What should I do?

- **You do not need to use an alternative water supply (e.g., bottled water).**
- This is not an emergency. If it had been, you would have been notified immediately. However, *some people who drink water containing hexavalent chromium in excess of the MCL over many years may have an increased risk of getting cancer.*
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

Rosamond Community Services District is working with the State Water Resources Control Board, Division of Drinking Water to address this water quality violation. We anticipate resolving the problem within three years.

For more information, please contact the Rosamond Community Services District at (661) 256-3411 or the State Water Resources Control Board, Division of Drinking Water at 66-335-7315.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in

apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS** (including nursing homes and care facilities): Must notify tenants.
- **BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS:** Must notify employees of businesses located on the property.

This notice is being sent to you by Rosamond Community Services District.

State Water System ID#: 1510018 Date distributed: _____.

Enclosure 3

Certification of Completion of Public Notification Form

Attachment C

Hexavalent Chromium Public Notification Template

Instructions for Tier 2 Chromium MCL Notice Template

Template Attached

Since exceeding the hexavalent chromium maximum contaminant level (MCL) is a Tier 2 violation, you must provide public notice to persons served as soon as practical but within 30 days after you learn of the violation [California Code of Regulations Title 22, Chapter 15, Section 64463.4(b)]. **Each water system required to give public notice must submit the notice to the State Water Resources Control Board, Division of Drinking Water (DDW) for approval prior to distribution or posting, unless otherwise directed by the DDW [64463(b)].**

Notification Methods

You must use the methods summarized in the table below to deliver the notice to consumers. If you mail, post, or hand deliver, print your notice on letterhead, if available.

<i>If You Are a...</i>	<i>You Must Notify Consumers by...</i>	<i>...and By One or More of the Following Methods to Reach Persons Not Likely to be Reached by the Previous Method...</i>
Community Water System [64463.4(c)(1)]	Mail or direct delivery ^(a)	Publication in a local newspaper
		Posting in conspicuous public places served by the water system or on the Internet ^(b)
		Delivery to community organizations
Non-Community Water System [64463.4(c)(2)]	Posting in conspicuous locations throughout the area served by the water system ^(b)	Publication in a local newspaper or newsletter distributed to customers
		Email message to employees or students
		Posting on the Internet or intranet ^(b)
		Direct delivery to each customer

(a) Notice must be distributed to each customer receiving a bill including those that provide their drinking water to others (e.g., schools or school systems, apartment building owners, or large private employers), and other service connections to which water is delivered by the water system.

(b) Notice must be posted in place for as long as the violation or occurrence continues, but in no case less than seven days.

The notice attached is appropriate for the methods described above. However, you may wish to modify it before using it for posting. If you do, you must still include all the required elements and leave the health effects and notification language in italics unchanged. This language is mandatory [64465].

Multilingual Requirement

The notice must (1) be provided in English, Spanish, and the language spoken by any non-English-speaking group exceeding 10 percent of the persons served by the water system and (2) include a telephone number or address where such individuals may contact the water system for assistance.

If any non-English-speaking group exceeds 1,000 persons served by the water system, but does not exceed 10 percent served, the notice must (1) include information in the appropriate language(s) regarding the importance of the notice and (2) contain the telephone number or address where such individuals may contact the water system to obtain a translated copy of the notice from the water system or assistance in the appropriate language.

Population Served

Make sure it is clear who is served by your water system -- you may need to list the areas you serve.

Corrective Action

In your notice, describe corrective actions you are taking. Do not use overly technical terminology when describing treatment methods. Listed below are some steps commonly taken by water systems with chemical or radiological violations. Use one or more of the following actions, if appropriate, or develop your own:

- “We are working with [local/state agency] to evaluate the water supply and researching options to correct the problem. These options may include treating the water to remove chromium or connecting to [system]’s water supply.”
- “We have stopped using the contaminated well. We have increased pumping from other wells, and we are investigating drilling a new well.”
- “We will increase the frequency at which we test the water for chromium.”
- “We have since taken samples at this location and had them tested. They show that we meet the standards.”

After Issuing the Notice

Send a copy of each type of notice and a certification that you have met all the public notice requirements to the DDW within ten days after you issue the notice [64469(d)]. You should also issue a follow-up notice in addition to meeting any repeat notice requirements the DDW sets.

It is recommended that you notify health professionals in the area of the violation. People may call their doctors with questions about how the violation may affect their health, and the doctors should have the information they need to respond appropriately.

It is a good idea to issue a “problem corrected” notice when the violation is resolved.

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

Rosamond Community Services District Has Levels of Hexavalent Chromium Above the Drinking Water Standard

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what you should do, what happened, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Based on the samples collected from _____ (____ Quarter of _____) to _____ (____ Quarter of _____), water produced by Well Nos. 05, 08, and 09 contained an average of _____ µg/L (_____ milligrams per liter) of hexavalent chromium. Well Nos. 05, 08, and 09 produce water that is above the hexavalent chromium maximum contaminant level (MCL) of 10.0 µg/L (0.010 mg/L). This standard, set by the State Water Resources Control Board, Division of Drinking Water, is based upon the running annual average of the most recent quarterly hexavalent chromium monitoring.

What should I do?

- **You do not need to use an alternative water supply (e.g., bottled water).**
- This is not an emergency. If it had been, you would have been notified immediately. However, *some people who drink water containing hexavalent chromium in excess of the MCL over many years may have an increased risk of getting cancer.*
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

Rosamond Community Services District is working with the State Water Resources Control Board to resolve the hexavalent chromium problem. We anticipate resolving the problem within three years.

For more information, please contact the Rosamond Community Services District at (661) 256-3411 or 3179 35th Street West, Rosamond, CA 93560

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS** (including nursing homes and care facilities): Must notify tenants.
- **BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS:** Must notify employees of businesses located on the property.

This notice is being sent to you by Rosamond Community Services District.

State Water System ID#: 1510018 Date distributed: _____.

Attachment D

Certification of Public Notification Template

Certification of Completion of Public Notification
(Include a Copy of the Public Notice When Submitting this Form)

This form, when completed and returned to the Division of Drinking Water – Tehachapi District (4925 Commerce Drive, Suite 120, Bakersfield, CA 93309 or fax to 661-335-7316), serves as certification that public notification to water users was completed as required by Title 22, California Code of Regulations, Sections 64463-64465.

Public Water System Name: _____ Rosamond Community Services District _____

Public Water System No.: _____ 1510018 _____

Public notification for failure to comply with the maximum contaminant level (MCL) for hexavalent chromium for the _____ **QUARTER OF** _____ was performed

by the following method(s) (check and complete those that apply):

- The notice was mailed to users on: _____
A copy of the notice is attached.
- The notice was hand delivered to water customers on: _____
A copy of the notice is attached.
- The notice was published in the local newspaper on: _____
A copy of the newspaper notice is attached.
- The notice was posted at conspicuous places on: _____
A copy of the notice is attached.
A list of locations the notice was posted is attached.
- The notice was delivered to community organizations on: _____
A copy of the notice is attached.
A list of community organizations the notice was delivered to is attached.

I hereby certify that the above information is factual.

Printed Name

Title

Signature

Date

Disclosure: Be advised that Section 116725 and 116730 of the California Health and Safety Code state that any person who knowingly makes any false statement on any report or document submitted for the purpose of compliance with the attached order may be liable for a civil penalty not to exceed five thousand dollars (\$5,000) for separate violation each day that the violation continues. In addition, the violators may be prosecuted in criminal court and, upon conviction, be punished by a fine of not more than \$25,000 for each day of violation, or be imprisoned in the county jail not to exceed one year, or by both the fine and imprisonment.

Due to the Division of Drinking Water within 10 days of issuance of notice to customers

Enforcement Action No. 03-19-15R-013

Attachment E

Quarterly Progress Report Template

Quarterly Progress Report

Water System:	Rosamond Community Services District	Water System No.:	1510018
Compliance Order No.:	03-19-15R-013	Violation:	Hexavalent chromium MCL
Calendar Quarter:		Date Prepared:	

This form should be prepared and signed by Water System personnel with appropriate authority to implement the directives of the Compliance Order and the Corrective Action Plan. Please attach additional sheets as necessary. The quarterly progress report must be submitted by the 10th day of each subsequent quarter, to the Division of Drinking Water, Tehachapi District Office.

Summary of Compliance Plan:

Tasks completed in the reporting quarter:

Tasks remaining to complete:

Anticipate compliance date:

Name

Signature

Title

Date