

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26

STATE OF CALIFORNIA
WATER RESOURCES CONTROL BOARD
DIVISION OF DRINKING WATER

TO: California Rehabilitation Center - Norco
P.O. Box 1841
Norco, CA 92860-0991

Attn: Cynthia Y. Tampkins, Warden
California Rehabilitation Center - Norco

CITATION FOR VIOLATION OF CALIFORNIA CODE OF REGULATIONS, TITLE
22, SECTIONS 64426.1 (b) (2) and 64534.4 (a) - WATER SYSTEM NO. 3310800
C I T A T I O N N O . 05-20-15C-006
Issued on October 6, 2015

Section 116650 of the California Health and Safety Code authorizes the issuance of a citation to a public water system for violation of the California Safe Drinking Water Act (Health and Safety Code, Division 104, Part 12, Chapter 4, commencing with Section 116270) (hereinafter "California SDWA"), or any regulation, standard, permit or order issued or adopted thereunder.

The State Water Resources Control Board (hereinafter "Board"), acting by and through its Division of Drinking Water (hereinafter "Division") and the Deputy Director for the Division (hereinafter "Deputy Director"), hereby issues a citation to the California Rehabilitation Center – Norco (hereinafter, "CRC") (P.O. Box 1841, Norco,

1 CA 92860-0991) for violation of California Code of Regulations (CCR), Title 22,
2 Section 64426.1 subsection (b)(2) and Section 64534.4, subsection (a).

3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

APPLICABLE AUTHORITIES

Section 116650 of California Health and Safety Code provides:

(a) If the department determines that a public water system is in violation of this chapter or any regulation, permit, standard, citation, or order issued or adopted thereunder, the department may issue a citation to the public water system. The citation shall be served upon the public water system personally or by certified mail. Service shall be deemed effective as of the date of personal service or the date of receipt of the certified mail. If a person to whom a citation is directed refuses to accept delivery of the certified mail, the date of service shall be deemed to be the date of mailing.

(b) Each citation shall be in writing and shall describe the nature of the violation or violations, including a reference to the statutory provision, standard, order, citation, permit, or regulation alleged to have been violated.

(c) A citation may specify a date for elimination or correction of the condition constituting the violation.

(d) A citation may include the assessment of a penalty as specified in subdivision (e).

(e) The department may assess a penalty in an amount not to exceed one thousand dollars (\$1,000) per day for each day that a violation occurred, and for each day that a violation continues to occur. A separate penalty may be assessed for each violation.

1 **California Code of Regulations, Title 22, Sections 64426.1, subsections (a) and**
2 **(b), and Section 64534.4, subsection (a) provide, in relevant part:**

3 **§64426.1 Total Coliform Maximum Contaminant Level (MCL)**

4 (a) Results of all samples collected in a calendar month pursuant to Sections
5 64423, 64424, and 64425 that are not invalidated by the State Board or the laboratory
6 shall be included in determining compliance with the total coliform MCL. Special
7 purpose samples such as those listed in section 64421(b) and samples collected by
8 the water supplier during special investigations shall not be used to determine
9 compliance with the total coliform MCL.

10 (b) A public water system is in violation of the total coliform MCL when any of
11 the following occurs:

12 (2) For a public water system which collects fewer than 40 samples per
13 month, more than one sample collected during any month is total coliform-positive

14 **§64534.4 Disinfectant Residuals Monitoring**

15 (a) Community and nontransient noncommunity water systems that use
16 chlorine or chloramines shall measure the residual disinfectant levels at the same
17 points in the distribution system and at the same time as total coliforms are sampled,
18 as specified in section 64421.

19
20 **STATEMENT OF FACTS**

21 The CRC water system is operated under Water Supply Permit No. 05-20-07P-004,
22 issued on January 29, 2007.

23
24 CRC serves water to approximately 5,400 staff and inmates at the Rehabilitation
25 Center in Norco, CA. Water is also supplied to the Center Force (Hospitality House),
26 and the Department of Forestry (Camp Norco). CRC is located within the City of
27 Norco in the northwestern portion of Riverside County, and receives all of its potable



1 water from two service connections with the City of Norco (City). CRC has two
2 reservoirs, one booster station at Reservoir No. 1, and a chlorination station also
3 located at Reservoir No. 1. The water supplied by the City consists primarily of
4 groundwater produced by the City's wells and, depending on system demand and
5 availability, treated groundwater purchased from Western Municipal Water District
6 (WMWD). CRC provides continuous disinfection treatment for the water it receives to
7 ensure that a chlorine residual is present in the distribution system.

8
9 CRC collects three routine coliform samples per week rotated among five designated
10 sampling sites in the distribution system in accordance with their Division-approved
11 Bacteriological Sample Siting Plan (BSSP), dated March 28, 2011. In addition to the
12 routine samples, CRC collects a special sample at Reservoir No. 1 weekly for
13 bacteriological analysis. All routine coliform samples are also analyzed for
14 heterotrophic plate count (Plate Count) as required by the Division. Pursuant to Title
15 22, CCR, Section 64534.4, CRC is required measure residual disinfectant levels at
16 the same locations in the distribution system and at the same time total coliform
17 samples are collected. In accordance with the Groundwater Rule, CRC is required to
18 notify the City of Norco of all routine distribution system coliform-positive results within
19 24 hours of being notified of the findings by the laboratory.

20
21 The following is a chronology of events that occurred during September 2015
22 regarding the total coliform MCL failure. The laboratory reports are included as
23 Attachment No. 1.

24
25 **Wednesday, September 2, 2015:** CRC collected three routine total coliform
26 monitoring samples (routine samples) and one special reservoir sample (at Reservoir
27 No. 1). Two of the routine samples (Unit IV and Plant Operations) were found to be

1 total coliform-positive, but absent for *E.coli*. The Unit IV sample had a Plate Count of
2 6.0 CFU/mL and the chlorine residual at the site measured 0.28 mg/L. The Plant Ops
3 sample had a Plate Count of 12.0 CFU/mL and the chlorine residual at the site
4 measured 0.33 mg/L. The other two samples had non-detect Plate Counts. The
5 sample sites had detectable chlorine residuals of 0.67 mg/L and 0.31 mg/L.

6

7 **Thursday, September 4, 2015:** CRC collected three repeat samples for each routine
8 coliform-positive sample, plus one special sample at the Western St. Intertie. All
9 seven samples were found to be absent for total coliform bacteria, and had Plate
10 Counts ranging from non-detect to 28.0 CFU/mL. All repeat sample sites had a
11 detectable chlorine residual ranging from 0.20 mg/L to 0.74 mg/L. The chlorine
12 residual measured at the Western St. Intertie was 0.76 mg/L.

13

14 CRC notified the Division and the City of Norco of the routine total coliform-positive
15 samples. Both triggered source water samples collected by the City were absent for
16 *E.coli*. With two total coliform-positive samples, CRC was determined to be violation
17 of the Total Coliform MCL for the month of September.

18

19 **Wednesday, September 9, 2015:** CRC collected three routine samples and one
20 special sample at Reservoir No. 1. All samples were found to be absent for coliform
21 bacteria. Two routine samples were non-detect for Plate Count, and one sample had
22 a Plate Count of 2.0 CFU/mL. CRC did not measure the chlorine residual at all sites
23 at the time of routine sample collection.

24

25 **Wednesday, September 16, 2015:** CRC collected three routine samples and one
26 special sample at Reservoir No. 1. All samples were found to be absent for coliform
27 bacteria. Two of the routine samples had detectable Plate Count of 2.0 CFU/mL and



1 4.0 CFU/mL. All routine sample sites had detectable chlorine residual ranging from
2 0.23 mg/L to 0.54 mg/L. The chlorine residual measured at Reservoir No.1 was 1.31
3 mg/L.

4
5 **Wednesday, September 23, 2015:** CRC collected three routine samples and one
6 special sample at Reservoir No. 1. All samples were found to be absent for coliform
7 bacteria. All samples were non-detect for Plate Count. Chlorine residuals ranged from
8 0.31 mg/L to 0.71 mg/L at the routine sample sites, and measured 0.56 mg/L at
9 Reservoir No. 1.

10

11 **Wednesday, September 30, 2015:** CRC collected three routine samples and one
12 special sample at Reservoir No. 1. All samples were found to be absent for coliform
13 bacteria. All samples were non-detect for Plate Count. Chlorine residuals ranged from
14 0.64 mg/L to 0.75 mg/L at the routine samples sites, and measured 0.71 mg/L at
15 Reservoir No. 1.

16

17

DETERMINATION

18 The Division has determined that CRC failed to comply with the Maximum
19 Contaminant Level (MCL) for total coliform bacteria during the month of September
20 2015. For a public water system that collects fewer than 40 samples in a month, the
21 water system is in violation of the total coliform MCL when more than one sample
22 collected during any month is total coliform-positive. Two routine distribution system
23 samples collected during September 2015 were total coliform-positive. CRC also
24 failed to comply with the disinfectant residual monitoring requirement. CRC did not
25 measure the residual disinfectant levels at the same points in the distribution system
26 and at the same time as total coliforms were sampled on September 9, 2015.

27

DIRECTIVES

CRC is hereby directed to take the following actions:

1. Forthwith, CRC shall cease and desist from failing to comply with the Primary Drinking Water Standard for bacteriological water quality.
2. Forthwith, CRC shall comply with the requirements for disinfectant residual monitoring in accordance with Section 64534.4, Title 22 of the California Code of Regulations.
3. The notices of the Total Coliform MCL violation must remain posted at conspicuous locations throughout the facility until November 1, 2015.
4. By October 15, 2015, CRC shall provide to the Division certification of public notification using the enclosed form (Attachment No. 2). The certification of notification must identify the number of notices posted and the locations where the notices were posted.
5. CRC shall include information regarding the Total Coliform MCL violation identified in this Citation in the 2015 Consumer Confidence Report, which must be completed and distributed to staff and inmates by July 1, 2016. A draft of the 2015 Consumer Confidence Report shall be submitted to the Division for review and approval prior to distribution and/or posting.

The Division reserves the right to make such modifications to this Citation as it may deem necessary to protect public health and safety. Such modifications may be issued as amendments to this Citation, and shall be deemed effective upon issuance.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29

Nothing in this Citation relieves CRC of its obligation to meet the requirements of the California Safe Drinking Water Act, or of any regulation, permit, standard, or order issued or adopted thereunder.

All submittals required by this Citation shall be submitted to the Division at the following address:

J. Steven Williams, P.E.
District Engineer
State Water Resources Control Board
Division of Drinking Water
1350 Front Street, Room 2050
San Diego, CA 92101

PARTIES BOUND

This Citation shall apply to and be binding upon CRC, its officers, directors, shareholders, agents, employees, contractors, successors, and assignees.

SEVERABILITY

The Directives of this Citation are severable, and CRC shall comply with each and every provision thereof, notwithstanding the effectiveness of any other provision.

FURTHER ENFORCEMENT ACTION

The California SDWA authorizes the Board to: issue a citation with assessment of administrative penalties to a public water system for violation or continued violation of the requirements of the California SDWA or any permit, regulation, permit or order issued or adopted thereunder including, but not limited to, failure to correct a violation identified in a citation or compliance order. The California SDWA also authorizes the

1 Board to take action to suspend or revoke a permit that has been issued to a public
2 water system if the system has violated applicable law or regulations or has failed to
3 comply with an order of the Board; and to petition the superior court to take various
4 enforcement measures against a public water system that has failed to comply with
5 an order of the Board. The Board does not waive any further enforcement action by
6 issuance of this citation.

7

8

9

10

11

12

13

10-6-2015



14

Date

J. Steven Williams, P.E.,
District Engineer
Division of Drinking Water
State Water Resources Control Board

15

16

17

18

19

Attachments:

20

1. September 2015 Distribution System Bacteriological Monitoring Results
2. Proof of Notification Form

21

22

23

cc: County of Riverside, Department of Environmental Health (w/o attachments)

24

25

Deanna Rogers, Capital Outlay Analyst, Department of Corrections and Rehabilitation, Facilities Management Division, Capital Outlay Section, P.O. Box 942883, Sacramento, CA 94283-0001 (w/out attachments)

26

27

28

29

Kimberly Hughes, Associate Warden – Business Services, California Rehabilitation Center - Norco, P.O. Box 1841, Norco, CA 92860-0991 (w/out attachments)

30

31

32

33

Hector Lopez, Correctional Business Manager, California Rehabilitation Center - Norco, P.O. Box 1841, Norco, CA 92860-0991 (w/ attachments)

34



Attachment No. 1



REPORT

3337 MICHELSON DRIVE, SUITE CN 750
IRVINE, CA 92612
(714) 730-6239 • FAX (714) 730-6462
www.truesdail.com

Client: California Dept. Corrections & Rehab (CDCR)-CRC

P.O. Box 1841
Norco, CA 92860

Attention: Singh Rai

Project Name: Weekly Routine

Project Number: Agmnt #5600005537

P.O. Number: 4400007387

Work Order No.: 15I0058

Printed: 09/14/2015

CASE NARRATIVE

SAMPLE RECEIPT SUMMARY

Sample ID	Laboratory ID	Matrix	Type	Date Sampled	Date Received
Plant Ops	15I0058-01	Water	Grab	09/02/2015 08:00	09/02/2015 12:10
Unit IV	15I0058-02	Water	Grab	09/02/2015 09:00	09/02/2015 12:10
Res # 1	15I0058-03	Water	Grab	09/02/2015 09:40	09/02/2015 12:10
Navy	15I0058-04	Water	Grab	09/02/2015 10:00	09/02/2015 12:10

DEFINITIONS

Symbol	Definition
_P	Present
_A	Absent
DF	Dilution Factor
MDL	Method Detection Limit
ND	Not Detected
RL	Reporting Limit

Respectfully yours,

Lyn Phaerakkakit
Project Manager



Client: California Dept. Corrections & Rehab

Project Name: Weekly Routine
 Project Number: Agmnt #5600005537

Printed: 09/14/2015

Plant Ops
15I0058-01 (Water)

Analyte	Result	RL	Units	DF	Batch	Analyzed	Analyst	Method	Notes
---------	--------	----	-------	----	-------	----------	---------	--------	-------

Truesdail Laboratories, Inc

Field Measurements

Chlorine, Residual	0.33	0.00	mg/L	1	1509147	09/02/2015 08:00	LP	Field	
--------------------	------	------	------	---	---------	------------------	----	-------	--

Microbiology

Total Coliforms	Present	1.00	P/A	1	1509049	09/03/2015 12:30	PA	SM 9223 B	_P
Plate Count	12.0	1.00	CFU/mL	1	1509049	09/04/2015 12:30	PA	SM 9215 B	
E. Coli	Absent	1.00	P/A	1	1509049	09/03/2015 12:30	PA	SM 9223 B	_A

Wet Chemistry

Color	1.00		CU	1	1509055	09/03/2015 09:36	AR	SM 2120 C	
Odor	ND	1.00	TON	1	1509144	09/02/2015 17:00	AL	EPA 140.1	
pH	8.08	-3.00	N/A	1	1509026	09/02/2015 14:03	AL	SM 4500-H+ B	
Specific Conductivity	867	2.00	umho/cm	1	1509204	09/08/2015 17:00	AL	SM 2510 B	
MBAS	ND	0.0500	mg/L	1	1509084	09/04/2015 07:45	al	SM 5540 C	
Total Dissolved Solids	483	25.0	mg/L	1	1509175	09/08/2015 20:00	AL	SM 2540 C	
Turbidity	0.211	0.100	NTU	1	1509055	09/03/2015 08:41	AR	EPA 180.1	

Unit IV
15I0058-02 (Water)

Analyte	Result	RL	Units	DF	Batch	Analyzed	Analyst	Method	Notes
---------	--------	----	-------	----	-------	----------	---------	--------	-------

Truesdail Laboratories, Inc

Field Measurements

Chlorine, Residual	0.28	0.00	mg/L	1	1509147	09/02/2015 09:00	LP	Field	
--------------------	------	------	------	---	---------	------------------	----	-------	--

Microbiology

Total Coliforms	Present	1.00	P/A	1	1509049	09/03/2015 12:30	PA	SM 9223 B	_P
Plate Count	6.00	1.00	CFU/mL	1	1509049	09/04/2015 12:30	PA	SM 9215 B	
E. Coli	Absent	1.00	P/A	1	1509049	09/03/2015 12:30	PA	SM 9223 B	_A

Wet Chemistry

Color	1.00		CU	1	1509055	09/03/2015 09:37	AR	SM 2120 C	
Odor	ND	1.00	TON	1	1509144	09/02/2015 17:00	AL	EPA 140.1	
pH	8.10	-3.00	N/A	1	1509026	09/02/2015 14:05	AL	SM 4500-H+ B	
Specific Conductivity	873	2.00	umho/cm	1	1509204	09/08/2015 17:00	AL	SM 2510 B	
MBAS	ND	0.0500	mg/L	1	1509084	09/04/2015 07:50	al	SM 5540 C	
Total Dissolved Solids	482	25.0	mg/L	1	1509175	09/08/2015 20:00	AL	SM 2540 C	
Turbidity	0.209	0.100	NTU	1	1509055	09/03/2015 08:43	AR	EPA 180.1	

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from Truesdail Laboratories.



Client: California Dept. Corrections & Rehab

Project Name: Weekly Routine
 Project Number: Agmnt #5600005537

Printed: 09/14/2015

Res # 1
15I0058-03 (Water)

Analyte	Result	RL	Units	DF	Batch	Analyzed	Analyst	Method	Notes
---------	--------	----	-------	----	-------	----------	---------	--------	-------

Truesdail Laboratories, Inc

Field Measurements

Chlorine, Residual	0.67	0.00	mg/L	1	1509147	09/02/2015 09:40	LP	Field	
--------------------	------	------	------	---	---------	------------------	----	-------	--

Microbiology

Total Coliforms	Absent	1.00	P/A	1	1509049	09/03/2015 12:30	PA	SM 9223 B	_A
Plate Count	ND	1.00	CFU/mL	1	1509049	09/04/2015 12:30	PA	SM 9215 B	
E. Coli	Absent	1.00	P/A	1	1509049	09/03/2015 12:30	PA	SM 9223 B	_A

Wet Chemistry

Color	0.00		CU	1	1509055	09/03/2015 09:38	AR	SM 2120 C	
Odor	ND	1.00	TON	1	1509144	09/02/2015 17:00	AL	EPA 140.1	
pH	8.20	-3.00	N/A	1	1509026	09/02/2015 14:08	AL	SM 4500-H+ B	
Specific Conductivity	887	2.00	umho/cm	1	1509204	09/08/2015 17:00	AL	SM 2510 B	
MBAS	ND	0.0500	mg/L	1	1509084	09/04/2015 07:55	al	SM 5540 C	
Total Dissolved Solids	500	25.0	mg/L	1	1509175	09/08/2015 20:00	AL	SM 2540 C	
Turbidity	0.104	0.100	NTU	1	1509055	09/03/2015 08:44	AR	EPA 180.1	

Navy
15I0058-04 (Water)

Analyte	Result	RL	Units	DF	Batch	Analyzed	Analyst	Method	Notes
---------	--------	----	-------	----	-------	----------	---------	--------	-------

Truesdail Laboratories, Inc

Field Measurements

Chlorine, Residual	0.31	0.00	mg/L	1	1509147	09/02/2015 10:00	LP	Field	
--------------------	------	------	------	---	---------	------------------	----	-------	--

Microbiology

Total Coliforms	Absent	1.00	P/A	1	1509049	09/03/2015 12:30	PA	SM 9223 B	_A
Plate Count	ND	1.00	CFU/mL	1	1509049	09/04/2015 12:30	PA	SM 9215 B	
E. Coli	Absent	1.00	P/A	1	1509049	09/03/2015 12:30	PA	SM 9223 B	_A

Wet Chemistry

Color	0.00		CU	1	1509055	09/03/2015 09:39	AR	SM 2120 C	
Odor	ND	1.00	TON	1	1509144	09/02/2015 17:00	AL	EPA 140.1	
pH	8.18	-3.00	N/A	1	1509026	09/02/2015 14:11	AL	SM 4500-H+ B	
Specific Conductivity	885	2.00	umho/cm	1	1509204	09/08/2015 17:00	AL	SM 2510 B	
MBAS	ND	0.0500	mg/L	1	1509084	09/04/2015 08:00	al	SM 5540 C	
Total Dissolved Solids	501	25.0	mg/L	1	1509175	09/08/2015 20:00	AL	SM 2540 C	
Turbidity	0.106	0.100	NTU	1	1509055	09/03/2015 08:45	AR	EPA 180.1	

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from Truesdail Laboratories.



Client: California Dept. Corrections & Rehab

Project Name: Weekly Routine

Project Number: Agmnt #5600005537

Printed: 09/14/2015

QUALITY CONTROL

Microbiology

Truesdail Laboratories, Inc


Analyte	Result	RL	Units	Spike Level	Source Result	%REC	% Rec Limits	RPD	RPD Limit	Note
---------	--------	----	-------	-------------	---------------	------	--------------	-----	-----------	------

Batch: 1509049 - Colisure-24

Blank (1509049-BLK1)

Prepared: 9/2/2015 Analyzed: 9/4/2015

Plate Count	ND	0.0100	CFU/mL							
Total Coliforms	Absent	1.00	P/A							
E. Coli	Absent	1.00	P/A							



TRUESDAIL LABORATORIES, INC.
 14201 FRANKLIN AVENUE - JUSTIN, CA 92700-7008
 (714) 730-6239 - FAX (714) 730-6462

CHAIN OF CUSTODY

1510058

METHODS

TURNAROUND TIME: Normal FAX
 DATE: 9-2-15 PAGE: 1 OF 1

Customer: California Rehabilitation Center (CRC)
 Contact: Mr. Singh Rai
 Phone: Direct Line - (951) 737-2693 ext 4470 Fax: (951) 273-2342
 Address: 5th and Western Avenue
 Norco, CA 91760
 Project: Weekly Routine

SAMPLE ID	DATE	TIME	DESCRIPTION
PLANT 095	9-2-15	0800	
UNIT IV	9-2-15	0900	
WEST	9-2-15	0945	
NAVY	9-2-15	1000	

Chain of Custody Signature Record

1		T. Rao	OPCR	9-2-15
2		T. Rao	TLI	9/2/15 10:45
3		TLI	TLI	9/2/15 12:10
4		Arzuel	TLI	9/2/15 12:10
5				
6				
7				

LABORATORY SAMPLE LOG IN (Enter following line items on invoice)	MYOB Code	Description	Price
	21 - Col (PVA)		5
	21 - HPC		3
	41 - Color		5
	41 - Odor		7
	41 - Turbidity		5
	41 - Elec Conductivity		7
	41 - MBAS		22
	41 - TDS		8
	41 - pH		4
	Total		

NUMBER OF CONTAINERS	COMMENTS
2	CL2 Residuals
3	
3	
3	

TOTAL NUMBER OF CONTAINERS	SAMPLE CONDITIONS:
	Cool <input checked="" type="checkbox"/> Warm <input type="checkbox"/>
	RECEIVED 12.3' L
	Yes <input type="checkbox"/> No <input type="checkbox"/>

SPECIAL REQUIREMENTS:



REPORT

3337 MICHELSON DRIVE, SUITE CN 750
IRVINE, CA 92612
(714) 730-6239 • FAX (714) 730-6462
www.truesdail.com

Client: California Dept. Corrections & Rehab (CDCR)-CRC

P.O. Box 1841
Norco, CA 92860

Attention: Singh Rai

Project Name: Weekly Routine

Project Number: Agmnt #5600005537

P.O. Number: 4400007387

Work Order No.: 15I0122

Printed: 09/09/2015

CASE NARRATIVE

SAMPLE RECEIPT SUMMARY

Sample ID	Laboratory ID	Matrix	Type	Date Sampled	Date Received
Plant Ops	15I0122-01	Water	Grab	09/04/2015 09:15	09/04/2015 14:39
Unit IV	15I0122-02	Water	Grab	09/04/2015 09:30	09/04/2015 14:39
Fact Dorm 105	15I0122-03	Water	Grab	09/04/2015 09:15	09/04/2015 14:39
Western Interior	15I0122-04	Water	Grab	09/04/2015 10:55	09/04/2015 14:39
L1 & L2 HOSE BIB	15I0122-05	Water	Grab	09/04/2015 09:30	09/04/2015 14:39
Walden House	15I0122-06	Water	Grab	09/04/2015 10:00	09/04/2015 14:39
Navy	15I0122-07	Water	Grab	09/04/2015 10:30	09/04/2015 14:39

DEFINITIONS

Symbol	Definition
_A	Absent
DF	Dilution Factor
MDL	Method Detection Limit
ND	Not Detected
RL	Reporting Limit

Respectfully yours,

Lyn Phaerakkakit
Project Manager



Client: California Dept. Corrections & Rehab

Project Name: Weekly Routine

Project Number: Agmnt #5600005537

Printed: 09/09/2015

Plant Ops
15I0122-01 (Water)

Table with 10 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes

Truesdail Laboratories, Inc

Field Measurements

Table row: Chlorine, Residual 0.27 0.00 mg/L 1 1509149 09/04/2015 09:15 LP Field

Microbiology

Table rows: Total Coliforms Absent 1.00 P/A 1 1509135 09/05/2015 10:00 AL SM 9223 B _A; Plate Count ND 1.00 CFU/mL 1 1509135 09/06/2015 14:00 PA SM 9215 B; E. Coli Absent 1.00 P/A 1 1509135 09/05/2015 10:00 AL SM 9223 B _A

Unit IV
15I0122-02 (Water)

Table with 10 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes

Truesdail Laboratories, Inc

Field Measurements

Table row: Chlorine, Residual 0.57 0.00 mg/L 1 1509149 09/04/2015 09:30 LP Field

Microbiology

Table rows: Total Coliforms Absent 1.00 P/A 1 1509135 09/05/2015 10:00 AL SM 9223 B _A; Plate Count 2.00 1.00 CFU/mL 1 1509135 09/06/2015 14:00 PA SM 9215 B; E. Coli Absent 1.00 P/A 1 1509135 09/05/2015 10:00 AL SM 9223 B _A

Fact Dorm 105
15I0122-03 (Water)

Table with 10 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes

Truesdail Laboratories, Inc

Field Measurements

Table row: Chlorine, Residual 0.27 0.00 mg/L 1 1509149 09/04/2015 09:15 LP Field

Microbiology

Table rows: Total Coliforms Absent 1.00 P/A 1 1509135 09/05/2015 10:00 AL SM 9223 B _A; Plate Count 28.0 1.00 CFU/mL 1 1509135 09/06/2015 14:00 PA SM 9215 B; E. Coli Absent 1.00 P/A 1 1509135 09/05/2015 10:00 AL SM 9223 B _A

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from Truesdail Laboratories.



Client: California Dept. Corrections & Rehab

Project Name: Weekly Routine

Project Number: Agmnt #5600005537

Printed: 09/09/2015

Western Interior
1510122-04 (Water)

Table with 10 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes

Truesdail Laboratories, Inc

Field Measurements

Table row: Chlorine, Residual 0.76 0.00 mg/L 1 1509149 09/04/2015 10:55 LP Field

Microbiology

Table rows: Total Coliforms Absent 1.00 P/A 1 1509135 09/05/2015 10:00 AL SM 9223 B _A
Plate Count ND 1.00 CFU/mL 1 1509135 09/06/2015 14:00 PA SM 9215 B
E. Coli Absent 1.00 P/A 1 1509135 09/05/2015 10:00 AL SM 9223 B _A

L1 & L2 HOSE BIB
1510122-05 (Water)

Table with 10 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes

Truesdail Laboratories, Inc

Field Measurements

Table row: Chlorine, Residual 0.74 0.00 mg/L 1 1509149 09/04/2015 09:30 LP Field

Microbiology

Table rows: Total Coliforms Absent 1.00 P/A 1 1509135 09/05/2015 10:00 AL SM 9223 B _A
Plate Count ND 1.00 CFU/mL 1 1509135 09/06/2015 14:00 PA SM 9215 B
E. Coli Absent 1.00 P/A 1 1509135 09/05/2015 10:00 AL SM 9223 B _A

Walden House
1510122-06 (Water)

Table with 10 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes

Truesdail Laboratories, Inc

Field Measurements

Table row: Chlorine, Residual 0.20 0.00 mg/L 1 1509149 09/04/2015 10:00 LP Field

Microbiology

Table rows: Total Coliforms Absent 1.00 P/A 1 1509135 09/05/2015 10:00 AL SM 9223 B _A
Plate Count 2.00 1.00 CFU/mL 1 1509135 09/06/2015 14:00 PA SM 9215 B
E. Coli Absent 1.00 P/A 1 1509135 09/05/2015 10:00 AL SM 9223 B _A

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from Truesdail Laboratories.



Client: California Dept. Corrections & Rehab

Project Name: Weekly Routine

Project Number: Agmnt #5600005537

Printed: 09/09/2015

Navy
15I0122-07 (Water)

Table with 10 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes

Truesdail Laboratories, Inc

Field Measurements

Table row for Chlorine, Residual: 0.20, 0.00 mg/L, 1, 1509149, 09/04/2015 10:30, LP, Field

Microbiology

Table rows for Microbiology: Total Coliforms (Absent), Plate Count (ND), E. Coli (Absent)

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products.



Client: California Dept. Corrections & Rehab

Project Name: Weekly Routine

Project Number: Agmnt #5600005537

Printed: 09/09/2015

QUALITY CONTROL

Microbiology

Truesdail Laboratories, Inc


Analyte	Result	RL	Units	Spike Level	Source Result	%REC	% Rec Limits	RPD	RPD Limit	Note
---------	--------	----	-------	-------------	---------------	------	--------------	-----	-----------	------

Batch: 1509135 - Colisure-24

Blank (1509135-BLK1)

Prepared: 9/4/2015 Analyzed: 9/6/2015

Plate Count	ND	0.0100	CFU/mL							
-------------	----	--------	--------	--	--	--	--	--	--	--



TRUESDAIL LABORATORIES, INC.
 14201 FRANKLIN AVENUE - TUSTIN, CA 92780-7008
 (714) 730-6239 - FAX (714) 730-6462

CHAIN OF CUSTODY

15I0122

METHODS

X TURNAROUND TIME Normal TAT
 DATE: _____ PAGE: 1 OF 1

COMPANY: California Rehabilitation Center (CRC)
 CONTACT: Mr. Singh Rai
 PHONE: Direct Line - (951) 737-2683 ext 4470 FAX (951) 273-2342
 ADDRESS: 5th and Western Avenue
 Norco, CA 91760
 Project: Weekly Routine

SAMPLE I.D.	DATE	TIME	DESCRIPTION	Total / Fecal / E coli (P/A)	Heterotrophic Plate Count (HPC)	Color, Odor, Turbidity	Specific Conductance	MBAS	Total Dissolved Solids (TDS)	pH	NUMBER OF CONTAINERS	COMMENTS
Plant Ops	9/4/15	915		X								0.27 mg/L
Unit IV	15	930		X								0.57 mg/L
Fecal Damages	"	915		X								0.27 mg/L
Mag Terminal	11	1055		X								0.57 mg/L
Unit 11	11	930		X								0.74 mg/L
Mag House	11	1050		X								0.20 mg/L
NAVY	11	1030		X								0.20 mg/L

Chain of Custody Signature Record

1. <u>Lee BARD</u>	Signature	Company/ Agency	9/4-15	Date/ Time	11:39
2. <u>[Signature]</u>	Signature	Company/ Agency	9/4-15	Date/ Time	2:39
3. <u>[Signature]</u>	Signature	Company/ Agency	9/4/15	Date/ Time	14:39
4. _____	Signature	Company/ Agency		Date/ Time	
5. _____	Signature	Company/ Agency		Date/ Time	
6. _____	Signature	Company/ Agency		Date/ Time	
7. _____	Signature	Company/ Agency		Date/ Time	

LABORATORY SAMPLE LOGIN
 (Enter following line items on invoice):

MYOB Code	Description	Price
21 - Coli (P/A)		5
21 - HPC		3
41 - Color		5
41 - Odor		7
41 - Turbidity		5
41 - Elec Conductivity		7
41 - MBAS		22
41 - TDS		8
41 - pH		4
Total		

SPECIAL REQUIREMENTS:

Cool Warm
 RECEIVED 3.3°C

Yes No



REPORT

3337 MICHELSON DRIVE, SUITE CN 750
IRVINE, CA 92612
(714) 730-6239 • FAX (714) 730-6462
www.truesdail.com

Client: California Dept. Corrections & Rehab (CDCR)-CRC

P.O. Box 1841
Norco, CA 92860

Attention: Singh Rai

Project Name: Agmnt #5600005537

Project Number: Agmnt #5600005537

P.O. Number: 4400007387

Work Order No.: 15I0176

Printed: 09/18/2015

CASE NARRATIVE

SAMPLE RECEIPT SUMMARY

Sample ID	Laboratory ID	Matrix	Type	Date Sampled	Date Received
warehouse	15I0176-01	Water	Grab	09/09/2015 09:00	09/09/2015 12:30
visitor	15I0176-02	Water	Grab	09/09/2015 09:30	09/09/2015 12:30
Unit IV	15I0176-03	Water	Grab	09/09/2015 09:15	09/09/2015 12:30
Navy	15I0176-04	Water	Grab	09/09/2015 08:00	09/09/2015 12:30
Res#1	15I0176-05	Water	Grab	09/09/2015 10:15	09/09/2015 12:30

DEFINITIONS

Symbol	Definition
_A	Absent
DF	Dilution Factor
MDL	Method Detection Limit
ND	Not Detected
RL	Reporting Limit

Respectfully yours,

Lyn Phaerakkakit
Project Manager



Client: California Dept. Corrections & Rehab

Project Name: Agmnt #5600005537

Project Number: Agmnt #5600005537

Printed: 09/18/2015

warehouse
15I0176-01 (Water)

Analyte	Result	RL	Units	DF	Batch	Analyzed	Analyst	Method	Notes
---------	--------	----	-------	----	-------	----------	---------	--------	-------

Truesdail Laboratories, Inc

Microbiology

Total Coliforms	Absent	1.00	P/A	1	1509190	09/10/2015 13:00	PA	SM 9223 B	_A
Plate Count	ND	1.00	CFU/mL	1	1509190	09/11/2015 13:00	PA	SM 9215 B	
E. Coli	Absent	1.00	P/A	1	1509190	09/10/2015 13:00	PA	SM 9223 B	_A

Wet Chemistry

Color	5.00		CU	1	1509201	09/10/2015 09:32	AR	SM 2120 C	
Odor	ND	1.00	TON	1	1509182	09/09/2015 17:00	AL	EPA 140.1	
pH	7.84	0.00	N/A	1	1509171	09/09/2015 18:10	AL	SM 4500-H+ B	
Specific Conductivity	863	2.00	umho/cm	1	1509363	09/18/2015 10:31	AL	SM 2510 B	
MBAS	ND	0.0500	mg/L	1	1509212	09/11/2015 07:15	al	SM 5540 C	
Total Dissolved Solids	496	25.0	mg/L	1	1509263	09/14/2015 11:51	AL	SM 2540 C	
Turbidity	0.402	0.100	NTU	1	1509201	09/10/2015 09:16	AR	EPA 180.1	

Haloacetic Acids by EPA 552.2

Monochloroacetic acid	ND	1.00	ug/L	1	1509199	09/10/2015 22:50	JG	EPA 552.2	
Dichloroacetic acid	ND	1.00	ug/L	1	1509199	09/10/2015 22:50	JG	EPA 552.2	
Trichloroacetic acid	ND	1.00	ug/L	1	1509199	09/10/2015 22:50	JG	EPA 552.2	
Monobromoacetic acid	ND	1.00	ug/L	1	1509199	09/10/2015 22:50	JG	EPA 552.2	
Dibromoacetic acid	3.63	1.00	ug/L	1	1509199	09/10/2015 22:50	JG	EPA 552.2	
<i>Surrogate: 2,3-Dibromopropionic acid</i>		85%	70-130		1509199	09/10/2015 22:50	JG	EPA 552.2	

Trihalomethanes

Bromoform	48.1	0.500	ug/L	1	1509165	09/09/2015 18:10	JJ	EPA 524.2	
Chloroform	1.00	0.500	ug/L	1	1509165	09/09/2015 18:10	JJ	EPA 524.2	
Dibromochloromethane	12.7	0.500	ug/L	1	1509165	09/09/2015 18:10	JJ	EPA 524.2	
Bromodichloromethane	3.32	0.500	ug/L	1	1509165	09/09/2015 18:10	JJ	EPA 524.2	
Total Trihalomethanes	65.1	0.500	ug/L	1	1509165	09/09/2015 18:10	JJ	EPA 524.2	
<i>Surrogate: Dibromofluoromethane</i>		89%	70-130		1509165	09/09/2015 18:10	JJ	EPA 524.2	
<i>Surrogate: Toluene-d8</i>		97%	70-130		1509165	09/09/2015 18:10	JJ	EPA 524.2	
<i>Surrogate: Bromofluorobenzene</i>		104%	70-130		1509165	09/09/2015 18:10	JJ	EPA 524.2	

visitor
15I0176-02 (Water)

Analyte	Result	RL	Units	DF	Batch	Analyzed	Analyst	Method	Notes
---------	--------	----	-------	----	-------	----------	---------	--------	-------

Truesdail Laboratories, Inc

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from Truesdail Laboratories.



Client: California Dept. Corrections & Rehab

Project Name: Agmnt #5600005537

Project Number: Agmnt #5600005537

Printed: 09/18/2015

visitor (Continued)
15I0176-02 (Water) (Continued)

Analyte	Result	RL	Units	DF	Batch	Analyzed	Analyst	Method	Notes
---------	--------	----	-------	----	-------	----------	---------	--------	-------

Truesdail Laboratories, Inc

Microbiology

Total Coliforms	Absent	1.00	P/A	1	1509190	09/10/2015 13:00	PA	SM 9223 B	_A
Plate Count	ND	1.00	CFU/mL	1	1509190	09/11/2015 13:00	PA	SM 9215 B	
E. Coli	Absent	1.00	P/A	1	1509190	09/10/2015 13:00	PA	SM 9223 B	_A

Wet Chemistry

Color	1.00		CU	1	1509201	09/10/2015 09:34	AR	SM 2120 C	
Odor	ND	1.00	TON	1	1509182	09/09/2015 17:00	AL	EPA 140.1	
pH	7.94	0.00	N/A	1	1509171	09/09/2015 18:12	AL	SM 4500-H+ B	
Specific Conductivity	664	2.00	umho/cm	1	1509363	09/18/2015 10:31	AL	SM 2510 B	
MBAS	ND	0.0500	mg/L	1	1509212	09/11/2015 07:20	al	SM 5540 C	
Total Dissolved Solids	397	25.0	mg/L	1	1509263	09/14/2015 11:51	AL	SM 2540 C	
Turbidity	0.136	0.100	NTU	1	1509201	09/10/2015 09:17	AR	EPA 180.1	

Unit IV
15I0176-03 (Water)

Analyte	Result	RL	Units	DF	Batch	Analyzed	Analyst	Method	Notes
---------	--------	----	-------	----	-------	----------	---------	--------	-------

Truesdail Laboratories, Inc

Haloacetic Acids by EPA 552.2

Monochloroacetic acid	ND	1.00	ug/L	1	1509199	09/10/2015 23:56	JG	EPA 552.2	
Dichloroacetic acid	ND	1.00	ug/L	1	1509199	09/10/2015 23:56	JG	EPA 552.2	
Trichloroacetic acid	ND	1.00	ug/L	1	1509199	09/10/2015 23:56	JG	EPA 552.2	
Monobromoacetic acid	ND	1.00	ug/L	1	1509199	09/10/2015 23:56	JG	EPA 552.2	
Dibromoacetic acid	3.54	1.00	ug/L	1	1509199	09/10/2015 23:56	JG	EPA 552.2	

Surrogate: 2,3-Dibromopropionic acid 128% 70-130 1509199 09/10/2015 23:56 JG EPA 552.2

Trihalomethanes

Bromoform	31.6	0.500	ug/L	1	1509165	09/09/2015 18:51	JJ	EPA 524.2	
Chloroform	0.987	0.500	ug/L	1	1509165	09/09/2015 18:51	JJ	EPA 524.2	
Dibromochloromethane	8.91	0.500	ug/L	1	1509165	09/09/2015 18:51	JJ	EPA 524.2	
Bromodichloromethane	2.48	0.500	ug/L	1	1509165	09/09/2015 18:51	JJ	EPA 524.2	
Total Trihalomethanes	43.9	0.500	ug/L	1	1509165	09/09/2015 18:51	JJ	EPA 524.2	

Surrogate: Dibromofluoromethane 82% 70-130 1509165 09/09/2015 18:51 JJ EPA 524.2

Surrogate: Toluene-d8 97% 70-130 1509165 09/09/2015 18:51 JJ EPA 524.2

Surrogate: Bromofluorobenzene 89% 70-130 1509165 09/09/2015 18:51 JJ EPA 524.2

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from Truesdail Laboratories.



Client: California Dept. Corrections & Rehab

Project Name: Agmnt #5600005537

Project Number: Agmnt #5600005537

Printed: 09/18/2015

Unit IV (Continued)
15I0176-03 (Water) (Continued)

Table with 11 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes

Navy
15I0176-04 (Water)

Table with 11 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes

Truesdail Laboratories, Inc

Microbiology

Microbiology data table with 11 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes

Wet Chemistry

Wet Chemistry data table with 11 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes

Res#1
15I0176-05 (Water)

Table with 11 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes

Truesdail Laboratories, Inc

Microbiology

Microbiology data table with 11 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes

Wet Chemistry

Wet Chemistry data table with 11 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from Truesdail Laboratories.



Client: California Dept. Corrections & Rehab

Project Name: Agmnt #5600005537

Project Number: Agmnt #5600005537

Printed: 09/18/2015

QUALITY CONTROL

Microbiology

Truesdail Laboratories, Inc

Analyte	Result	RL	Units	Spike Level	Source Result	%REC	% Rec Limits	RPD	RPD Limit	Note
---------	--------	----	-------	-------------	---------------	------	--------------	-----	-----------	------

Batch: 1509190 - Colisure-24

Blank (1509190-BLK1)

Prepared: 9/9/2015 Analyzed: 9/11/2015

Plate Count	ND	0.0100	CFU/mL							
-------------	----	--------	--------	--	--	--	--	--	--	--

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from Truesdail Laboratories.



REPORT

3337 MICHELSON DRIVE, SUITE CN 750
IRVINE, CA 92612
(714) 730-6239 • FAX (714) 730-6462
www.truesdail.com

Client: California Dept. Corrections & Rehab (CDCR)-CRC

P.O. Box 1841
Norco, CA 92860

Attention: Singh Rai

Project Name: Agmnt #5600005537

Project Number: Agmnt #5600005537

P.O. Number: 4400007387

Work Order No.: 15I0312

Printed: 09/25/2015

CASE NARRATIVE

SAMPLE RECEIPT SUMMARY

Sample ID	Laboratory ID	Matrix	Type	Date Sampled	Date Received
Res#1	15I0312-01	Water	Grab	09/16/2015 10:00	09/16/2015 13:27
Navy	15I0312-02	Water	Grab	09/16/2015 09:45	09/16/2015 13:27
Unit IV	15I0312-03	Water	Grab	09/16/2015 09:15	09/16/2015 13:27
visitor	15I0312-04	Water	Grab	09/16/2015 08:45	09/16/2015 13:27

DEFINITIONS

Symbol	Definition
_A	Absent
DF	Dilution Factor
MDL	Method Detection Limit
ND	Not Detected
RL	Reporting Limit

Respectfully yours,

Lyn Phaerakkakit
Project Manager



Client: California Dept. Corrections & Rehab

Project Name: Agmnt #5600005537

Project Number: Agmnt #5600005537

Printed: 09/25/2015

Res#1
15I0312-01 (Water)

Table with 10 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes

Truesdail Laboratories, Inc

Field Measurements

Table row for Chlorine, Residual: 1.31, 0.00 mg/L, 1, 1509539, 09/16/2015 10:00, LP, Field

Microbiology

Table rows for Total Coliforms (Absent), Plate Count (ND), E. Coli (Absent)

Wet Chemistry

Table rows for Color (0.00), Odor (ND), pH (8.05), Specific Conductivity (898), MBAS (ND), Total Dissolved Solids (534), Turbidity (ND)

Navy
15I0312-02 (Water)

Table with 10 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes

Truesdail Laboratories, Inc

Field Measurements

Table row for Chlorine, Residual: 0.54, 0.00 mg/L, 1, 1509539, 09/16/2015 09:45, LP, Field

Microbiology

Table rows for Total Coliforms (Absent), Plate Count (ND), E. Coli (Absent)

Wet Chemistry

Table rows for Color (1.00), Odor (ND), pH (8.00), Specific Conductivity (897), MBAS (ND), Total Dissolved Solids (540), Turbidity (0.124)

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from Truesdail Laboratories.



Client: California Dept. Corrections & Rehab

Project Name: Agmnt #5600005537

Project Number: Agmnt #5600005537

Printed: 09/25/2015

**Unit IV
15I0312-03 (Water)**

Analyte	Result	RL	Units	DF	Batch	Analyzed	Analyst	Method	Notes
---------	--------	----	-------	----	-------	----------	---------	--------	-------

Truesdail Laboratories, Inc

Field Measurements

Chlorine, Residual	0.55	0.00	mg/L	1	1509539	09/16/2015 09:15	LP	Field	
--------------------	------	------	------	---	---------	------------------	----	-------	--

Microbiology

Total Coliforms	Absent	1.00	P/A	1	1509318	09/17/2015 14:00	PA	SM 9223 B	_A
Plate Count	2.00	1.00	CFU/mL	1	1509318	09/18/2015 14:00	PA	SM 9215 B	
E. Coli	Absent	1.00	P/A	1	1509318	09/17/2015 14:00	PA	SM 9223 B	_A

Wet Chemistry

Color	1.00		CU	1	1509328	09/17/2015 11:23	AR	SM 2120 C	
Odor	ND	1.00	TON	1	1509452	09/16/2015 19:00	AL	EPA 140.1	
pH	8.05	0.00	N/A	1	1509292	09/16/2015 15:23	AL	SM 4500-H+ B	
Specific Conductivity	885	2.00	umho/cm	1	1509489	09/23/2015 00:00	AL	SM 2510 B	
MBAS	ND	0.0500	mg/L	1	1509355	09/17/2015 19:30	AL	SM 5540 C	
Total Dissolved Solids	512	25.0	mg/L	1	1509438	09/22/2015 00:00	AL	SM 2540 C	
Turbidity	0.117	0.100	NTU	1	1509328	09/17/2015 10:59	AR	EPA 180.1	

**visitor
15I0312-04 (Water)**

Analyte	Result	RL	Units	DF	Batch	Analyzed	Analyst	Method	Notes
---------	--------	----	-------	----	-------	----------	---------	--------	-------

Truesdail Laboratories, Inc

Field Measurements

Chlorine, Residual	0.23	0.00	mg/L	1	1509539	09/16/2015 08:45	LP	Field	
--------------------	------	------	------	---	---------	------------------	----	-------	--

Microbiology

Total Coliforms	Absent	1.00	P/A	1	1509318	09/17/2015 14:00	PA	SM 9223 B	_A
Plate Count	4.00	1.00	CFU/mL	1	1509318	09/18/2015 14:00	PA	SM 9215 B	
E. Coli	Absent	1.00	P/A	1	1509318	09/17/2015 14:00	PA	SM 9223 B	_A

Wet Chemistry

Color	26.0		CU	1	1509328	09/17/2015 11:24	AR	SM 2120 C	
Odor	ND	1.00	TON	1	1509452	09/16/2015 19:00	AL	EPA 140.1	
pH	7.95	0.00	N/A	1	1509292	09/16/2015 15:25	AL	SM 4500-H+ B	
Specific Conductivity	890	2.00	umho/cm	1	1509489	09/23/2015 00:00	AL	SM 2510 B	
MBAS	ND	0.0500	mg/L	1	1509355	09/17/2015 19:35	AL	SM 5540 C	
Total Dissolved Solids	428	25.0	mg/L	1	1509438	09/22/2015 00:00	AL	SM 2540 C	
Turbidity	2.29	0.100	NTU	1	1509328	09/17/2015 11:01	AR	EPA 180.1	

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from Truesdail Laboratories.



Client: California Dept. Corrections & Rehab

Project Name: Agmnt #5600005537

Project Number: Agmnt #5600005537

Printed: 09/25/2015

QUALITY CONTROL

Microbiology

Truesdail Laboratories, Inc

Analyte	Result	RL	Units	Spike Level	Source Result	%REC	% Rec Limits	RPD	RPD Limit	Note
---------	--------	----	-------	-------------	---------------	------	--------------	-----	-----------	------


Batch: 1509318 - Colisure-24

Blank (1509318-BLK1)

Prepared: 9/16/2015 Analyzed: 9/18/2015

Plate Count	ND	0.0100	CFU/mL							
-------------	----	--------	--------	--	--	--	--	--	--	--

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from Truesdail Laboratories.



TRUESDAIL LABORATORIES, INC.
 14761 FRANKLIN AVENUE - JUSTIN, CA 92780-7008
 (714) 730-6239 FAX (714) 730-6462

CHAIN OF CUSTODY

1510312

METHODS

TURNAROUND TIME Normal FAX
 DATE 9-16-15 PAGE 1 OF 1

Customer: California Rehabilitation Center (CRC)
 Contact: Mr. Singh Rai Richard Hill
 Phone: Direct Line - (951) 737-2683 ext 4170 Fax (951) 273-2342
 Address: 5th and Western Avenue
 Norco, CA 91760
 Project: Weekly Routine

SAMPLE ID	DATE	TIME	DESCRIPTION
RES #1	9-16-15	1000	
NAVY	9-16-15	945	
Unit+IV	9-16-15	915	
Visitor	9-16-15	845	

Chain of Custody Signature Record

Signature	Company/Agency	Date/Time
<i>[Signature]</i>	TII 9/16/15	10:50
<i>[Signature]</i>	TII 9/16/15	11:27
<i>[Signature]</i>	TU 9/16/15	13:27
Signature	Company/Agency	Date/Time

LABORATORY SAMPLE LOGIN
 (Enter following line items on invoice)

MYOB Code	Description	Price
21 - Col (P/A)		5
21 - HPC		3
41 - Color		5
41 - Odor		7
41 - Turbidity		5
41 - Elec Conductivity		7
41 - MBAS		22
41 - TDS		8
41 - pH		4
Total		

Total / Fecal / E coli (P/A)	Heterotrophic Plate Count (HPC)	Color, Odor, Turbidity	Specific Conductance	MBAS	Total Dissolved Solids (TDS)	TU
X	X	X	X	X	X	X
X	X	X	X	X	X	X
X	X	X	X	X	X	X
X	X	X	X	X	X	X

NUMBER OF CONTAINERS	COMMENTS
3	CL2 Residuals
3	1.31 mg/L
3	0.54 mg/L
3	0.55 mg/L
3	0.23 mg/L

TOTAL NUMBER OF CONTAINERS: 12
 SPECIAL REQUIREMENTS:
 RECEIVED: Cool Warm
 Yes No



REPORT

3337 MICHELSON DRIVE, SUITE CN 750
IRVINE, CA 92612
(714) 730-6239 • FAX (714) 730-6462
www.truesdail.com

Client: California Dept. Corrections & Rehab (CDCR)-CRC

P.O. Box 1841
Norco, CA 92860

Attention: Singh Rai

Project Name: Agmnt #5600005537

Project Number: Agmnt #5600005537

P.O. Number: 4400007387

Work Order No.: 1510447

Printed: 10/02/2015

CASE NARRATIVE

SAMPLE RECEIPT SUMMARY

Sample ID	Laboratory ID	Matrix	Type	Date Sampled	Date Received
plant ops	1510447-01	Water	Grab	09/23/2015 07:15	09/23/2015 13:15
warehouse	1510447-02	Water	Grab	09/23/2015 08:00	09/23/2015 13:15
Res#1	1510447-03	Water	Grab	09/23/2015 09:15	09/23/2015 13:15
Navy	1510447-04	Water	Grab	09/23/2015 08:30	09/23/2015 13:15

DEFINITIONS

Symbol	Definition
_A	Absent
DF	Dilution Factor
MDL	Method Detection Limit
ND	Not Detected
RL	Reporting Limit

Respectfully yours,

Lyn Phaerakkakit
Project Manager



Client: California Dept. Corrections & Rehab

Project Name: Agmnt #5600005537

Project Number: Agmnt #5600005537

Printed: 10/02/2015

plant ops
1510447-01 (Water)

Analyte	Result	RL	Units	DF	Batch	Analyzed	Analyst	Method	Notes
---------	--------	----	-------	----	-------	----------	---------	--------	-------

Truesdail Laboratories, Inc

Field Measurements

Chlorine, Residual	0.71	0.00	mg/L	1	1509609	09/23/2015 07:15	LP	Field	
--------------------	------	------	------	---	---------	------------------	----	-------	--

Microbiology

Total Coliforms	Absent	1.00	P/A	1	1509483	09/24/2015 14:24	PA	SM 9223 B	_A
Plate Count	4.00	1.00	CFU/mL	1	1509483	09/25/2015 14:37	PA	SM 9215 B	
E. Coli	Absent	1.00	P/A	1	1509483	09/24/2015 14:24	PA	SM 9223 B	_A

Wet Chemistry

Color	0.00		CU	1	1509507	09/24/2015 13:46	AR	SM 2120 C	
Odor	ND	1.00	TON	1	1509617	09/23/2015 18:00	AL	EPA 140.1	
pH	8.13	0.00	N/A	1	1509494	09/23/2015 19:01	AL	SM 4500-H+ B	
Specific Conductivity	858	2.00	umho/cm	1	1509530	09/24/2015 00:00	AL	SM 2510 B	
MBAS	ND	0.0500	mg/L	1	1509570	09/24/2015 19:50	AL	SM 5540 C	
Turbidity	0.181	0.100	NTU	1	1509507	09/24/2015 13:22	AR	EPA 180.1	

plant ops
1510447-01RE1 (Water)

Analyte	Result	RL	Units	DF	Batch	Analyzed	Analyst	Method	Notes
---------	--------	----	-------	----	-------	----------	---------	--------	-------

Truesdail Laboratories, Inc

Wet Chemistry

Total Dissolved Solids	505	25.0	mg/L	1	1510004	09/30/2015 00:00	AL	SM 2540 C	
------------------------	-----	------	------	---	---------	------------------	----	-----------	--

warehouse
1510447-02 (Water)

Analyte	Result	RL	Units	DF	Batch	Analyzed	Analyst	Method	Notes
---------	--------	----	-------	----	-------	----------	---------	--------	-------

Truesdail Laboratories, Inc

Field Measurements

Chlorine, Residual	0.31	0.00	mg/L	1	1509609	09/23/2015 08:00	LP	Field	
--------------------	------	------	------	---	---------	------------------	----	-------	--

Microbiology

Total Coliforms	Absent	1.00	P/A	1	1509483	09/24/2015 14:24	PA	SM 9223 B	_A
Plate Count	ND	1.00	CFU/mL	1	1509483	09/25/2015 14:37	PA	SM 9215 B	
E. Coli	Absent	1.00	P/A	1	1509483	09/24/2015 14:24	PA	SM 9223 B	_A

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from Truesdail Laboratories.



Client: California Dept. Corrections & Rehab

Project Name: Agmnt #5600005537

Project Number: Agmnt #5600005537

Printed: 10/02/2015

warehouse (Continued)
15I0447-02 (Water) (Continued)

Table with 10 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes

Truesdail Laboratories, Inc

Wet Chemistry

Table with 10 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes. Rows include Color, Odor, pH, Specific Conductivity, MBAS, Turbidity.

warehouse
15I0447-02RE1 (Water)

Table with 10 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes

Truesdail Laboratories, Inc

Wet Chemistry

Table with 10 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes. Row includes Total Dissolved Solids.

Res#1
15I0447-03 (Water)

Table with 10 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes

Truesdail Laboratories, Inc

Field Measurements

Table with 10 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes. Row includes Chlorine, Residual.

Microbiology

Table with 10 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes. Rows include Total Coliforms, Plate Count, E. Coli.

Wet Chemistry

Table with 10 columns: Analyte, Result, RL, Units, DF, Batch, Analyzed, Analyst, Method, Notes. Rows include Color, Odor, pH, Specific Conductivity, MBAS, Turbidity.

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from Truesdail Laboratories.



Client: California Dept. Corrections & Rehab

Project Name: Agmnt #5600005537

Project Number: Agmnt #5600005537

Printed: 10/02/2015

Res#1

15I0447-03RE1 (Water)

Analyte	Result	RL	Units	DF	Batch	Analyzed	Analyst	Method	Notes
---------	--------	----	-------	----	-------	----------	---------	--------	-------

Truesdail Laboratories, Inc

Wet Chemistry

Total Dissolved Solids	495	25.0	mg/L	1	1510004	09/30/2015 00:00	AL	SM 2540 C	
------------------------	-----	------	------	---	---------	------------------	----	-----------	--

Navy

15I0447-04 (Water)

Analyte	Result	RL	Units	DF	Batch	Analyzed	Analyst	Method	Notes
---------	--------	----	-------	----	-------	----------	---------	--------	-------

Truesdail Laboratories, Inc

Field Measurements

Chlorine, Residual	0.61	0.00	mg/L	1	1509609	09/23/2015 08:30	LP	Field	
--------------------	------	------	------	---	---------	------------------	----	-------	--

Microbiology

Total Coliforms	Absent	1.00	P/A	1	1509483	09/24/2015 14:24	PA	SM 9223 B	_A
Plate Count	ND	1.00	CFU/mL	1	1509483	09/25/2015 14:37	PA	SM 9215 B	
E. Coli	Absent	1.00	P/A	1	1509483	09/24/2015 14:24	PA	SM 9223 B	_A

Wet Chemistry

Color	0.00		CU	1	1509507	09/24/2015 13:50	AR	SM 2120 C	
Odor	ND	1.00	TON	1	1509617	09/23/2015 18:00	AL	EPA 140.1	
pH	8.25	0.00	N/A	1	1509494	09/23/2015 19:05	AL	SM 4500-H+ B	
Specific Conductivity	892	2.00	umho/cm	1	1509530	09/24/2015 00:00	AL	SM 2510 B	
MBAS	ND	0.0500	mg/L	1	1509570	09/25/2015 07:40	AL	SM 5540 C	
Turbidity	ND	0.100	NTU	1	1509507	09/24/2015 13:30	AR	EPA 180.1	

Navy

15I0447-04RE1 (Water)

Analyte	Result	RL	Units	DF	Batch	Analyzed	Analyst	Method	Notes
---------	--------	----	-------	----	-------	----------	---------	--------	-------

Truesdail Laboratories, Inc

Wet Chemistry

Total Dissolved Solids	495	25.0	mg/L	1	1510004	09/30/2015 00:00	AL	SM 2540 C	
------------------------	-----	------	------	---	---------	------------------	----	-----------	--

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from Truesdail Laboratories.



Client: California Dept. Corrections & Rehab

Project Name: Agmnt #5600005537

Project Number: Agmnt #5600005537

Printed: 10/02/2015

QUALITY CONTROL

Microbiology

Truesdail Laboratories, Inc

Analyte	Result	RL	Units	Spike Level	Source Result	%REC	% Rec Limits	RPD	RPD Limit	Note
---------	--------	----	-------	-------------	---------------	------	--------------	-----	-----------	------


Batch: 1509483 - Colisure-24

Blank (1509483-BLK1)

Prepared: 9/23/2015 Analyzed: 9/25/2015

Plate Count	ND	0.0100	CFU/mL							
-------------	----	--------	--------	--	--	--	--	--	--	--

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from Truesdail Laboratories.



TRUESDAIL LABORATORIES, INC.
 14201 FRANKLIN AVENUE - JUSTIN, CA 92780-7008
 (714) 730-6239 FAX (714) 730-6462

CHAIN OF CUSTODY

1510447

METHODS

DATE: _____ TURNAROUND TIME: Normal (24)
 PAGE 1 of 1

Customer: California Rehabilitation Center (CRC)
 Contract: Mr. Singh Rai
 Project: Weekly Routine
 Address: 5th and Western Avenue
 Norco, CA 91760
 Phone: Direct Line - (951) 737-2683 ext 4470 FAX (951) 273-2314
 Sample Laboratory:

SAMPLE ID	DATE	TIME	DESCRIPTION	Total / Fecal / E coli (P/A)	Heterotrophic Plate Count (HPC)	Color, Odor, Turbidity	Specific Conductance	MBAS	Total Dissolved Solids (TDS)	TDS	COMMENTS
Plant ops		0715		X	X	X	X	X	X	X	CL2 Residuals 0.71
Ware house		0800		X	X	X	X	X	X	X	0.31
Res 1		0915		X	X	X	X	X	X	X	0.56
NAVY		0830		X	X	X	X	X	X	X	0.61

Chain of Custody Signature Record

1		CRC	9-23-15/1100
2		TLI	9/23/15 11:00
3		TLI	9/23/15 13:15
4		TLI	9/23/15 13:15
5			
6			
7			

LABORATORY SAMPLE LOGIN

MYOB Code	Description	Price
21 - Col (17A)		5
21 - HPC		3
41 - Color		5
41 - Odor		7
41 - Turbidity		5
41 - Elec Conductivity		7
41 - MBAS		22
41 - TDS		8
41 - pH		4
Total		

LABORATORY SAMPLE LOGIN (Enter following line items on invoice)

TOTAL NUMBER OF CONTAINERS: 12

RECEIVED: Cool Warm

SPECIAL REQUIREMENTS: 3.6°C

Yes No



REPORT

3337 MICHELSON DRIVE, SUITE CN 750
IRVINE, CA 92612
(714) 730-6239 • FAX (714) 730-6462
www.truesdail.com

Client: California Dept. Corrections & Rehab (CDCR)-CRC

P.O. Box 1841
Norco, CA 92860

Attention: Singh Rai

Project Name: Weekly Routine

Project Number: Agmnt #5600005537

P.O. Number: 4400007387

Work Order No.: 15I0538

Printed: 10/05/2015

CASE NARRATIVE

SAMPLE RECEIPT SUMMARY

Sample ID	Laboratory ID	Matrix	Type	Date Sampled	Date Received
plant ops	15I0538-01	Water	Grab	09/30/2015 08:05	09/30/2015 13:25
Unit IV	15I0538-02	Water	Grab	09/30/2015 08:30	09/30/2015 13:25
Navy	15I0538-03	Water	Grab	09/30/2015 08:45	09/30/2015 13:25
Res#1	15I0538-04	Water	Grab	09/30/2015 09:15	09/30/2015 13:25

DEFINITIONS

Symbol	Definition
_A	Absent
DF	Dilution Factor
MDL	Method Detection Limit
ND	Not Detected
RL	Reporting Limit

Respectfully yours,

Lyn Phaerakkakit
Project Manager



Client: California Dept. Corrections & Rehab

Project Name: Weekly Routine

Project Number: Agmnt #5600005537

Printed: 10/05/2015

plant ops
15I0538-01 (Water)

Analyte	Result	RL	Units	DF	Batch	Analyzed	Analyst	Method	Notes
---------	--------	----	-------	----	-------	----------	---------	--------	-------

Truesdail Laboratories, Inc

Field Measurements

Chlorine, Residual	0.74	0.00	mg/L	1	1510039	09/30/2015 08:05	LP	Field	
--------------------	------	------	------	---	---------	------------------	----	-------	--

Microbiology

Total Coliforms	Absent	1.00	P/A	1	1510060	10/01/2015 15:00	PA	SM 9223 B	_A
Plate Count	ND	1.00	CFU/mL	1	1510060	10/02/2015 15:00	PA	SM 9215 B	
E. Coli	Absent	1.00	P/A	1	1510060	10/01/2015 15:00	PA	SM 9223 B	_A

Wet Chemistry

Color	0.00		CU	1	1510003	10/01/2015 08:45	AR	SM 2120 C	
Odor	ND	1.00	TON	1	1510047	09/30/2015 17:00	AL	EPA 140.1	
pH	8.16	0.00	N/A	1	1510016	09/30/2015 14:42	AR	SM 4500-H+ B	
Specific Conductivity	931	2.00	umho/cm	1	1509634	09/30/2015 16:00	AL	SM 2510 B	
MBAS	ND	0.0500	mg/L	1	1510002	10/01/2015 07:50	al	SM 5540 C	
Total Dissolved Solids	491	25.0	mg/L	1	1510004	10/01/2015 00:00	AL	SM 2540 C	
Turbidity	0.192	0.100	NTU	1	1510003	10/01/2015 08:26	AR	EPA 180.1	

Unit IV
15I0538-02 (Water)

Analyte	Result	RL	Units	DF	Batch	Analyzed	Analyst	Method	Notes
---------	--------	----	-------	----	-------	----------	---------	--------	-------

Truesdail Laboratories, Inc

Field Measurements

Chlorine, Residual	0.61	0.00	mg/L	1	1510039	09/30/2015 08:30	LP	Field	
--------------------	------	------	------	---	---------	------------------	----	-------	--

Microbiology

Total Coliforms	Absent	1.00	P/A	1	1510060	10/01/2015 15:00	PA	SM 9223 B	_A
Plate Count	ND	1.00	CFU/mL	1	1510060	10/02/2015 15:00	PA	SM 9215 B	
E. Coli	Absent	1.00	P/A	1	1510060	10/01/2015 15:00	PA	SM 9223 B	_A

Wet Chemistry

Color	0.00		CU	1	1510003	10/01/2015 08:46	AR	SM 2120 C	
Odor	ND	1.00	TON	1	1510047	09/30/2015 17:00	AL	EPA 140.1	
pH	8.13	0.00	N/A	1	1510016	09/30/2015 14:46	AR	SM 4500-H+ B	
Specific Conductivity	915	2.00	umho/cm	1	1509634	09/30/2015 16:00	AL	SM 2510 B	
MBAS	ND	0.0500	mg/L	1	1510002	10/01/2015 07:55	al	SM 5540 C	
Total Dissolved Solids	490	25.0	mg/L	1	1510004	10/01/2015 00:00	AL	SM 2540 C	
Turbidity	0.127	0.100	NTU	1	1510003	10/01/2015 08:27	AR	EPA 180.1	

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from Truesdail Laboratories.



Client: California Dept. Corrections & Rehab

Project Name: Weekly Routine
 Project Number: Agmnt #5600005537

Printed: 10/05/2015

Navy
15I0538-03 (Water)

Analyte	Result	RL	Units	DF	Batch	Analyzed	Analyst	Method	Notes
---------	--------	----	-------	----	-------	----------	---------	--------	-------

Truesdail Laboratories, Inc

Field Measurements

Chlorine, Residual	0.75	0.00	mg/L	1	1510039	09/30/2015 08:45	LP	Field	
--------------------	------	------	------	---	---------	------------------	----	-------	--

Microbiology

Total Coliforms	Absent	1.00	P/A	1	1510060	10/01/2015 15:00	PA	SM 9223 B	_A
Plate Count	ND	1.00	CFU/mL	1	1510060	10/02/2015 15:00	PA	SM 9215 B	
E. Coli	Absent	1.00	P/A	1	1510060	10/01/2015 15:00	PA	SM 9223 B	_A

Wet Chemistry

Color	0.00		CU	1	1510003	10/01/2015 08:47	AR	SM 2120 C	
Odor	ND	1.00	TON	1	1510047	09/30/2015 17:00	AL	EPA 140.1	
pH	8.15	0.00	N/A	1	1510016	09/30/2015 14:49	AR	SM 4500-H+ B	
Specific Conductivity	925	2.00	umho/cm	1	1509634	09/30/2015 16:00	AL	SM 2510 B	
MBAS	ND	0.0500	mg/L	1	1510002	10/01/2015 08:00	al	SM 5540 C	
Total Dissolved Solids	498	25.0	mg/L	1	1510004	10/01/2015 00:00	AL	SM 2540 C	
Turbidity	0.142	0.100	NTU	1	1510003	10/01/2015 08:29	AR	EPA 180.1	

Res#1
15I0538-04 (Water)

Analyte	Result	RL	Units	DF	Batch	Analyzed	Analyst	Method	Notes
---------	--------	----	-------	----	-------	----------	---------	--------	-------

Truesdail Laboratories, Inc

Field Measurements

Chlorine, Residual	0.71	0.00	mg/L	1	1510039	09/30/2015 09:15	LP	Field	
--------------------	------	------	------	---	---------	------------------	----	-------	--

Microbiology

Total Coliforms	Absent	1.00	P/A	1	1510060	10/01/2015 15:00	PA	SM 9223 B	_A
Plate Count	ND	1.00	CFU/mL	1	1510060	10/02/2015 15:00	PA	SM 9215 B	
E. Coli	Absent	1.00	P/A	1	1510060	10/01/2015 15:00	PA	SM 9223 B	_A

Wet Chemistry

Color	0.00		CU	1	1510003	10/01/2015 08:48	AR	SM 2120 C	
Odor	ND	1.00	TON	1	1510047	09/30/2015 17:00	AL	EPA 140.1	
pH	8.19	0.00	N/A	1	1510016	09/30/2015 14:52	AR	SM 4500-H+ B	
Specific Conductivity	922	2.00	umho/cm	1	1509634	09/30/2015 16:00	AL	SM 2510 B	
MBAS	ND	0.0500	mg/L	1	1510002	10/01/2015 08:05	al	SM 5540 C	
Total Dissolved Solids	505	25.0	mg/L	1	1510004	10/01/2015 00:00	AL	SM 2540 C	
Turbidity	0.101	0.100	NTU	1	1510003	10/01/2015 08:30	AR	EPA 180.1	

This report applies only to the sample, or samples, investigated and is not necessarily indicative of the quality or condition of apparently identical or similar products. As a mutual protection to clients, the public and these laboratories, this report is submitted and accepted for the exclusive use of the client to whom it is addressed and upon the condition that it is not to be used, in whole or in part, in any advertising or publicity matter without prior written authorization from Truesdail Laboratories.

CHAIN OF CUSTODY

1510538

METHODS

Customer: California Rehabilitation Center (CRC)
 Project: Mr. Singh Rai / E.H.11
 Address: Direct Line - (951) 737-2683 ext 4470 FAX (951) 273-2342
 5th and Western Avenue
 Norco, CA 91760
 Project: Weekly Routine

Sample Description:

SAMPLE ID	DATE	TIME	DESCRIPTION
Plantops	9-30-15	0805	
UNIT IV	9-30-15	0830	
NAVY	9-30-15	0845	
RESA 1	9-30-15	915	

Chain of Custody Signature Record

1		Signature	Norco	Company/ Agency	9-30-15	Date/ Time
2		Signature	TV	Company/ Agency	9/30/15	110
3		Signature	TV	Company/ Agency	9/30/15	1325
4		Signature	TV	Company/ Agency	9/30/15	1325
5		Signature		Company/ Agency		
6		Signature		Company/ Agency		
7		Signature		Company/ Agency		

LABORATORY SAMPLE LOG IN
 (Enter following line items on invoice)

MYO# Code	Description	Price
21 - Coli (TVA)		5
21 - HPC		3
41 - Color		5
41 - Odor		7
41 - Turbidity		5
41 - Elec Conductivity		7
41 - MPAS		22
41 - TDS		8
41 - pH		4
Total		

NUMBER OF CONTAINERS

CL2 Residuals
 3 6.74 mg/L
 3 0.61 ms/L
 3 0.75 as/L
 3 0.71 as/L

COMMENTS

DATE: 9-30-15 TURNAROUND TIME: Terminal FAX: 1 OF 1

SPECIAL REQUIREMENTS:

RECEIVED: Cool Warm
 5.6°C
 Yes No

Attachment No. 2

Drinking Water Notification to Consumers

PROOF OF NOTIFICATION

Name of Water System: _____

Please explain what caused the problem if you have determined what it was and what steps you have taken to correct it. _____

Consumers Notified _____ Yes _____ No

If not, explain: _____

Date of Notification: _____

On the date of notification set forth above, I served the above referenced document(s) on the consumers by:

_____ Sending a copy through the U.S. Mail, first class, postage prepaid, addressed to each of the resident(s) at the place where the property is situated, pursuant to the California Civil Code. Attach copy of Notice.

_____ Newspaper (if the problem has been corrected). Attach a copy of Notice.

_____ Personally hand-delivering a copy to each of the consumers. Attach a copy of Notice.

_____ Posted on a public bulletin board, that will be seen by each of the consumers (for small, non-community water systems with prior Division approval). Attach copy of Notice.

I hereby declare the forgoing to be true and correct under penalty of perjury.

Dated: _____

Signature of Person Serving Notice

****Notice:** Complete this Proof of Notification and return it along with a copy of the notification to the State Water Resources Control Board, Division of Drinking Water (Division) within 10 days of receipt of giving public notice.

Disclosure: Be advised that the California Health and Safety Code states that any person who knowingly makes a false statement on any report or document submitted for the purpose of compliance with the attached order may be liable for a civil penalty not to exceed five thousand dollars (\$5,000) for each separate violation for each day that violation continues. In addition, the violators may be prosecuted in criminal court and upon conviction, be punished by fine of not more than twenty-five thousand dollars (\$25,000) for each day of violation, or be imprisoned in county jail not to exceed one year or by both the fine and imprisonment.