



# Shasta County

01\_75\_16C\_002\_4500016\_23

DEPARTMENT OF RESOURCE MANAGEMENT  
1855 Placer Street, Redding, CA 96001

Richard W. Simon, AICP  
Director

Dale J. Fletcher, CBO  
Assistant Director

July 26, 2016

Richard Lindroth  
Lakehead Subdivision Mutual Water Co.  
21406 Coleman Street  
Lakehead, CA 96051

## **CITATION FOR LAKEHEAD SUBDIVISION MUTUAL WATER SYSTEM# 4500016 JUNE 2016, FAILURE TO MONITOR FOR BACTERIOLOGICAL WATER QUALITY**

The Lakehead Subdivision Mutual Water System is classified as a community public water system which is required to collect one routine sample per month for coliform bacteria as prescribed under Sections 64423 and 64424 of Title 22, California Code of Regulations (Title 22). During the month of June 2016, Lakehead Subdivision Mutual Water Company and Lakehead Subdivision Mutual Water System did not submit a copy of a laboratory analysis to this office for review by July 10, 2016, or did not collect its routine bacteriological water sample from the distribution system. Therefore, this Citation is being issued to the Lakehead Subdivision Mutual Water Company for violating the bacteriological monitoring and reporting requirements for the month of June 2016.

The Lakehead Subdivision Mutual Water Company Water System owner is hereby directed to take the following actions:

1. As required under Section 64463.7 of Title 22, provide public notification to customers within one year of this notice of violation. Enclosure 'A' is a format you may use to fulfill the above public notification requirements. If you wish to propose any change to this notification, please contact our office.
2. Provide two types of public notification: 1) Posting in conspicuous locations throughout the area served by the water system; and 2) mail or hand deliver copies to each water user.
3. Complete and return Enclosure 'B' "Certification of Completion of Public Notification" form within 10 days of giving public notice.
4. The Lakehead Subdivision Mutual Water Company Water System representatives shall comply with Section 64423, Title 22, CCR, in all future monitoring periods.

Suite 101  
AIR QUALITY MANAGEMENT DISTRICT  
530 225-5674  
Fax 530 225-5237

Suite 102  
BUILDING DIVISION  
530 225-5761  
Fax 530 245-6468

Suite 103  
PLANNING DIVISION  
530 225-5532  
Fax 530 245-6468

Suite 201  
ENVIRONMENTAL HEALTH DIVISION  
530 225-5787  
Fax 530 225-5413

Suite 200  
ADMINISTRATION & COMMUNITY EDUCATION  
530 225-5789  
Fax 530 225-5807

Lakehead Subdivision Mutual Water Co.  
Page 2  
July 26, 2016

Failure to comply with the directives of this citation may result in further enforcement action with the possibility of administrative penalties.

Note that Section 116577 of the California Safe Drinking Water Act provides for the Shasta County Environmental Health Division to be reimbursed by the public water system for costs incurred for preparing and issuing a citation to that system. In accordance with Section 116577, Lakehead Subdivision Mutual Water Co. is hereby charged for the preparation and issuance of this letter. Our current costs are \$65.73 per hour. The estimated time to prepare this citation is one-half hour (\$32.87). Please submit your payment with the certification form requested in item 3 above.

Please contact me at 530/225-5787, Monday through Friday, between 8:00 and 8:30 a.m. should you have any questions or concerns.

Sincerely,

A handwritten signature in cursive script that reads "Christy Gilbreath".

Christy Gilbreath  
Registered Environmental Health Specialist

CG/pw

Enclosures