



# Shasta County

DEPARTMENT OF RESOURCE MANAGEMENT  
1855 Placer Street, Redding, CA 96001

Richard W. Simon, AICP  
Director

Dale J. Fletcher, CBO  
Assistant Director

August 16, 2016

Anderson Park Village  
3020 Ark Way  
Cottonwood, CA 96022

CITATION 01\_75\_16C\_005\_4500254\_22 FOR WATER QUALITY FAILURE - PUBLIC WATER SYSTEM NO. 4500254, ANDERSON PARK VILLAGE

This letter is to inform you that the Anderson Park Village Water System failed to meet bacteriological domestic water quality standards for July 2016. The number of positive bacteriological samples exceeds the limits of Title 22, California Code of Regulations (CCR), Article 3, Section 64426.1(b). Four of ten water samples collected between July 5 and August 5, 2016, were positive for total coliform bacteria. The standard is that no more than one sample per month may do so.

Section 64464.1, Title 22, CCR, specifies that the Shasta County Environmental Health Division (SCEHD) shall direct the water supplier to provide public notification. For the July 2016 water quality failure, the water system shall give notices by posting a notification in conspicuous locations throughout the area served by the water system and by one or more of the following methods to reach persons not likely to be reached by the previous method: publication in local newspaper, email message to customers (employees and students), posting in the internet or by direct delivery to each customer. The enclosed notice titled "Important Information about Your Drinking Water" is the public notice that you shall give to all water users and post to fulfill the above notification requirements.

Within 45 days of receipt of this letter, you are required to send this office a signed statement which indicates the date the notice was posted. Completing and returning the enclosed "Certification of Completion of Public Notification" form fulfills this requirement. Please also include what corrective action was taken to prevent such failures in the future and the cause of the failure if known.

Note that Section 116577 of the California Safe Drinking Water Act provides for the Shasta County Environmental Health Division (SCEHD) to be reimbursed by the public water system for costs incurred for preparing and issuing public notifications to that system. In accordance with Section 116577, the water system will be billed for the preparation and issuance of this letter and notification. Approximately one 1/2-hour was spent preparing this letter and

Suite 101  
AIR QUALITY MANAGEMENT DISTRICT  
530 225-5674  
Fax 530 225-5237

Suite 102  
BUILDING DIVISION  
530 225-5761  
Fax 530 245-6468

Suite 103  
PLANNING DIVISION  
530 225-5532  
Fax 530 245-6468

Suite 201  
ENVIRONMENTAL HEALTH DIVISION  
530 225-5787  
Fax 530 225-5413

Suite 200  
ADMINISTRATION & COMMUNITY EDUCATION  
530 225-5789  
Fax 530 225-5807

Anderson Park Village


Page 2

August 16, 2016

notification, and currently our costs are approximately \$65.73 per hour. You shall submit a check in the amount of \$32.87 to SCEHD.

Please call me at 530/225-5787 Monday through Friday between 8:00 and 8:30 a.m. should you have any questions regarding this matter.

Sincerely,

A handwritten signature in cursive script that reads "Christy Gilbreath".

Christy Gilbreath, R.E.H.S.

Registered Environmental Health Specialist

CG/js

Enclosures