



Shasta County

DEPARTMENT OF RESOURCE MANAGEMENT
1855 Placer Street, Redding, CA 96001

Richard W. Simon, AICP
Director

Dale J. Fletcher, CBO
Assistant Director

September 7, 2016

Lillian Lewis
P. O. Box 87
Dunsmuir, CA 96025

**LAKE SHASTA PINES RV AND CAMPGROUND WATER SYSTEM NO. 4500101
COMPLIANCE ORDER NO. 01_75_16R_009_4500101_08 FOR THREATENED
VIOLATION OF CALIFORNIA HEALTH AND SAFETY CODE SECTION 116555(a)(3)**

Section 116655 of the California Health and Safety Code (CHSC) authorizes the issuance of a compliance order to a public water system for violations or threatened violations of the California Safe Drinking Water Act or any permit, regulation, or standard issued or adopted thereunder.

APPLICABLE AUTHORITIES

The Shasta County Environmental Health Division (SCEHD) acting through the delegated authority, granted by the State Water Resources Control Board Division of Drinking Water (DDW), hereby issues a compliance order to Lillian Lewis and the Lake Shasta Pines RV Park and Campground Water System (Water System) for a threatened failure to comply with CHSC Section 116555(a)(3).

STATEMENT OF FACTS

The Water System is classified as a community water system serving approximately 150 people through 66 active service connections. On August 30, 2016, SCEHD and DDW staff performed a sanitary survey inspection of the Water System, along with the Water System's certified operator. As a result of the inspection, it was observed that the 26,000-gallon storage tank was in poor condition, continuously leaks, and has a degrading roof. Several large holes on the roof were open to the elements and did not allow for a proper inspection of the roof.

DETERMINATIONS

SCEHD has determined that without corrective action required by this Order, the breach in the storage tank could lead to a buildup of unwanted sediment, exposure to rodents birds, rats, insects, and bacteria in the distribution system and potentially a waterborne disease outbreak. This would be a violation of Section 116555 (a)(3) of the CHSC.

<input type="checkbox"/> Suite 101 AIR QUALITY MANAGEMENT DISTRICT 530 225-5674 Fax 530 225-5237	<input type="checkbox"/> Suite 102 BUILDING DIVISION 530 225-5761 Fax 530 245-6468	<input type="checkbox"/> Suite 103 PLANNING DIVISION 530 225-5532 Fax 530 245-6468	<input checked="" type="checkbox"/> Suite 201 ENVIRONMENTAL HEALTH DIVISION 530 225-5787 Fax 530 225-5413	<input type="checkbox"/> Suite 200 ADMINISTRATION & COMMUNITY EDUCATION 530 225-5789 Fax 530 225-5807
---	---	---	--	--

DIRECTIVES

The Water System is hereby directed to take the following actions:

- (1) Provide a corrective action plan by November 1, 2016, with a time schedule for replacing or repairing the storage tank.
- (2) By December 1, 2016, submit for review and approval final design plans and specifications for the repair of the existing storage tank or construction of a new storage tank. The storage tank repair or new storage tank shall be designed and constructed in accordance with California Code of Regulations, Title 22, Chapter 16, California Waterworks Standards including, but not limited to, Section 64554 (a)(2) New and Existing Source Capacity, Section 64585 Design and Construction, and Section 64582 Disinfection of Reservoirs.
- (3) The Water System shall remain on boiled or bottled water for its drinking water supply and continue public notification until the storage tank has been repaired or replaced.
- (4) The Water System shall continue to maintain a minimum free chlorine residual of 1.0-mg/L in the distribution system until the boil water / bottled water advisory is lifted.
- (5) The Water System, or certified operator, shall contact SCEHD when corrective work has been completed in order to schedule a field inspection to verify the storage tank has been repaired or replaced by March 1, 2017.

All submittals required by this Order shall be forwarded to:

Christy Gilbreath, R.E.H.S
Registered Environmental Health Specialist
Shasta County Environmental Health Division
1855 Placer Street, Suite 201, Redding, CA 96001

The SCEHD reserves the right to make such modifications to this Order as it may deem necessary to protect public health and safety. Such modifications may be issued as amendments to this Order and shall be deemed effective upon issuance. Nothing in this Order relieves the Water System of its obligation to meet the requirements of the California Safe Drinking Water Act, or any regulation, permit, standard, or order issued or adopted thereunder.

Failure to comply with any provisions of this Order will result in issuance of a citation and possible assessed civil penalty of up to \$100 per day per provision being violated.

The SCEHD shall not be liable for any injuries or damages to persons or property resulting from acts of omissions by the Lake Shasta Pines RV and Campground Water System, its employees, agents or contractors in carrying out any activities pursuant to this Order, nor shall SCEHD be held as a party to any contract entered into by the Water System or its agents in carrying out


activities pursuant to this Order. By issuance of this Order, SCEHD does not waive any further enforcement action.

PARTIES BOUND


This Order shall apply to and be binding upon the Water System, its owners, shareholders, officers, directors, agents, employees, contractors, successors, and assignees.

SEVERABILITY

The directives of this Order are severable, and the Water System shall comply with each and every provision thereof notwithstanding the effectiveness of any provision.



Carla Serio, R.E.H.S., Director
Shasta County Environmental Health Division



Date

c: Mey Bunte, Division of Drinking Water, State Water Resources Control Board