

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

STATE OF CALIFORNIA
WATER RESOURCES CONTROL BOARD
DIVISION OF DRINKING WATER

TO: DOT/Hunter Hill Rest Area
611 Payran Street
Petaluma, CA 94952-5910

ATTN: Christine Corcoran

CITATION FOR VIOLATION OF TITLE 22, CALIFORNIA CODE OF REGULATIONS (CCR)

SECTION 64426.1(b)(2)

FOR THE MONTH OF FEBRUARY 2016

WATER SYSTEM NO: 4800781

CITATION NO: 02_04_16C_003

ISSUE DATE: MARCH 10, 2016

Section 116650 of the California Health and Safety Code (CHSC), authorizes the issuance of a citation for failure to comply with a requirement of the California Safe Drinking Water Act (CHSC, Division 104, Part 12, Chapter 4, commencing with Section 116270), or any regulation, standard, permit, or order issued thereunder.

The Division of Drinking Water (Division) of the State Water Resources Control Board (Board) hereby issues a citation, to Hunter Hill Rest Area (Hunter Hill) for failure to comply with Title 22, California Code of Regulations (CCR) Section 64426.1(b)(2).



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

APPLICABLE AUTHORITIES

Section 116650 of the CHSC states in relevant part:

- (a) If the Division determines that a public water system is in violation of this chapter or any regulation, permit, standard, citation or order issued thereunder, the division may issue a citation to the public water system. The citation shall be served upon the public water system personally, or by certified mail. Service shall be deemed effective as of the date of personal service or the date of receipt of the certified mail, if a person to whom a citation is directed, refuses to accept the delivery of the certified mail, the date of service shall be deemed to be the date of mailing.
- (b) Each citation shall be in writing and shall describe the nature of the violation or violations, including a reference to the statutory provision, standard, order, citation, permit, or regulation alleged to have been violated.
- (c) A citation may specify a date of elimination or correction of the condition constituting the violation.
- (d) A citation may include the assessment of a penalty as specified in subdivision (e).
- (e) The Division may assess a penalty in an amount not to exceed one thousand dollars (\$1000) per day that a violation occurred, and for each day that a violation continues to occur. A separate penalty may be assessed for each violation.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

Section 64426.1(b)(2) states in relevant part:

(b) A public water system is in violation of the total coliform MCL when any of the following occurs:

(2) For a public water system which collects fewer than 40 samples per month, more than one sample collected during any month is total coliform-positive

STATEMENT OF FACTS

Hunter Hill is a transient-noncommunity water system located on Westbound Interstate 80 between American Canyon Road and State Highway 37 in Vallejo, Solano County. . The water system consists of one groundwater well, a hypochlorination treatment system, a 500 gallon non-pressurized storage tank, an alternating booster pump system, and a 79 gallon hydropneumatic tank. Hunter Hill collected its routine bacteriological sample on February 2, 2016 the sample was total coliform-positive and *E.coli* negative. On February 8th, three repeat samples were total coliform-positive and *E.coli* negative. Hunter Hill failed the total coliform MCL for the month of February 2016.

DETERMINATIONS

Hunter Hill has violated the bacteriological Maximum Contaminant Level (MCL) in Section 64426.1(b)(2).

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

DIRECTIVES

Hunter Hill is hereby directed to take the following actions:

1. Notify all persons served by Hunter Hill of the total coliform positive results, in conformance with Section 64463.4 and Section 64465, Title 22 of the CCR and as follows:
 - a) Completion of Attachment A to include the name, address, and telephone number of a representative of Hunter Hill as a source of additional information concerning the public notice. You must also give a legible, written description (preferably typed) of the corrective actions taken by the water system to prevent this violation from occurring in the future. You must use the space provided on Attachment A for this written description.
 - b) Post the notice contained in Attachment A, after it has been completed in accordance with (a) above, in conspicuous locations throughout the area served by the water system. Posting must begin no later than March 21, 2016, and must continue for seven days.
2. Hunter Hill shall complete the attached Compliance Certification form and return it to the Division within 10 days of the public notice being given to system customers but in no case later than April 1, 2016. A copy of the notice posted within the water system must be attached to this form.
3. Hunter Hill shall collect five (5) routine bacteriological samples for the month of March 2016.

The Division reserves the right to make such modifications to this Citation, as it may deem necessary to protect public health and safety. Such modifications may be issued as amendments to this Citation and shall be effective upon issuance.



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

Nothing in this Citation relieves Hunter Hill of its obligation to meet the requirements of the California Safe Drinking Water Act (CHS, Division 104, Part 12, Chapter 4, commencing with Section 116270), or any regulation, standard, permit, or order issued thereunder.

All submittals required by this Citation shall be submitted to Division at the following address:

Robert Brownwood, P.E.
San Francisco District
State Water Resources Control Board
Division of Drinking Water
850 Marina Bay Parkway, Bldg. P., 2nd Floor
Richmond, CA 94804

PARTIES BOUND

The Citation shall apply to be binding upon Hunter Hill its officers, directors, agents, employees, contractors successors, and assignees.

SEVERABILITY

The directives of this Citation are severable, and Hunter Hill shall comply with each and every provision thereof notwithstanding the effectiveness of any provision.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

FURTHER ENFORCEMENT ACTION

The California SDWA authorizes the Board to issue a citation with assessment of administrative penalties to a public water system for violation or continued violation of the requirements of the California SDWA or any permit, regulation, or order issued thereunder including, but not limited to, failure to correct a violation identified in citation or compliance order. The California SDWA also authorizes the Board to take action to suspend or revoke a permit that has been issued to a public water system if the system has violated applicable laws or regulations or has failed to comply with an order of the Board, and to petition the superior court to take various enforcement measures against a public water system that has failed to comply with or violates an order of the Board. The Board does not waive any further enforcement action by issuance of this citation.

MARCH 10, 2016
Date

Robert C. Brown
Robert Brownwood, P.E.
San Francisco District Engineer
State Water Resources Control Board
Division of Drinking Water

Attachment: Compliance Certification
Certified Mail No: 7014 3490 0001 7031 0949
Cc: Solano County Environmental Health Department

