



EDMUND G. BROWN JR.
GOVERNOR



MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board

Division of Drinking Water

Water System No. 4900791

August 27, 2014

Scott Evans
Western Mobile Home Park
871 38th Avenue
Santa Cruz, CA 95062

**CITATION NO. 02-18-14C-028
CIS-1,2-DICHLOROETHYLENE AND TRICHLOROETHYLENE MONITORING AND
REPORTING VIOLATION FOR SECOND QUARTER 2014**

Enclosed is a Citation issued to the Western Mobile Home Park (System) public water system.

Western Mobile Home Park will be billed at the State Water Resources Control Board Division of Drinking Water's (Division) hourly rate (currently estimated at \$128.00) for the time spent on issuing this Citation. Health and Safety Code Section 116577 provides that a public water system must reimburse the Division for actual costs incurred by the Division for specified enforcement actions, including, but not limited to, preparing, issuing, and monitoring compliance with a citation. At this time, the Division has spent approximately two hours on enforcement activities associated with this violation.

Western Mobile Home Park will receive a bill sent from our Division Fee Billing Unit in August of the next fiscal year. This bill will contain any fees for any enforcement time spent on the Western Mobile Home Park for the current fiscal year.

If you have any questions regarding this matter, please contact Waldon Wong of my staff at (707) 576-2764 or me at (707) 576-2006.

Sincerely,

Janice M. Thomas, P.E., Sonoma District Engineer
Division of Drinking Water
STATE WATER RESOURCES CONTROL BOARD

Enclosures

CC (w/ Enclosures): Tim Ehlert, P.O. Box 176, Sebastopol, CA 95473

FELICIA MARCUS, CHAIR | THOMAS HOWARD, EXECUTIVE DIRECTOR

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

STATE OF CALIFORNIA
WATER RESOURCES CONTROL BOARD
DIVISION OF DRINKING WATER

Name of Public Water System: Western Mobile Home Park

Water System No: 4900791

To: Scott Evans
871 38th Avenue
Santa Cruz, CA 95062

Issued: August 27, 2014

**CITATION FOR NONCOMPLIANCE
WITH CIS-1,2-DICHLOROETHYLENE AND TRICHLOROETHYLENE
MONITORING AND REPORTING
SECOND QUARTER 2014**

The Division of Drinking Water of the State of California Water Resources Control Board (Division) hereby issues a citation to the Western Mobile Home Park (hereinafter System) for failure to comply with Title 22, California Code of Regulations (CCR) Sections 64445.1(c)(5)(B) and 64469(a).

Section 116650 of the California Health and Safety Code (CHSC), authorizes the issuance of a citation for failure to comply with a requirement



1 of California Safe Drinking Water Act (CHSC, Division 104, Part 12, Chapter
2 4, commencing with Section 116270), or any regulation, standard, permit or
3 order issued thereunder. A copy of the *Applicable Statutes and Regulations*
4 is located in Appendix 1, which is attached hereto and incorporated by
5 reference.
6

7
8 **STATEMENT OF FACTS**

9 Western Mobile Home Park is classified as a community water system
10 serving a population 225 through 73 service connections.
11

12 The Division received monitoring results for trichloroethylene from Well 02 of
13 1.8 micrograms per liter (ug/L) in October 1999. By letter dated December
14 9, 2004, the System was notified of the requirement to commence quarterly
15 trichloroethylene monitoring for Well 02.
16

17
18 The Division received monitoring results for cis-1,2-dichloroethylene from
19 Well 02 of 0.53 ug/L in September 2011. By letter dated November 3, 2011,
20 the System was notified of the requirement to commence quarterly cis-1,2-
21 dichloroethylene monitoring for Well 02.
22

23
24 According to Sections 64445.1 and 64469, the System is required to collect
25 one cis-1,2-dichloroethylene and trichloroethylene sample per quarter from
26 Well 02 and report the findings to the Division database. As of the date of
27 this Citation, the Division has not received results for a quarterly cis-1,2-



1 dichloroethylene or trichloroethylene collected from Well 02 of the Western
2 Mobile Home Park during the Second Quarter 2014.

3
4 **DETERMINATIONS**

5 The System violated Title 22, CCR, Sections 64445.1 and 64469, Monitoring
6 and Compliance – Organic Chemicals and Reporting Requirements.
7 Section 64445.1 defines a violation of monitoring as collecting fewer than
8 the minimum number of required samples. Section 64469 defines a
9 violation of reporting after the tenth day of the following month.
10

11
12 The System took fewer than the minimum number of required samples and
13 did not report the findings, if any, to the Division during Second Quarter
14 2014. Therefore, the System violated the monitoring and reporting of cis-
15 1,2-dichloroethylene and trichloroethylene contained in Section 64445.1 and
16 64469.
17

18
19 **DIRECTIVES**

20 Western Mobile Home Park is hereby directed to take the following actions:
21

- 22
- 23 1. Comply with Sections 64445.1 and 64469, Title 22, CCR in all future
24 monitoring periods.
 - 25
 - 26 2. On or before **September 29, 2014**, notify all persons served by the
27 System of the monitoring and reporting violation in conformance with



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

Title 22, Sections 64463.4 and 64465. Appendix 2: Public Notification Template may be used to fulfill this directive.

3. The System shall complete Appendix 3: Compliance Certification. Submit it with a copy of the public notification to the Division on or before **October 10, 2014**.

The Division reserves the right to make such modifications to this Citation, as it may deem necessary to protect public health and safety. Such modifications may be issued as amendments to this Citation and shall be effective upon issuance.

Nothing in this Citation relieves the System of its obligation to meet the requirements of the California Safe Drinking Water Act (CHSC, Division 104, Part 12, Chapter 4, commencing with Section 116270), or any regulation, standard, permit or order issued thereunder.

All submittals required by this Citation shall be submitted to the Division

at the following address: Janice M. Thomas, P.E.
State Water Resources Control Board
Division of Drinking Water
50 D Street, Suite 200
Santa Rosa, CA 95404

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

PARTIES BOUND

This Citation shall apply to and be binding upon the System, its owners, officers, directors, agents, employees, contractors, successors, and assignees.

SEVERABILITY

The directives of this Citation are severable, and the System shall comply with each provision thereof notwithstanding the effectiveness of any provision.

FURTHER ENFORCEMENT ACTION

Division 104, Part 12, Chapter 4, (commencing with Section 116270) of the California Health and Safety Code authorizes the Division to: issue additional citations with assessment of penalties if the System continues to fail to correct a violation identified in a citation; take action to suspend or revoke a permit that has been issued to a public water system if the System has violated applicable law or regulations or has failed to comply with orders of the Division; and petition the superior court to take various enforcement measures against a public water system that has failed to comply with orders of the Division. The Division does not waive any further enforcement action by issuance of this citation.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

Janice M. Thomas

August 27, 2014

Janice M. Thomas, P.E., Sonoma District Engineer
Division of Drinking Water
STATE WATER RESOURCES CONTROL BOARD

Date



Appendices (3):

1. Applicable Statutes and Regulations
2. Public Notification Template
3. Compliance Certification

Certified Mail No. 7012 3460 0002 6459 4607

4900791/Compliance
02-18-14C-028-4900791-03.docx/WWW

**APPENDIX 1. APPLICABLE STATUTES AND REGULATIONS
FOR CITATION NO. 02-18-14C-028**

Section 116650 of the CHSC states in relevant part:

- (a) If the department determines that a public water system is in violation of this chapter or any regulation, permit, standard, citation, or order issued or adopted thereunder, the department may issue a citation to the public water system. The citation shall be served upon the public water system personally or by certified mail. Service shall be deemed effective as of the date of personal service or the date of receipt of the certified mail. If a person to whom a citation is directed refuses to accept delivery of the certified mail, the date of service shall be deemed to be the date of mailing.
- (b) Each citation shall be in writing and shall describe the nature of the violation or violations, including a reference to the statutory provision, standard, order, citation, permit, or regulation alleged to have been violated.
- (c) A citation may specify a date for elimination or correction of the condition constituting the violation.
- (d) A citation may include the assessment of a penalty as specified in subdivision (e).
- (e) The department may assess a penalty in an amount not to exceed one thousand dollars (\$1,000) per day for each day that a violation occurred, and for each day that a violation continues to occur. A separate penalty may be assessed for each violation.

California Code of Regulations (CCR), Section 64444 Table 64444-A states in relevant part:

Table 64444-A
Maximum Contaminant Levels
Organic Chemicals

<i>Chemical</i>	<i>Maximum Contaminant Level, mg/L</i>
cis-1,2-dichloroethylene.....	0.006
trichloroethylene	0.005

California Code of Regulations (CCR), Section 64445.1 Table 6445.1-A states in relevant part:

Table 64445.1-A
Detection Limits for Purposes of Reporting (DLRs)
For Regulated Organic Chemicals

<i>Chemical</i>	<i>Detection Limit for Purposes of Reporting (DLR) (mg/L)</i>
(a) All VOCs, except as listed.....	0.0005

California Code of Regulations (CCR), Section 64445.1 states in relevant part:

- (c) When organic chemicals are detected pursuant to Table 64445.1-A.
 - (5) If the detected level of an organic chemical for any sampling site exceeds that listed in Table 64444-A, the water supplier shall report this information to the Department within 48 hours of receipt of the result. Unless use of the contaminated source is discontinued, the water supplier shall resample the contaminated source and compliance shall be determined as follows:
 - (B) Water systems serving 3,300 persons or less shall sample quarterly for a minimum of one year and shall submit the results to the Department as specified in §64469.

California Code of Regulations (CCR), Section 64469 states in relevant part:

- (a) Analytical results of all sample analyses completed in a calendar month shall be reported to the Department no later than the tenth day of the following month.

California Code of Regulations (CCR), Section 64463.4 states in relevant part:

- (c) A water system shall deliver the notice, in a manner designed to reach person served, within the required time period as follows:
 - (1) Unless otherwise directed by the Department in writing based on its assessment of the violation or occurrence and the potential for adverse effects on public health and welfare, community water systems shall give public notice by:
 - (A) Mail or direct delivery to each customer receiving a bill including those that provide their drinking water to others (e.g., schools or school systems, apartment building owners, or large private employers), and other service connections to which water is delivered by the water system; and
 - (B) Use of one or more of the following methods to reach persons not likely to be reached by a mailing or direct delivery (renters, university students, nursing home patients, prison inmates, etc.):
 - 1. Publication in a local newspaper;
 - 2. Posting in conspicuous public places served by the water system, or on the Internet; or
 - 3. Delivery to community organizations.

California Code of Regulations (CCR), Section 64465 states in relevant part:

- (a) Each public notice given pursuant to this article, except Tier 3 public notices for variances and exemptions pursuant to subsection (b), shall contain the following:
 - (1) A description of the violation or occurrence, including the contaminant(s) of concern, and (as applicable) the contaminant level(s);
 - (2) The date(s) of the violation or occurrence;
 - (3) Any potential adverse health effects from the violation or occurrence;
 - (4) The population at risk, including subpopulations particularly vulnerable if exposed to the contaminant in drinking water;
 - (5) Whether alternative water supplies should be used;
 - (6) What actions consumers should take, including when they should seek medical help, if known;
 - (7) What the water system is doing to correct the violation or occurrence;
 - (8) When the water system expects to return to compliance or resolve the occurrence;
 - (9) The name, business address, and phone number of the water system owner, operator, or designee of the water system as a source of additional information concerning the public notice;
 - (10) A statement to encourage the public notice recipient to distribute the public notice to other persons served, using the following standard language: "Please share this information with all the other people who drink this water, especially those who may not have received this public notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail."; and
 - (11) A water system with a monitoring and testing procedure violation, this language shall be included: "We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During [*compliance period dates*], we [*'did not monitor or test'* or *'did not*

complete all monitoring or testing' for [contaminant(s)], and therefore, cannot be sure of the quality of your drinking water during that time."

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Western Mobile Home Park Failed to Test for cis-1,2-dichloroethylene and trichloroethylene – Second Quarter 2014

We failed to test the drinking water for cis-1,2-dichloroethylene and trichloroethylene during the second quarter 2014. Although this is not an emergency, as our customers, you have a right to know about this violation – what happened, what you should do, and what we did to correct the situation. Please share this information with other people who drink this water, especially those who may not have received this notice directly. You can do this by posting this notice in a public place or giving out copies by hand or mail.

What happened?

We are required by state regulations to monitor our drinking water for specific contaminants on a regular basis. Results of this routine monitoring are an indicator of whether or not the drinking water meets health standards. During April/May/June 2014, we did not test for cis-1,2-dichloroethylene and trichloroethylene and, therefore, cannot be sure of the quality of the drinking water during that time.

What does this mean?

The California Department of Public Health (CDPH) sets drinking water standards and has determined that cis-1,2-dichloroethylene and trichloroethylene pose a chronic health concern at high levels of exposure. Some people who drink water containing cis-1,2-dichloroethylene in excess of the MCL over many years may experience liver problems. Some people who drink water containing trichloroethylene in excess of the MCL over many years may experience liver problems and may have an increased risk of getting cancer. Quarterly chemical sampling is important to periodically verify the quality of your drinking water.

What should I do?

You do not need to take any corrective actions. This is not an emergency. If you have health concerns, you may wish to consult your doctor. General guidelines on cis-1,2-dichloroethylene and trichloroethylene are available from EPA's Safe Drinking Water Hotline at (800) 426-4791.

What corrective actions have been taken to prevent this violation from occurring in the future?

This notification of the public is being done in compliance with Sections 64463.4 and 64465, Title 22 of the CCR as a means of keeping the public informed.

Persons wishing more information should contact:

(name)

(address)

(phone number)

APPENDIX 3. COMPLIANCE CERTIFICATION

Citation Number 02-18-14C-028

Name of Water System: **Western Mobile Home Park**

System Number: **4900791**

I certify that the users of the water supplied by this water system were notified of the monitoring and reporting violations of Title 22, California Code of Regulations (CCR), Sections 64445.1 and 64469 for the compliance period of second quarter 2014 and that the following actions, as directed in 02-18-14C-028 have been completed.

<u>Required Action</u>	<u>Date Completed</u>
(Citation Directive 2) Public Notification – Continuous Posting for 7 Days and Other Notification Methods completed.	

Signature of Water System Representative

Date

Attach a copy of the notice posted in the system and a copy published via other notification methods.

**THIS FORM MUST BE COMPLETED AND RETURNED TO THE DIVISION NO LATER THAN
OCTOBER 10, 2014**

Disclosure: Be advised that Section 116725 and 116730 of the California Health and Safety Code states that any person who knowingly makes any false statement on any report or document submitted for the purpose of compliance with the attached order may be liable for a civil penalty not to exceed five thousand dollars (\$5,000) for each separate violation for each day that violation continues. In addition, the violators may be prosecuted in criminal court and upon conviction, be punished by a fine of not more than \$25,000 for each day of violation, or be imprisoned in county jail not to exceed one year, or by both the fine and imprisonment.