



EDMUND G. BROWN JR.
GOVERNOR



MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board

Division of Drinking Water

Water System No. 4900532

March 19, 2015

Steve Urbanek
Sonoma CSA 41 - Jenner
2300 County Center Drive – Suite B100
Santa Rosa, CA 95403

CITATION NO. 02-18-15C-012 DISINFECTION BYPRODUCTS MAXIMUM CONTAMINANT LEVEL VIOLATION FOR FOURTH QUARTER 2014

Enclosed is a Citation issued to the Sonoma CSA 41 - Jenner (System) public water system.

Sonoma CSA 41 - Jenner will be billed at the State Water Resources Control Board Division of Drinking Water's (Division) hourly rate (currently estimated at \$128.00) for the time spent on issuing this Citation. Health and Safety Code Section 116577 provides that a public water system must reimburse the Division for actual costs incurred by the Division for specified enforcement actions, including, but not limited to, preparing, issuing, and monitoring compliance with a citation. At this time, the Division has spent approximately one hour on enforcement activities associated with this violation.

Sonoma CSA 41 – Jenner will receive a bill sent from our Division Fee Billing Unit in August of the next fiscal year. This bill will contain any fees for any enforcement time spent on the Sonoma CSA 41 - Jenner for the current fiscal year.

If you have any questions regarding this matter, please contact George Chien of my staff at (707) 576-2971 or me at (707) 576-2006.

Sincerely,

Janice M. Thomas, P.E., Sonoma District Engineer
Division of Drinking Water
STATE WATER RESOURCES CONTROL BOARD

Enclosure: Citation No. 02-18-15C-012

c: Hal Wood, P.O. Box 730, Forestville, CA 95436 (w enclosure)

FELICIA MARCUS, CHAIR | THOMAS HOWARD, EXECUTIVE DIRECTOR

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

STATE OF CALIFORNIA
WATER RESOURCES CONTROL BOARD
DIVISION OF DRINKING WATER

Name of Public Water System: Sonoma CSA 41 – Jenner

Water System No: 4900532

To: Steve Urbanek
2300 County Center Drive – Suite B100
Santa Rosa, CA 95403

Physical Location: Jenner, California 95450

Issued: March 19, 2015

CITATION FOR NONCOMPLIANCE
WITH DISINFECTION BYPRODUCTS MAXIMUM CONTAMINANT LEVEL
FOURTH QUARTER 2014
AND
PERMIT 02-18-14P-4900532

The Division of Drinking Water of the State of California Water Resources Control Board (Division) hereby issues a citation to the Sonoma CSA 41 – Jenner (hereinafter System) for failure to comply with Title 22, California



1 Code of Regulations (CCR) Sections 64533, 64535.2, and Permit No. 02-
2 18-14P-4900532.

3
4 Section 116650 of the California Health and Safety Code (CHSC),
5 authorizes the issuance of a citation for failure to comply with a requirement
6 of California Safe Drinking Water Act (CHSC, Division 104, Part 12, Chapter
7 4, commencing with Section 116270), or any regulation, standard, permit or
8 order issued thereunder. A copy of the *Applicable Statutes and Regulations*
9 is located in Appendix 1, which is attached hereto and incorporated by
10 reference.
11

12
13 **STATEMENT OF FACTS**

14
15 Sonoma CSA 41 – Jenner is classified as a community water system
16 serving a population of 250 through approximate 122 service connections.

17 Sonoma CSA 41 – Jenner uses disinfection with sodium hypochlorite.
18

19 A domestic water supply permit, Permit No. 02-18-14P-4900532, was issued
20 to the System on May 27, 2014. Provision 14 requires the System to operate
21 in accordance with the following criterion:
22

- 23 14. All water supplied by Sonoma County CSA 41 – Jenner for domestic
24 purposes shall meet all Maximum Contaminant Levels (MCLs)
25 established by the California Department of Public Health.
26
27



1 The Division received quarterly monitoring results for total trihalomethanes
2 (TTHM) and haloacetic acids (five) (HAA5) collected in December 2014 at
3 the monitoring location, 11054 Burke Avenue, of 0.170 milligrams per liter
4 (mg/L) and 0.160 mg/L, respectively. The locational running annual average
5 (LRAA) of TTHM and HAA5 for fourth quarter 2014 was computed as 0.101
6 mg/L and 0.074 mg/L, respectively.
7

8
9 **DETERMINATIONS**

10 The Division has determined that the System is in violation of Title 22, CCR,
11 Section 64533 and 64535.2, and Permit No. 02-18-14P-4900532. Section
12 64533 defines the MCLs of TTHM and HAA5 as 0.080 mg/L and 0.060
13 mg/L, respectively. Section 64535.2 defines the computation of the LRAA
14 and defines a violation of when LRAA concentration exceeds the MCL.
15

16
17 The TTHM LRAA of fourth quarter 2014 was computed as 0.101 mg/L and
18 the HAA5 LRAA of fourth quarter 2014 was computed as 0.074 mg/L.
19 Therefore, the System violated the MCL contained in Section 64533 and
20 64535.2 in fourth quarter 2014.
21

22
23 **DIRECTIVES**

24 Sonoma CSA 41 – Jenner is hereby directed to take the following actions:
25
26
27



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

1. Comply with Sections 64533 and 64535.2, Title 22, CCR and Permit No. 02-18-14P-4900532 in all future monitoring periods.

2. On or before **April 20, 2015**, notify all persons served by the System of the monitoring and reporting violation in conformance with Title 22, Sections 64463.4 and 64465. Appendix 2: Public Notification Template may be used to fulfill this directive. The public notification and Compliance Certification shall be performed quarterly until the System is no longer in violation of TTHM or HAA5 MCL.

3. The System shall conduct operational evaluation in conformance with Title 22, Section 64534.2(d)(6). The System shall complete and submit Appendix 3: Operational Evaluation to the Division on or before **June 19, 2015**.

4. The System shall complete Appendix 4: Compliance Certification. Submit it with a copy of the public notification to the Division on or before **June 29, 2015**.

The Division reserves the right to make such modifications to this Citation, as it may deem necessary to protect public health and safety. Such modifications may be issued as amendments to this Citation and shall be effective upon issuance.



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

Nothing in this Citation relieves the System of its obligation to meet the requirements of the California Safe Drinking Water Act (CHSC, Division 104, Part 12, Chapter 4, commencing with Section 116270), or any regulation, standard, permit or order issued thereunder.

All submittals required by this Citation shall be submitted to the Division at the following address: Janice M. Thomas, P.E.
State Water Resources Control Board
Division of Drinking Water
50 D Street, Suite 200
Santa Rosa, CA 95404

PARTIES BOUND

This Citation shall apply to and be binding upon the System, its owners, officers, directors, agents, employees, contractors, successors, and assignees.

SEVERABILITY

The directives of this Citation are severable, and the System shall comply with each provision thereof notwithstanding the effectiveness of any provision.

FURTHER ENFORCEMENT ACTION

Division 104, Part 12, Chapter 4, (commencing with Section 116270) of the California Health and Safety Code authorizes the Division to: issue additional citations with assessment of penalties if the System continues to fail to correct a violation identified in a citation; take action to suspend or revoke a permit that has been issued to a public water system if the System has violated applicable law or regulations or has failed to comply with orders of the Division; and petition the superior court to take various enforcement measures against a public water system that has failed to comply with orders of the Division. The Division does not waive any further enforcement action by issuance of this citation.

Janice M. Thomas

March 19, 2015

Janice M. Thomas, P.E., Sonoma District Engineer

Date

Division of Drinking Water

STATE WATER RESOURCES CONTROL BOARD

Appendices (4):

1. Applicable Statutes and Regulations
2. Public Notification Template
3. Operational Evaluation
4. Compliance Certification



Certified Mail No. 7013 2250 0000 5448 3422

4900532/Compliance
02-18-15C-012-4900532-02 /GC



**APPENDIX 1. APPLICABLE STATUTES AND REGULATIONS
FOR CITATION NO. 02-18-15C-012**

Section 116650 of the CHSC states in relevant part:

- (a) If the department determines that a public water system is in violation of this chapter or any regulation, permit, standard, citation, or order issued or adopted thereunder, the department may issue a citation to the public water system. The citation shall be served upon the public water system personally or by certified mail. Service shall be deemed effective as of the date of personal service or the date of receipt of the certified mail. If a person to whom a citation is directed refuses to accept delivery of the certified mail, the date of service shall be deemed to be the date of mailing.
- (b) Each citation shall be in writing and shall describe the nature of the violation or violations, including a reference to the statutory provision, standard, order, citation, permit, or regulation alleged to have been violated.
- (c) A citation may specify a date for elimination or correction of the condition constituting the violation.
- (d) A citation may include the assessment of a penalty as specified in subdivision (e).
- (e) The department may assess a penalty in an amount not to exceed one thousand dollars (\$1,000) per day for each day that a violation occurred, and for each day that a violation continues to occur. A separate penalty may be assessed for each violation.
- (f) continues to occur. A separate penalty may be assessed for each violation.

California Code of Regulations (CCR), Section 64533 states in relevant part:

- (a) Using the monitoring and calculation methods specified in sections 64534, 64534.2, 64535, and 64535.2, the primary MCLs for the disinfection byproducts shown in table 64533-A shall not be exceeded in drinking water supplied to the public.

**Table 64533-A
Maximum Contaminant Levels and Detection Limits for Purposes of Reporting
Disinfection Byproducts**

Disinfection Byproduct	Maximum Contaminant Level (mg/L)
Total trihalomethanes (TTHM)	0.080
Haloacetic acids (five) (HAA5)	0.060

California Code of Regulations (CCR), Section 64534.2(d) states in relevant part:

- (6) If the operational evaluation level (OEL) exceeds 0.080 mg/L for TTHM or 0.060 mg/L for HAA5 at any monitoring location, systems shall conduct an operational evaluation. The operational evaluation shall include the examination of system treatment and distribution operational practices, including storage tank operations, excess storage capacity, distribution system flushing, changes in sources or source water quality, and treatment changes or problems that may contribute to TTHM and HAA5 formation and what steps could be considered to minimize future exceedances. Systems that are able to identify the cause of the OEL exceedance may submit a written request to the Department to limit the scope of the evaluation.

California Code of Regulations (CCR), Section 64535.2 states in relevant part:

- (e) TTHM and HAA5 MCL compliance, as monitored pursuant to section 64534.2(d), shall be determined as follows:
 - (1) For systems monitoring quarterly, each locational running annual average (LRAA), computed quarterly, shall not exceed the MCLs specified in section 64533;
 - (3) If a system fails to complete four consecutive quarters of monitoring, compliance with the MCL for the last four-quarter compliance period shall be based on an average of the available data. If more than one sample per quarter is taken at a monitoring location, all the samples taken in the quarter at that monitoring location shall be averaged to determine a quarterly average to be used in the LRAA calculation; and
 - (4) If the LRAA exceeds the MCL, calculated based on four consecutive quarters of monitoring (or the LRAA calculated based on fewer than four quarters of data if the MCL would be exceeded regardless of the monitoring results of subsequent quarters), the system is in violation of the MCL and shall notify the public pursuant to sections 64463, 64463.4, and 64465, including the language in appendix 64465-G, in addition to reporting to the Department pursuant to sections 64537 through 64537.6.

California Code of Regulations (CCR), Section 64537 states in relevant part:

- (d) Systems required to conduct an operational evaluation pursuant to section 64534.2(d)(6) shall submit a written report of the evaluation to the Department no later than 90 days after being notified of the analytical result that caused the OEL exceedance. Systems shall make the written report available to the public upon request. If the Department approves the system's written request to limit the scope of the evaluation under section 64534.2(d)(6), the system shall keep the written approval with the completed report.

California Code of Regulations (CCR), Section 64463.4 states in relevant part:

- (a) A water system shall give public notice pursuant to this section if any of the following occurs:
 - (3) Other violations of the monitoring and testing procedure requirements in this chapter, and chapters 15.5, 17 and 17.5, for which the Department determines that a Tier 2 rather than a Tier 3 public notice is required, based on potential health impacts and persistence of the violations;
- (b) A water system shall give the notice as soon as possible within 30 days after it learns of a violation or occurrence specified in subsection (a), except that the water system may request an extension of up to 60 days for providing the notice. This extension would be subject to the Department's written approval based on the violation or occurrence having been resolved and the Department's determination that public health and welfare would in no way be adversely affected. In addition, the water system shall:
 - (1) Maintain posted notices in place for as long as the violation or occurrence continues, but in no case less than seven days;
 - (2) Repeat the notice every three months as long as the violation or occurrence continues. Subject to the Department's written approval based on its determination that public health would in no way be adversely affected, the water system may be allowed to notice less frequently but in no case less than once per year.

- (c) A water system shall deliver the notice, in a manner designed to reach person served, within the required time period as follows:
- (1) Unless otherwise directed by the Department in writing based on its assessment of the violation or occurrence and the potential for adverse effects on public health and welfare, community water systems shall give public notice by:
 - (A) Mail or direct delivery to each customer receiving a bill including those that provide their drinking water to others (e.g., schools or school systems, apartment building owners, or large private employers), and other service connections to which water is delivered by the water system; and
 - (B) Use of one or more of the following methods to reach persons not likely to be reached by a mailing or direct delivery (renters, university students, nursing home patients, prison inmates, etc.):
 1. Publication in a local newspaper;
 2. Posting in conspicuous public places served by the water system, or on the Internet; or
 3. Delivery to community organizations.

California Code of Regulations (CCR), Section 64465 states in relevant part:

- (a) Each public notice given pursuant to this article, except Tier 3 public notices for variances and exemptions pursuant to subsection (b), shall contain the following:
 - (1) A description of the violation or occurrence, including the contaminant(s) of concern, and (as applicable) the contaminant level(s);
 - (2) The date(s) of the violation or occurrence;
 - (3) Any potential adverse health effects from the violation or occurrence, including the appropriate standard health effects language from appendices 64465-A through G;
 - (4) The population at risk, including subpopulations particularly vulnerable if exposed to the contaminant in drinking water;
 - (5) Whether alternative water supplies should be used;
 - (6) What actions consumers should take, including when they should seek medical help, if known;
 - (7) What the water system is doing to correct the violation or occurrence;
 - (8) When the water system expects to return to compliance or resolve the occurrence;
 - (9) The name, business address, and phone number of the water system owner, operator, or designee of the water system as a source of additional information concerning the public notice;
 - (10) A statement to encourage the public notice recipient to distribute the public notice to other persons served, using the following standard language: —Please share this information with all the other people who drink this water, especially those who may not have received this public notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.¶; and
 - (11) For a water system with a monitoring and testing procedure violation, this language shall be included: —We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards. During [compliance period dates], we [_did not monitor or test' or _did not complete all monitoring or testing'] for [contaminant(s)], and therefore, cannot be sure of the quality of your drinking water during that time.
- (c) A public water system providing notice pursuant to this article shall comply with the following multilingual-related requirements:
 - (2) For a Tier 2 or Tier 3 public notice:
 - (A) The notice shall contain information in Spanish regarding the importance of the notice, or contain a telephone number or address where Spanish-speaking residents may contact the public water system to obtain a translated copy of the notice or assistance in Spanish; and

- (B) When a non-English speaking group other than Spanish-speaking exceeds 1,000 residents or 10 percent of the residents served by the public water system, the notice shall include:
1. Information in the appropriate language(s) regarding the importance of the notice; or
 2. A telephone number or address where such residents may contact the public water system to obtain a translated copy of the notice or assistance in the appropriate language; and

- (d) Each public notice given pursuant to this article shall:
- (1) Be displayed such that it catches people's attention when printed or posted and be formatted in such a way that the message in the public notice can be understood at the eighth-grade level;
 - (2) Not contain technical language beyond an eighth-grade level or print smaller than 12 point; and
 - (3) Not contain language that minimizes or contradicts the information being given in the public notice.

**Appendix 64465-G. Health Effects Language
Disinfection Byproducts, Byproduct Precursors, and Disinfectant Residuals**

<i>Contaminant</i>	<i>Health Effects Language</i>
TTHMs [Total Trihalomethanes]:	Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience liver, kidney, or central nervous system problems, and may have an increased risk of getting cancer.
Haloacetic Acids	Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este Informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

**Sonoma County CSA 41 - Jenner Has Levels of
Disinfection Byproducts Above Drinking Water Standard**

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what you should do, what happened, and what we did to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Water sample results collected in 2014 showed that the locational running annual average of total trihalomethanes (TTHM) level was 0.101 milligrams per liter (mg/L) and haloacetic acids (five) (HAA5) level was 0.074 mg/L. This is above the standard, or maximum contaminant level (MCL), of 0.080 mg/L for TTHM and 0.060 mg/L for HAA5.

What should I do?

- **You do not need to boil your water or take other corrective actions.**
- This is not an emergency. If it had been, you would have been notified immediately. However, *Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience liver, kidney, or central nervous system problems, and may have an increased risk of getting cancer. Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.*
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What was done?

To protect drinking water from disease-causing organisms, or pathogens, a disinfectant is added to drinking water. However, disinfection byproducts can form when organic-rich water is disinfected. A major challenge is how to control and limit risks from pathogens and minimize disinfection byproduct formation at the same time. Disinfection byproducts tend to be highest during periods of long detention times in storage tanks. As a result of disinfection requirements, we have exceeded the MCL of TTHM and HAA5.

[Describe corrective action].

For more information, please contact Steve Urbanek at (707) 565-3884.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS** (including nursing homes and care facilities): Must notify tenants.
- **BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS:** Must notify employees of businesses located on the property.

This notice is being sent to you by Sonoma County CSA 41 – Jenner.

State Water System ID#: 4900532 . Date distributed: _____.