



EDMUND G. BROWN JR.  
GOVERNOR



MATTHEW RODRIGUEZ  
SECRETARY FOR  
ENVIRONMENTAL PROTECTION

## State Water Resources Control Board

Division of Drinking Water

Water System No. 2100576

October 30, 2015

Tal Roseberry  
Piezzi Building  
P.O. Box 96  
Tomales, CA 94971

### CITATION NO. 02\_18\_15C\_057

### TOTAL COLIFORM MAXIMUM CONTAMINANT LEVEL (MCL) VIOLATION FOR SEPTEMBER 2015

Enclosed is a Citation issued to the Piezzi Building (System) public water system.

Piezzi Building will be billed at the State Water Resources Control Board Division of Drinking Water's (Division) hourly rate (currently estimated at \$128.00) for the time spent on issuing this Citation. Health and Safety Code Section 116577 provides that a public water system must reimburse the Division for actual costs incurred by the Division for specified enforcement actions, including, but not limited to, preparing, issuing, and monitoring compliance with a citation. At this time, the Division has spent approximately one hour on enforcement activities associated with this violation.

The System will receive a bill from the Division in August of the next fiscal year. This bill will contain fees for any enforcement time spent on the System for the current fiscal year.

If you have any questions regarding this matter, please contact Cindi Lee of my staff at (707) 576-2422 or me at (707) 576-2006.

Sincerely,

A handwritten signature in blue ink that reads "Janice M. Thomas".

Janice M. Thomas, P.E., Sonoma District Engineer  
Division of Drinking Water  
STATE WATER RESOURCES CONTROL BOARD

Enclosures

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27

STATE OF CALIFORNIA  
WATER RESOURCES CONTROL BOARD  
DIVISION OF DRINKING WATER

**Name of Public Water System:** Piezzi Building

**Water System No:** 2100576

**To:** Piezzi Building  
P.O. Box 96  
Tomales, CA 94971

**Issued:** October 30, 2015

**CITATION FOR NONCOMPLIANCE  
WITH TOTAL COLIFORM MAXIMUM CONTAMINANT LEVEL  
SEPTEMBER 2015**

The Division of Drinking Water of the State of California Water Resources Control Board (Division) hereby issues a citation to the Piezzi Building (hereinafter System) for failure to comply with Title 22, California Code of Regulations (CCR) Section 64426.1.

Section 116650 of the California Health and Safety Code (CHSC), authorizes the issuance of a citation for failure to comply with a requirement of California Safe Drinking Water Act (CHSC, Division 104, Part 12, Chapter 4, commencing with Section 116270), or any regulation, standard, permit or

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27

order issued thereunder. A copy of the *Applicable Statues and Regulations* is located in Appendix 1, which is attached hereto and incorporated by reference.

**STATEMENT OF FACTS**

Piezzi Building is classified as a transient - noncommunity water system with 3 connections serving a population of 100. The Division received laboratory results for nine bacteriological samples collected during September 2015 from the System. All samples were analyzed for the presence of coliform bacteria and *E. coli* where four of the nine samples tested positive for coliform bacteria. None of the samples tested positive for *E. coli*.

**DETERMINATION**

The Division has determined that the System is in violation of Title 22, CCR, Section 64426.1, Total Coliform Maximum Contaminant Level. Section 64426.1(b)(2) defines a violation of the total coliform MCL as more than one sample collected during any month is total coliform-positive.

The System took fewer than 40 bacteriological samples during September 2015. The results of four were total coliform positive. Therefore, the System violated the total coliform maximum contaminant level contained in Section 64426.1 in September 2015.

**DIRECTIVES**

Piezzi Building is hereby directed to take the following actions:

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27

1. Comply with Section 64426.1, Title 22, CCR in all future monitoring periods.
2. On or before **November 27, 2015**, notify all persons served by the System of the MCL violation in conformance with Title 22, CCR, Sections 64463.4 and 64465. Appendix 2: Public Notification Template may be used to fulfill this directive.
3. Pursuant to Title 22, CCR, Section 64424(d), the System shall collect five (5) routine bacteriological samples on or before **November 20, 2015**.
4. The System shall complete Appendix 3: Compliance Certification. Submit it together with a copy of the public notification and the laboratory results from sampling required in Directive 3 to the Division on or before **December 11, 2015**.
5. The System shall submit to the Division the information described in Title 22, CCR, Section 64426(b)(2) on or before **December 11, 2015**. Appendix 4: Positive Total Coliform Investigation, which is attached to this document, may be used to fulfill this directive.

The Division reserves the right to make such modifications to this Citation, as it may deem necessary to protect public health and safety. Such

1 modifications may be issued as amendments to this Citation and shall be  
2 effective upon issuance.

3  
4 Nothing in this Citation relieves the System of its obligation to meet the  
5 requirements of the California Safe Drinking Water Act (CHSC, Division 104,  
6 Part 12, Chapter 4, commencing with Section 116270), or any regulation,  
7 standard, permit or order issued thereunder.  
8

9  
10 All submittals required by this Citation shall be submitted to the Division

11 at the following address: Janice M. Thomas, P.E.  
12 State Water Resources Control Board  
13 Division of Drinking Water  
14 50 D Street, Suite 200  
15 Santa Rosa, CA 95404

16 **PARTIES BOUND**

17 This Citation shall apply to and be binding upon the System, its owners,  
18 officers, directors, agents, employees, contractors, successors, and  
19 assignees.  
20

21 **SEVERABILITY**

22 The directives of this Citation are severable, and the System shall comply  
23 with each provision thereof notwithstanding the effectiveness of any  
24 provision.  
25  
26  
27



