



EDMUND G. BROWN JR.
GOVERNOR



MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board

Division of Drinking Water

April 28, 2016
Certified Mail/Return
7012 3460 0003 1112 7659

Central Gaither School
750 Palora Ave
Yuba City, CA 95993-9706

Attention: Thomas Butcher, Director of Maintenance

RE: Central Gaither School, Public Water System No. 5100150 – Citation No. 21-16C-014 for Exceedance of the Bacteriological Maximum Contaminant Level in April of 2016.

Enclosed is a citation issued to the Central Gaither School (Water System). The citation is being issued because the Water System failed to achieve the drinking water standard for total coliform bacteria during April of 2016. Please read this citation carefully. Public notification is required to inform consumers that the standard was not achieved during this time period.

Note that Section 116577 of the California Safe Drinking Water Act provides for the Division to be reimbursed by the Water System for costs incurred for preparing and issuing a citation. In accordance with Section 116577, the Water System will be billed for the preparation and issuance of this citation.

If you have any questions regarding this matter, please call Paul Rowe at (530) 224-4866 or me at (530) 224-4861.

Sincerely,

A handwritten signature in black ink, appearing to read "R. Crenshaw".

Reese B. Crenshaw, P.E.
Valley District Engineer
Drinking Water Field Operations Branch

Enclosures

FELICIA MARCUS, CHAIR | THOMAS HOWARD, EXECUTIVE DIRECTOR

364 Knollcrest Drive, Suite 101, Redding, CA 96002 | www.waterboards.ca.gov

1 **Citation No. 21-16C-014**

2

3

STATE OF CALIFORNIA

4

WATER RESOURCES CONTROL BOARD

5

DIVISION OF DRINKING WATER

6

7 **Public Water System:** Central Gaither School

8

Water System No.: 5100150

9

10

To: Central Gaither School

11

Attn: Thomas Butcher, Director of Maintenance

12

750 Palora Ave

13

Yuba City, CA 95993-9706

14

15

Issued: April 28, 2016

16

VIA CERTIFIED MAIL

17

18

CITATION FOR NONCOMPLIANCE

19

With Title 22 California Code of Regulations

20

Section 64426.1(b)

21

22

Section 116650 of the California Health and Safety Code (CHSC) authorizes the

23

issuance of a citation for failure to comply with a requirement of the California Safe

24

Drinking Water Act (CHSC, Division 104, Part 12, Chapter 4, commencing with

25

Section 116270), or any regulation, standard, permit, or order issued thereunder.

26

1 The State Water Resources Control Board (hereinafter "State Board"), acting by and
2 through its Division of Drinking Water (hereinafter "Division") and the Deputy Director
3 for the Division, hereby issues a citation to Central Gaither School for failure to
4 comply with Section 64426.1 (b), Title 22, of the California Code of Regulations
5 (CCR).

6
7 **APPLICABLE AUTHORITIES**

8 Section 116650 of the CHSC states:

9
10 *(a) If the Department determines that a public water system is in*
11 *violation of this chapter or any regulation, permit, standard, citation,*
12 *or order issued or adopted thereunder, the department may issue a*
13 *citation to the public water system. The citation shall be served*
14 *upon the public water system personally or by certified mail. Service*
15 *shall be deemed effective as of the date of personal service or the*
16 *date of receipt of the certified mail. If a person to whom a citation is*
17 *directed refuses to accept delivery of the certified mail, the date of*
18 *service shall be deemed to be the date of mailing.*

19
20 *(b) Each citation shall be in writing and shall describe the nature of the*
21 *violation or violations, including a reference to the statutory*
22 *provision, standard, order, citation, permit, or regulation alleged to*
23 *have been violated.*

24
25 *(c) A citation may specify a date for elimination or correction of the*
26 *condition constituting the violation.*
27

1 (d) A citation may include the assessment of a penalty as specified in
2 subdivision (e).

3
4 (e) The department may assess a penalty in an amount not to exceed
5 one thousand dollars (\$1,000) per day for each day that a violation
6 occurred, and for each day that a violation continues to occur. A
7 separate penalty may be assessed for each violation.

8
9 Section 64426.1 (b), Title 22, of the CCR states:

10
11 (b) A public water system is in violation of the total coliform maximum
12 contaminant level (MCL) when any of the following occurs:

13
14 (1) For a public water system which collects at least 40 samples
15 per month, more than 5.0 percent of the samples collected
16 during any month are total coliform-positive; or

17
18 (2) For a public water system which collects fewer than 40
19 samples per month, more than one sample collected during
20 any month is total coliform-positive; or

21
22 (3) Any repeat sample is fecal coliform-positive or *E. coli*-
23 positive; or

24
25 (4) Any repeat sample following a fecal coliform-positive or *E.*
26 *coli*-positive routine sample is total coliform-positive.

27

STATEMENT OF FACTS

The Central Gaither School domestic water system (System) is classified as a nontransient noncommunity water system serving approximately 250 persons per day. In accordance with Section 64423 of Title 22, the System is required to collect one routine bacteriological sample per month, unless there was a positive bacteriological sample the previous month, in which case, five routine bacteriological samples are required. On April 22, 2016, the System collected five routine bacteriological samples from the distribution system. As a result, three of the five samples indicated the presence of total coliform bacteria. Although this is the third month in a row that the System has been in violation of the total coliform MCL, the cause of the contamination is still unknown. No samples discussed showed the presence of E. coli.

DETERMINATIONS

The Division has determined that the System violated Section 64426.1(b)(2), Title 22, of the CCR, in that more than one bacteriological sample was positive for total coliform in the month of April 2016; thus exceeding the total coliform MCL.

DIRECTIVES

The System is hereby directed to take the following actions:

1. Comply with Section 64426.1, Title 22, of the CCR in all future monitoring periods.
2. **Within 30 days** of the issuance of this Citation, provide public notification in accordance with **Attachment 'A'**, to all persons served by the System of the

1 MCL violation as required by Section 64463.4 and Section 64465, Title 22, of
2 the CCR.

- 3
- 4 3. Changes and/or modifications to Attachment A shall be not be made unless
5 approved by the Division.
- 6
- 7 4. Complete and return **Attachment 'B'** "Certification of Completion of Public
8 Notification" form **within 10 days** of giving public notice. A copy of the notice
9 used to provide public notification shall be attached to the form.

10

11 The completed and signed copy of Attachment 'B' shall be submitted to the following
12 address:

13

14 Reese B. Crenshaw, P. E.
15 Valley District Engineer
16 Drinking Water Field Operations
17 Division of Drinking Water
18 State Water Resources Control Board
19 364 Knollcrest Drive, Suite 101
20 Redding, CA 96002
21 (530) 224-4800

22

23 Nothing in this Citation relieves the System of its obligation to meet the requirements
24 of Health and Safety Code, Division 104, Part 12, Chapter 4 (California Safe
25 Drinking Water Act), or any regulation, permit, standard or order issued or adopted
26 thereunder.

27

1 The Division reserves the right to make such modifications to this Citation, as it may
2 deem necessary to protect public health and safety. Such modifications may be
3 issued as amendments to this Citation and shall be effective upon issuance.

4 5 **FURTHER ENFORCEMENT ACTION**

6 The California SDWA authorizes the State Board to: issue citation with assessment
7 of administrative penalties to a public water system for violation or continued
8 violation of the requirements of the California SDWA or any permit, regulation,
9 permit or order issued or adopted thereunder including, but not limited to, failure to
10 correct a violation identified in a citation or compliance order. The California SDWA
11 also authorizes the State Board to take action to suspend or revoke a permit that
12 has been issued to a public water system if the system has violated applicable law
13 or regulations or has failed to comply with an order of the State Board; and to
14 petition the superior court to take various enforcement measures against a public
15 water system that has failed to comply with violates an order of the State Board. The
16 State Board does not waive any further enforcement action by issuance of this
17 citation.

18 19 **PARTIES BOUND**

20 This Citation shall apply to and be binding upon the System, its officers, directors,
21 agents, employees, contractors, successors, and assignees.

22 23 **SEVERABILITY**

24 The directives of this Citation are severable, and the Water System shall comply with
25 each and every provision thereof notwithstanding the effectiveness of any other
26 provision.

27

1
2
3
4
5
6
7
8
9
10
11

R. Crenshaw


4/29/16

Reese B. Crenshaw, P.E., District Engineer
Valley District
Drinking Water Field Operations Branch

Date

Attachments:

- 'A' Public Notification Template
- 'B' Certification of Completion



IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

**The Central Gaither Elementary School water system
did not meet Bacteriological Drinking Water Standards
in April 2016**

Our water system violated the bacteriological drinking water standard for April 2016. As our consumers, you have a right to know what you should do, what happened, and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. Three of five routine bacteriological samples taken on April 22, 2016, indicated the presence of coliform bacteria. The standard is that no more than one (1) sample per month may have the presence of total coliform.

What should I do?

- **You do not need to boil your water or take other corrective actions.** This is not an emergency, if it had been, you would have been notified immediately.
- Usually, coliforms are a sign that there could be a problem with the treatment or distribution system (pipes). Whenever we test for total coliform bacteria in any sample, we also test to see if other bacteria of greater concern, such as fecal coliform or *E. coli*, are present. **We did not find E. Coli bacteria in our testing.**
- People with severely compromised immune systems, infants, and some elderly may be at increased risk. These people should seek advice about drinking water from their health care providers. General guidelines on ways to lessen the risk of infection by microbes are available from U.S. EPA's Safe Drinking Water Hotline at 1(800) 426-4791.
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

The cause of total coliform bacteria in the drinking water is unknown at this time. The drinking water system was disinfected and flushed during the week of April 25, 2016 and additional water samples will be taken the following week.

For more information, please contact Thomas Butcher @ 530-822-5252

State Water System ID#: 5100150

CERTIFICATION OF COMPLETION OF PUBLIC NOTIFICATION

This form, when completed and returned to the Division of Drinking Water (364 Knollcrest Drive, Suite 101, Redding, CA 96002 or fax to 530-224-4844), serves as certification that public notification to water users was completed as required by the California Water Quality and Monitoring Regulations. Completing public notification and providing the Division with certification is important. Failure to do so will result in additional hourly time charges to your water utility and may result in a formal enforcement action with monetary penalties.

Public Water System Name Central Gaither School

Public Water System No. 5100150

Public notification for the April 2016 bacteriological failure was performed by the following method:

 Hand delivery to faculty and other staff served by the water system. Please indicate the date(s) the notice was hand delivered: _____

AND

 Mail, email, or hand delivery to parents of students. Please indicate the date(s) the notice was sent or delivered to parents: _____

I hereby certify that the above information is factual.

Printed Name

Signature

Date