



EDMUND G. BROWN JR.
GOVERNOR



MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board
Division of Drinking Water

October 24, 2014
System No.: 5410015

Mr. Dan Boggs, Water Superintendent
City of Tulare
3981 South K Street
Tulare, CA 93274

RE: Citation No. 03-24-14C-020
Violation of Title 22, California Code of Regulations, Section 64426.1,
For September 2014

Dear Mr. Boggs:

Enclosed is a Citation issued to the City of Tulare (Water System) public water system.

The Water System will be billed at the Division's hourly rate (currently estimated at \$126.00) for the time spent on issuing this Citation. The California Health and Safety Code Section 116577 provides that a public water system must reimburse the Division for actual costs incurred by the Division for specified enforcement actions, including but not limited to, preparing, issuing and monitoring compliance with a citation. At this time, the Division has spent approximately one and one-half hours on enforcement activities associated with this violation.

The Water System will receive a bill sent from the Division of Drinking Water Fee Billing Unit in August of the next fiscal year. This bill will contain fees for any enforcement time spent on the City of Tulare for the current fiscal year.

If you have any questions regarding this letter and the enclosed citation, please contact the Tulare District office at (559) 447-3300.

Sincerely,

A handwritten signature in blue ink, appearing to read "Chad Fischer".

Chad Fischer, P.E.
Senior Sanitary Engineer, Tulare District
SOUTHERN CALIFORNIA BRANCH
DRINKING WATER FIELD OPERATIONS

CJF/BP
Enclosures
cc: Tulare County Environmental Health Services Division

**STATE OF CALIFORNIA
WATER RESOURCES CONTROL BOARD
DIVISION OF DRINKING WATER**

IN RE: **CITY OF TULARE**
Water System No. 5410015

TO: Mr. Dan Boggs, Water Superintendent
City Of Tulare
3981 South K Street
Tulare, CA 93274

CC: Tulare County Environmental Health Services Division

**CITATION FOR VIOLATION OF
CALIFORNIA CODE OF REGULATIONS, TITLE 22, SECTION 64426.1
September 2014**

Issued on October 24, 2014

Section 116650 of the California Health and Safety Code authorizes the issuance of a citation to a public water system for violation of the California Safe Drinking Water Act (Health and Safety Code, Division 104, Part 12, Chapter 4, commencing with Section 116270) (hereinafter "California SDWA"), or any regulation, standard, permit or order issued or adopted thereunder.

The State Water Resources Control Board (hereinafter "Board"), acting by and through its Division of Drinking Water (hereinafter "Division") and the Deputy Director for the Division (hereinafter "Deputy Director"), hereby issues a citation to the City of Tulare (hereinafter "Water System") (3981 South K Street, Tulare, CA 93274) for violation of California Code of Regulations (CCR), Title 22, Section 64426.1.

1 **APPLICABLE AUTHORITIES**

2 The applicable statutes and regulations are provided in Appendix A, attached hereto and
3 incorporated by reference.

4
5 **STATEMENT OF FACTS**

6 The Water System is a community water system serving a population of approximately
7 60,300 persons through 17,086 service connections. The Water System currently operates
8 under Domestic Water Supply Permit No. 03-12-10P-004 issued by the Division on June
9 24, 2012.

10
11 The Water System is required to collect a minimum of eighteen (18) distribution system
12 bacteriological sample per week. The bacteriological water analysis results submitted by
13 the Water System reported the presence of total coliform bacteria in five (5) of ninety-two
14 (92) samples collected by the Water System in September 2014. None of the positive
15 samples showed the presence of fecal coliform or *E. coli* bacteria.

16
17 Upon being informed of the presence of total coliform bacteria in three (3) routine samples
18 collected on September 2, 2014, Water System staff collected a total of twelve (12) repeat
19 samples on September 3, 2014. All of the repeat samples were absent of total coliform
20 bacteria and *E. coli* bacteria.

21
22 Upon being informed of the presence of total coliform in one (1) routine sample collected
23 on September 9, 2014, Water System staff collected a total of four (4) repeat samples on
24 September 10, 2014. One (1) repeat sample showed the presence of total coliform
25 bacteria. Water System staff collected four (4) additional repeat samples on September 11,
26 2014. All of the repeat samples were absent of total coliform bacteria and *E. coli* bacteria.

27 A summary of Distribution Bacteriological Samples and Source Bacteriological Samples
from January 2013 to September 2014 is included in Attachments A and B, respectively.

1
2 Water System staff conducted a field investigation and completed the Positive Total
3 Coliform Investigation form provided by the Division. The source of contamination was
4 undetermined.

5
6 The Groundwater Rule (GWR) requires the collection of a sample for bacteriological
7 evaluation from the well(s) serving the system in response to a coliform-positive distribution
8 sample within 24 hours of being notified of the coliform-positive result. Based on data
9 submitted to the Division, the Water System did collect their raw water well samples in a
10 timely manner in follow-up to the total coliform-positive routine samples collected in the
11 month of September 2014. Bacteriological results of these wells did not show the presence
12 of total coliform bacteria or *E. coli* bacteria.

13
14 Public notification to the Division and consumers of a water system is required whenever a
15 violation of the Total Coliform MCL occurs. Notification to the Division is required by the
16 end of the business day on which the violation has been determined. If the Division is
17 closed, notification shall be within 24 hours of the determination. The Division was notified
18 on October 9, 2014, in accordance with regulation.

19
20 Public notification to the consumers of the Water System was conducted on October 24,
21 2014, advising each customer of the failure of the total coliform MCL during the month of
22 July 2014. A copy of the notice that was posted and distributed is provided as Attachment
23 C. The completed Proof of Notification Form is provided as Attachment D.

1 **DETERMINATION**

2 Title 22, CCR, Section 64426.1, Total Coliform Maximum Contaminant Level (MCL)
3 provides that a public water system that collects at least 40 samples per month has failed
4 to comply with the regulation whenever more than five percent of the samples collected
5 during any month are total coliform-positive.
6

7 The Division has determined that the Water System failed to comply with Title 22, CCR,
8 Section 64426.1, Total Coliform MCL for the month of September 2014 due to the
9 presence of total coliform bacteria in greater than five percent of samples collected in
10 September 2014.
11

12 **DIRECTIVES**

13 The Water System is hereby directed to comply with Title 22, CCR, Section 64426.1 in all
14 future monitoring periods. The Water System has completed the necessary public
15 notification and investigation and no other directives are necessary at this time.
16

17 The Division reserves the right to make such modifications to the Citation as it may deem
18 necessary to protect public health and safety. Such modifications may be issued as
19 amendments to this Citation and shall be effective upon issuance.
20

21 Nothing in this Citation relieves the Water System of its obligation to meet the requirements
22 of the California Safe Drinking Water Act or any regulation, standard, permit or order
23 issued thereunder.
24
25
26
27

1 All submittal required by this Citation shall be submitted to the Division at the following
2 address:

3
4 Chad Fischer, P.E.
5 Senior Sanitary Engineer
6 State Water Resources Control Board
7 Division of Drinking Water
8 265 W. Bullard Avenue, Suite 101
9 Fresno, CA 93704

10
11
12 **PARTIES BOUND**

13 This Citation shall apply to and be binding upon the Buena Vista School water system, its
14 officers, directors, agents, employees, contractors, successors, and assignees.

15
16
17 **SEVERABILITY**

18 The Directives of this Citation are severable, and the Water System shall comply with each
19 and every provision thereof notwithstanding the effectiveness of any provision.
20
21
22
23
24
25
26
27

FURTHER ENFORCEMENT ACTION

The California SDWA authorizes the Board to: issue citation with assessment of administrative penalties to a public water system for violation or continued violation of the requirements of the California SDWA or any permit, regulation or order issued or adopted thereunder including, but not limited to, failure to correct a violation identified in a citation or compliance order. The California SDWA also authorizes the Board to take action to suspend or revoke a permit that has been issued to a public water system if the system has violated applicable law or regulations or has failed to comply with an order of the Board; and to petition the superior court to take various enforcement measures against a public water system that has failed to comply with an order of the Board. The Board does not waive any further enforcement action by issuance of this citation.

10/24/14

Date



Chad Fischer, P.E.
Senior Sanitary Engineer, Tulare District
DRINKING WATER FIELD OPERATIONS BRANCH

CF/BP

Attachments:

- Attachment A: Summary of Distribution Bacteriological Samples (Jan 2013 to Sep 2014)
- Attachment B: Summary of Source Bacteriological Samples from (Jan 2013 to Sep 2014)
- Attachment B: Public Notice
- Attachment C: Proof of Notification

APPENDIX A

Applicable Statutes and Regulations for Citation No. 03-24-14C-020

Section 116650 of the CHSC states in relevant part:

§116650. Citations

- (a) If the Division determines that a public water system is in violation of this chapter or any regulation, permit, standard, citation, or order issued or adopted thereunder, the Division may issue a citation to the public water system. The citation shall be served upon the public water system personally or by certified mail. Service shall be deemed effective as of the date of personal service or the date of receipt of the certified mail. If a person to whom a citation is directed refuses to accept delivery of the certified mail, the date of service shall be deemed to be the date of mailing.
- (b) Each citation shall be in writing and shall describe the nature of the violation or violations, including a reference to the statutory provision, standard, order, citation, permit, or regulation alleged to have been violated.
- (c) A citation may specify a date for elimination or correction of the condition constituting the violation.
- (d) A citation may include the assessment of a penalty as specified in subdivision (e).
- (e) The Division may assess a penalty in an amount not to exceed one thousand dollars (\$1,000) per day for each day that a violation occurred, and for each day that a violation continues to occur. A separate penalty may be assessed for each violation.

Section 64426.1 of Title 22, California Code of Regulations (CCR) states in relevant part:

§64426.1. Total Coliform Maximum Contaminant Level (MCL).

- (a) Results of all samples collected in a calendar month pursuant to Sections 64423, 64424, and 64425 that are not invalidated by the Department or the laboratory shall be included in determining compliance with the total coliform MCL. Special purpose samples such as those listed in §64421(b) and samples collected by the water supplier during special investigations shall not be used to determine compliance with the total coliform MCL.
- (b) A public water system is in violation of the total coliform MCL when any of the following occurs:
 - (1) For a public water system which collects at least 40 samples per month, more than 5.0 percent of the samples collected during any month are total coliform-positive; or
 - (2) For a public water system which collects fewer than 40 samples per month, more than one sample collected during any month is total coliform-positive; or
 - (3) Any repeat sample is fecal coliform-positive or E. coli-positive; or
 - (4) Any repeat sample following a fecal coliform-positive or E. coli-positive routine sample is total coliform-positive.
- (c) If a public water system is not in compliance with paragraphs (b)(1) through (4), during any month in which it supplies water to the public, the water supplier shall notify the Department by the end of the business day on which this is determined, unless the determination occurs after the Department office is closed, in which case the supplier shall notify the Department within 24 hours of the determination. The water supplier shall also notify the consumers served by the water system. A Tier 2 Public Notice

shall be given for violations of paragraphs (b)(1) or (2), pursuant to section 64463.4. A Tier 1 Public Notice shall be given for violations of paragraphs (b)(3) or (4), pursuant to section 64463.1.

**Attachment A:
Summary of Distribution Bacteriological Samples (Jan 2013 to Sep 2014)**

Bacteriological Distribution Monitoring Report

5410015 *Tulare, City of*

Distribution System Freq: 18/W

Sample Date	Location	T Coli	E Coli	F Coli	HPC	Type	Cl2	Cl2 Avg	Viol. Type	GWR Satisfied?	Comments
9/11/2014	Well 26	A				Source Repeat					
9/11/2014	1727 W. Merritt	A				Repeat	0.63				
9/11/2014	1650 Merritt	A				Repeat	0.65				
9/11/2014	1822 Merritt	A				Repeat	0.66				
9/10/2014	1727 W. Merritt	A				Repeat	0.16				
9/10/2014	1650 W. Merritt	A				Repeat	0.43				
9/10/2014	1822 W. Merritt	P	A			Repeat	0.01				
9/10/2014	Well 26	A				Source Repeat					
9/9/2014	1727 W. Merritt	P	A			Routine	0.12				
9/4/2014	Well 12	A				Source Repeat					
9/3/2014	131 N. H St.	A				Repeat	0.59				
9/3/2014	105 N. H St.	A				Repeat	0.60				
9/3/2014	136 N. H St.	A				Repeat	0.60				
9/3/2014	211 W. Cross	A				Repeat	0.62				
9/3/2014	300 W. Cross Ave.	A				Repeat	0.62				
9/3/2014	345 W. Cross	A				Repeat	0.62				
9/3/2014	Well 12	A				Source Repeat					
9/3/2014	704 N. West St.	A				Repeat	0.48				
9/3/2014	1264 Damron	A				Repeat	0.63				
9/3/2014	754 N. West	A				Repeat	0.58				
9/3/2014	Well 26	A				Source Repeat					
9/2/2014	131 N. H St.	P	A			Routine	0.6				
9/2/2014	300 W. Cross Ave	P	A			Routine	0.67				
9/2/2014	704 N. West St.	P	A			Routine	0.5		MCL		Issued Citation 03-24-14C-XXX
9/1/2014	68 Samples	A	A			Routine	1.35-0.04				
8/12/2014	1594 E. Cross	A				Repeat	0.45				
8/12/2014	Site 23	A				Repeat	0.57				
8/12/2014	1703 E. Cross	A				Repeat	0.91				
8/11/2014	Site 23	P	A			Routine	0.51			Yes	GWR: Rep well samples collected.
8/1/2014	71 samples	A	A			Routine	0.37-1.61				
7/1/2014	72 Samples	A				Routine	0-1.27				
6/10/2014	1727 W. Merit	A				Repeat	0.07				
6/10/2014	1650 W. Merit	A				Repeat	0.53				
6/10/2014	1822 W. Merit	A				Repeat	0.03				
6/9/2014	1727 W. Merit	P				Routine	0.07			Yes	
6/1/2014	71 Samples	A	A			Routine	0.28-1.84				
5/16/2014	1503 W. Maple	A	A			Repeat	0.59				
5/16/2014	1537 W. Maple	A	A			Repeat	0.59				
5/16/2014	1425 W. Maple	A	A			Repeat	0.59			Yes	
5/15/2014	1503 W. Maple	P	A			Routine	0.08				
5/1/2014	71 Samples	A	A			Routine	0-1.35				
4/10/2014	Site 19	A				Repeat	0.57				
4/10/2014	4444 S. K. St.	A				Repeat	0.65				
4/10/2014	3950 S. K St.	A				Repeat	0.64				
4/10/2014	Site 29	A				Repeat	0.76				

Sample Date	Location	T Coli	E Coli	F Coli	HPC	Type	CI2	CI2 Avg	Viol. Type	GWR Satisfied?	Comments
4/10/2014	726 W. Pleasant	A				Repeat	0.82				
4/10/2014	864 W. Pleasant	A				Repeat	0.74				
4/8/2014	Site 19	P		A		Routine	0.43			Yes	
4/8/2014	Site 29	P		A		Routine	0.48			Yes	
4/1/2014	70 Samples	A				Routine	0.45-1.18				
3/1/2014	72 Samples	A				Routine	0.04-1.22				
2/1/2014	72 Samples	A				Routine	0.38-1.32				
1/1/2014	72 Samples	A				Routine	0.27-1.39				
12/3/2013	1300 blk. Of W. Elm	A				Repeat	0.62			Yes	
12/3/2013	572 S. West St.	A				Repeat	0.60			Yes	
12/3/2013	616 S. West St.	A				Repeat	0.60			Yes	
12/2/2013	1300 blk. Of W. Elm	P				Routine	0.59			Yes	GWR: Well was sampler
12/1/2013	71 Samples	A				Routine	0.2-1.27	0.75			
11/26/2013	Site 69	A				Repeat	0.53				
11/26/2013	2239 Poppyview	A				Repeat	0.53				
11/26/2013	2246 Poppyview	A				Repeat	0.53				
11/25/2013	Site 69-2200 Poppyview	P				Routine	0.55			Yes	GWR well was sampled.
11/1/2013	71 samples	A				Routine	0.33-1.38				
10/15/2013	300 blk. N. Laspina	A				Repeat	0.59				
10/15/2013	1644 Academy	A				Repeat	0.59				
10/15/2013	340 N. Laspina	A				Repeat	0.59				
10/14/2013	300 blk N. Laspina	P				Routine	0.63			Yes	
10/1/2013	71 samples	A				Routine	0.04-1.34				
9/1/2013	72 samples	A				Routine	0-1.29				
8/1/2013	72 samples	A				Routine	0.07-1.35				
7/23/2013	100 Blk S. Silva	A				Repeat	0.82				
7/23/2013	2129 E. Tulare	A				Repeat	0.72				
7/23/2013	168 S. Silva	A				Repeat	0.82				
7/22/2013	100 Blk S. Silva	P				Routine	0.79			Yes	
7/1/2013	71 samples	A				Routine	0.1-1.65				
6/1/2013	72 samples	A				Routine	0.07-1.45				
5/1/2013	72 samples	A				Routine	0.02-1.21	0.62			
4/1/2013	72 samples	A				Routine	0.03-1.36				
3/1/2013	60 samples	A				Routine	0.06-1.65				
2/1/2013	60 samples	A				Routine	0.21-0.93				
1/23/2013	275 Colonial Ct.	A				Repeat	0.28			Yes	
1/23/2013	258 Colonial Ct.	A				Repeat	0.28			Yes	
1/23/2013	200 Blk Yellowstone	A				Repeat	0.28			Yes	
1/22/2013	200 Blk Yellowstone	P				Routine	0.59			Yes	
1/1/2013	59 samples	A				Routine	0.03-1.16	0.64			

Violation Key

MCL	Exceeds the maximum contaminant level	MR5	Incorrect number of repeat samples as follow-up to a positive sample
MR1	No monthly sample for the report month	MR6	No source sample
MR2	No quarterly sample for the report month	MR7	No summary report submitted
MR3	Incorrect number of routine samples for the report month	MR8	Other comments and/or info
MR4	Did not collect 5 routine samples for previous month's positive sample	MR9	CI2 not reported

**Attachment B:
Summary of Source Bacteriological Samples (Jan 2013 to Sep 2014)**

Source Bacteriological Monitoring Report

5410054 Tulare City WWTP

<i>Sample Date</i>	<i>Time</i>	<i>Source</i>	<i>Sample Type</i>	<i>Test Method</i>	<i>T Coli</i>	<i>E Coli</i>	<i>F Coli</i>	<i>HPC</i>	<i>Violation</i>	<i>Comments</i>
9/23/2014	11:41	Well 41	Well	MPN	<1.1			190		
8/21/2014		Wells 21 & 41	Well	P/A	A			680 & 1200		
7/22/2014	9:20	Well 41	Well	MPN	1.1	<1.1	<1.1			
7/22/2014	10:12	Well 21	Well	P/A	A					
6/1/2014		Wells: 21 & 41	Well	P/A	A					
5/1/2014		Wells: 21 & 41	Well	P/A	A					
4/17/2014		Wells 4 & 41	Well	MPN	<1.1					
4/17/2014	11:51	Well 21	Well	MPN	2.2		<1.1			
3/18/2014		Wells: 21 & 41	Well	MPN	<1.1		<1.1			
2/25/2014		Wells: 21 & 41	Well	MPN	<1.1					
1/28/2014		Wells 21 & 41	Well	P/A	<1.1					
12/18/2013	10:57	Well 41	Well	MPN	<1.1		<1.1			
12/18/2013	11:06	Well 21	Well	MPN	1.1	<1.1	<1.1			
11/19/2013		Wells: 21 & 41	Well	P/A	A					
10/23/2013		Wells 21 & 41	Well	MPN	<1.1					
9/24/2013		Wells 21 & 41	Well	MPN	<1.1					
8/27/2013		Wells 21 & 41	Well	MPN	<1.1					
7/21/2013	12:15	Well 21	Well	MPN	1.1	<1.1				
7/17/2013	9:40	Well 41	Well	MPN	<1.1					
7/17/2013	9:47	Well 21	Well	MPN	5.1	<1.1				
6/20/2013		Wells 21 & 41	Well	MPN	<1.1					
5/22/2013		Wells 21 & 41	Well	MPN	<1.1					
4/16/2013		Wells 21 & 41	Well	MPN	<1.1					
3/20/2013		Wells 21 & 41	Well	MPN	<1.1					
2/20/2013		Wells 21 & 41	Well	P/A	A					
1/17/2013		Wells 21 & 41	Well	P/A	A					

**Attachment C:
Public Notice for September 2014**

Order Confirmation

VISALIA TIMES-DELA Visalia Times-Delata/Tulare Advance-Register PO Box 31 - 330 N West St Visalia CA 93291 (559) 735-3333		ADVANCE REGISTER Visalia Times-Delata/Tulare Advance-Register PO Box 31 - 330 N West St Visalia CA 93291 (559) 735-3333	
Customer # 5166VT CITY OF TULARE/SOLID WASTE 3981 S K ST TULARE CA 93274-7189 USA Customer Phone: 559-684-4325 Customer Email:	Payor Customer # 5166VT CITY OF TULARE/SOLID WASTE 3981 S K ST TULARE CA 93274-7189 USA Payor Phone: 559-684-4325	PO Number: Ordered By: Sherri Metz Customer Fax: Special Pricing: None Sales Rep: dygarcia Order Taker: dygarcia Order Source: Phone	Order Confirmation For Ad #0000292614

Tear Sheets	0	Proofs	1	Affidavits @ \$10.00	Blind Box	Promo Type
Net Amount		Tax Amount		Total Amount	Payment Amount	Amount Due
	\$450.80		\$0.00	\$450.80	\$0.00	\$450.80

Ad Number	0000292614-01	Ad Type	CLS MultiCol Liner	Ad Size	2.0 X 162 LI	Color	<NONE>	Production Method	AdBooker	Production Notes
External Ad Number		Ad Attributes		Ad Released	No	Pick Up				

Ad Content
IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
 Este informe contiene informacion muy importante sobre su agua potable. Traduzcilo o hable con alguien que lo entienda bien.

City of Tulare Has Levels of Coliform Bacteria Above the Drinking Water Standard

Our water system recently failed a drinking water standard. Although the incident was not an emergency, as our customers, you have a right to know what you should do, what happened and what we did to correct this situation.

We routinely monitor for drinking water contaminants. We took 92 samples to test for the presence of coliform bacteria in September, 2014. 5.4% of these samples showed the presence of total coliform bacteria. The standard is that no more than 5 percent of samples per month may show the presence of coliform bacteria.

What should I do?

- * You do not need to boil your water or take other corrective actions.
- * This is not an emergency. If it had been, you would have been notified immediately. Total coliform bacteria are generally not harmful themselves. Coliforms are bacteria which are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.
- * Usually, coliforms are a sign that there could be a problem with the treatment or distribution system (pipes). We never we detect coliform bacteria in any sample, we do follow-up testing to see if other bacteria of greater concern, such as fecal coliform or E. coli, are present. We did not find any of these bacteria in our subsequent testing.
- * People with severely compromised immune systems, infants, and some elderly may be at increased risk. These people should seek advice about drinking water from their health care providers. General guidelines on ways to lessen the risk of infection by microbes are available from EPA's Safe Drinking Water Hotline at 1(800)426-4791.
- * If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

The City increased the chlorine residual, flushed the distribution system and collected bacteriological samples. All repeat samples were negative for total coliform bacteria. This means that the amount

**Attachment D:
Proof of Notification Form**

PROOF OF NOTIFICATION
(Return with copy of the Notice)

As required by Section 116450 of the California Health and Safety Code, I notified all users of water supplied by the **City of Tulare** of the failure to meet the **total coliform bacteria MCL** for the month of **September 2014** as directed by the Division. At least one primary distribution method is required: mail, hand-delivery or newspaper publication. A second method is also required in order to reach persons not likely to be reached by a mailing, direct delivery or newspaper publication (renters, nursing home patients, prison inmates, etc.):

Notification was made on Newspaper 10-24-2014 Web Page 10-20-14
(date)

To summarize report delivery used and good-faith efforts used, please check all items below that apply and fill-in where appropriate:

- The notice was distributed by mail delivery to each customer served by the water system.
- The notice was distributed by direct delivery to each customer served by the water system. Specify direct delivery method(s) used: _____
- Publication of the notice in a local newspaper or newsletter of general circulation (attach a copy of the published notice, including name of newspaper and date published).
- Posted the notice at the following conspicuous locations served by the water system (if needed, please attach a list of locations). _____
- Posted the notice on the Internet at www. City of Tulare, Public Works, Water
- Other method used to notify customers. _____

DISCLOSURE: Be advised that Section 116725 and 116730 of the California Health and Safety Code state that any person who knowingly makes any false statement on any report or document submitted for the purpose of compliance with the attached order may be liable for a civil penalty not to exceed five thousand dollars (\$5,000) for separate violation for each day that violation continues. In addition, the violators may be prosecuted in criminal court and upon conviction, be punished by a fine of not more than \$25,000 for each day of violation, or be imprisoned in the county jail not to exceed one year, or by both the fine and imprisonment.

Certified by Name and Title: Dan Boggs Water Utility Manager
Date: 10-22-2014 Signature: Dan Boggs

Due to the State Water Resources Control Board – Division of Drinking Water, Tulare District, within 10 days of notification to the public.