



EDMUND G. BROWN JR.
GOVERNOR

MATTHEW RODRIGUEZ
SECRETARY FOR
ENVIRONMENTAL PROTECTION

State Water Resources Control Board

Division of Drinking Water

May 18, 2015
System No.: 5410009

Board of Directors
Pixley Public Utility District
P.O. Box 535
Pixley, CA 93256

RE: Compliance Order No. 03-12-15R-007
Violation of Title 22, California Code of Regulations, Section 1166555 (a)(1), for 2015
Year

Dear Board of Directors:

Enclosed is a Compliance Order issued to the Pixley Public Utility District (Water System) public water system.

The Water System will be billed at the Division's hourly rate (currently estimated at \$126.00) for the time spent on issuing this Citation. The California Health and Safety Code Section 116577 provides that a public water system must reimburse the Division for actual costs incurred by the Division for specified enforcement actions, including but not limited to, preparing, issuing and monitoring compliance with a citation. At this time, the Division has spent approximately 2 hours on enforcement activities associated with this violation.

The Water System will receive a bill sent from the Division of Drinking Water Fee Billing Unit in August of the next fiscal year. This bill will contain fees for any enforcement time spent for the current fiscal year.

If you have any questions regarding this letter and the enclosed citation, please contact Shen Huang or me at (559) 447-3300.

Sincerely,

Tricia A. Wathen, P.E.
Senior Sanitary Engineer, Visalia District
SOUTHERN CALIFORNIA BRANCH
DRINKING WATER FIELD OPERATIONS

TAW/SH

Enclosures

cc: Tulare County Environmental Health Department (Compliance Order only)

1
2
3 CALIFORNIA
4 STATE WATER RESOURCES CONTROL BOARD
5 DIVISION OF DRINKING WATER

6 IN RE: **PIXLEY PUBLIC UTILITY DISTRICT**
7 Water System No. 5410009

8 TO: Pixley Public Utility District
9 Board of Directors
10 P.O. Box 535
11 Pixley, CA 93256

12
13 CC: Tulare County Environmental Health Services Department

14 **COMPLIANCE ORDER NO. 03-12-15R-007**
15 **FOR**
16 **VIOLATION OF HEALTH AND SAFETY CODE SECTION 116655 (a)(1)**
17 **AND THE PRIMARY DRINKING WATER STANDARD FOR ARSENIC**

18 **Issued: May 18, 2015**

19 The State Water Resources Control Board (hereinafter "Board"), acting by and
20 through its Division of Drinking Water (hereinafter "Division") and the Deputy Director
21 for the Division (hereinafter "Deputy Director"), hereby issues this compliance order
22 (hereinafter "Order") pursuant to Section 116655 of the California Health and Safety
23 Code (hereinafter "CHSC") to Pixley Public Utility District for violation of CHSC
24 section 116555(a)(1) and Title 22, California Code of Regulations (hereinafter
25 "CCR"), Section 64431.
26
27

1 **APPLICABLE AUTHORITIES**

2
3 **CHSC, Section 116555(a)(1) states in relevant part:**

- 4 (a) Any person who owns a public water system shall ensure that the system does
5 all of the following:
6 (1) Complies with primary and secondary drinking water standards.

7 **CHSC, Section 116655 states in relevant part:**

- 8 (a) Whenever the department determines that any person has violated or is violating
9 this chapter, or any permit, regulation, or standard issued or adopted pursuant
10 to this chapter, the director may issue an order doing any of the following:
11 (1) Directing compliance forthwith.
12 (2) Directing compliance in accordance with a time schedule set by the
13 department.
14 (3) Directing that appropriate preventive action be taken in the case of a
15 threatened violation.
16 (b) An order issued pursuant to this section may include, but shall not be limited to,
17 any or all of the following requirements:
18 (1) That the existing plant, works, or system be repaired, altered, or added to.
19 (2) That purification or treatment works be installed.
20 (3) That the source of the water supply be changed.
21 (4) That no additional service connection be made to the system.
22 (5) That the water supply, the plant, or the system be monitored.
23 (6) That a report on the condition and operation of the plant, works, system, or
24 water supply be submitted to the department.

25
26 **Title 22, CCR, Section 64431 (hereinafter "Section 64431"), states in relevant
27 part:**

Public water systems shall comply with the primary MCLs in table 64431-A as
specified in this article.

Table 64431-A
Maximum Contaminant Levels
Inorganic Chemicals

<i>Chemical</i>	<i>Maximum Contaminant Level, mg/L</i>
Aluminum	1.
Antimony	0.006
Arsenic	0.010
Asbestos	7 MFL*
Barium	1.
Beryllium	0.004
Cadmium	0.005
Chromium	0.05
Cyanide	0.15
Fluoride	2.0
Hexavalent chromium	0.010
Mercury	0.002
Nickel	0.1
Nitrate (as NO ₃)	45.
Nitrate+Nitrite (sum as nitrogen)	10.
Nitrite (as nitrogen)	1.
Perchlorate	0.006
Selenium	0.05
Thallium	0.002

* MFL=million fibers per liter; MCL for fibers exceeding 10 um in length.

Title 22, CCR Section 64432 (hereinafter "Section 64432") provides in relevant part:

Section 64432

...

(g) If the level of any inorganic chemical, except for nitrate, nitrite, nitrate plus nitrite, or perchlorate, exceeds the MCL, the water supplier shall do one of the following:

(1) Inform the Department within 48 hours and monitor quarterly beginning in the next quarter after the exceedance occurred; or

(2) Inform the Department within seven days from the receipt of the analysis and, as confirmation, collect one additional sample within 14 days from receipt of the analysis. If the average of the two samples collected exceeds the MCL, this information shall be reported to the Department within 48 hours and the water

1 supplier shall monitor quarterly beginning in the next quarter after the exceedance
2 occurred.

3 (h) If the concentration of an inorganic chemical exceeds ten times the MCL, within
4 48 hours of receipt of the result the water supplier shall notify the Department and
5 resample as confirmation. The water supplier shall notify the Department of the
6 result(s) of the confirmation sample(s) within 24 hours of receipt of the confirmation
7 result(s).

8 (1) If the average concentration of the original and confirmation sample(s) is less
9 than or equal to ten times the MCL, the water supplier shall monitor quarterly
10 beginning in the quarter following the quarter in which the exceedance occurred.

11 (2) If the average concentration of the original and confirmation sample(s) exceeds
12 ten times the MCL, the water supplier shall, if directed by the Department;

13 (A) Immediately discontinue use of the contaminated water source; and

14 (B) Not return the source to service without written approval from the Department.

15 (i) Compliance with the MCLs shall be determined by a running annual average; if
16 any one sample would cause the annual average to exceed the MCL, the system is
17 immediately in violation. If a system takes more than one sample in a quarter, the
18 average of all the results for that quarter shall be used when calculating the running
19 annual average. If a system fails to complete four consecutive quarters of
20 monitoring, the running annual average shall be based on an average of the
21 available data.

22 **STATEMENT OF FACTS**

23 The Pixley Public Utility District water system (hereinafter "Water System") is a
24 community water system located in Tulare County that supplies water for domestic
25 purposes to approximately 3310 individuals through approximately 823 service
26 connections. The Water System operates under Domestic Water Supply Permit No.
27 03-12-12P-010 issued on August 10, 2012. The Water System is a community public
water system as defined in CHSC, section 116275.

1 The Water System utilizes three groundwater wells as its source of domestic water,
2 Well No. 02A, Well No. 03A, and Well No. 04. Title 22, CCR, Division 4, Chapter 15,
3 Article 4, establishes primary drinking water standards and monitoring and reporting
4 requirements for inorganic constituents. Community and nontransient noncommunity
5 water systems must comply with the maximum contaminant level for arsenic of
6 0.010 mg/L, as established in Title 22 CCR Section 64431.
7

8 Samples collected from the Water System on April 11, 2008, showed an arsenic
9 concentration of 0.024 mg/L in Well No. 01. Therefore, in accordance with Section
10 64431 (g), the Water System was required to begin quarterly arsenic monitoring of
11 each well, unless it chose to submit an additional sample, which it did not do.
12 Section 64431 (i) provides that compliance with the arsenic MCL is based on a
13 “running annual average” (RAA) of the quarterly monitoring samples, computed each
14 quarter. Further, Section 64431 (i) states: “if any one sample would cause the
15 annual average to exceed the MCL, the system is immediately in violation.” Well No.
16 01 has since been inactivated since 1st quarter 2011. Well No. 02A and Well No.
17 03A have generally exceeded the MCL since 2nd quarter 2008.
18

19 A summary of the Water System’s arsenic monitoring is presented in Table 1 and
20 Table 2 below. All results are as reported to the Division by the laboratory that
21 performed the analysis.
22
23
24
25
26
27

Table 1: Well No. 02A Arsenic Monitoring Results

Sample Quarter	Sample Date	Sample Result
1 st Quarter of 2014	No sample – offline due to repairs	
2 nd Quarter of 2014	04/30/14	0.022 mg/L
3 rd Quarter of 2014	07/31/2014	0.023 mg/L
4 th Quarter of 2014	10/23/2014	0.021 mg/L
1 st Quarter of 2015	01/21/2015	0.020 mg/L
1st Quarter 2015 Running Annual Average	0.022 mg/L	

Table 2: Well No. 03A Arsenic Monitoring Results

Sample Quarter	Sample Date	Sample Result
1 st Quarter of 2014	02/04/2014	0.020 mg/L
2 nd Quarter of 2014	No sample – offline due to repairs	
3 rd Quarter of 2014	07/31/14	0.010 mg/L
4 th Quarter of 2014	10/23/2015	0.012 mg/L
1 st Quarter of 2015	01/21/2015	0.013 mg/L
1st Quarter 2015 Running Annual Average	0.012 mg/L	

The 1st quarter 2015 RAA for Well No. 02A, calculated as the 4 quarterly sample results averaged over a four quarter period, is 0.022 mg/L, which exceeds the arsenic MCL of 0.010 mg/L. No sample was collected from Well No. 02A in 1st quarter 2014 due to the fact that it was down for repairs. Results of samples taken from water produced from Well No. 02A since 2008 show the RAA for arsenic in said Well continues to exceed the arsenic MCL. The 1st quarter 2015 RAA for Well No. 03A was calculated as the 3 quarterly sample results averaged over a three quarter period because there was no sample taken during the 2nd quarter 2015 since Well No. 03A was offline due to repairs. The 1st quarter 2015 RAA for arsenic is 0.012

1 mg/L, which exceeds the arsenic MCL. Well No. 03A has generally exceeded the
2 MCL since 2008. Historical arsenic results for the 2 wells are provided in Attachment
3 D.
4

5 The Water System was previously in violation of the Arsenic MCL. Compliance
6 Order No. 03-12-09O-001 was issued to the Water System on January 21, 2009, for
7 that violation. This compliance order replaces and voids Compliance Order No. 03-
8 12-09O-001, and its directives.
9

10 **DETERMINATIONS**

11 Based on the above Statement of Facts, the Division has determined that the Water
12 System has violated CHSC, Section 116555 and Section 64431 in that the water
13 produced by Well No. 02A and Well No. 03A, during the 1st quarter of 2015,
14 exceeded the arsenic MCL as shown in Table 1 and Table 2 above, and further has
15 determined that said violation has continued from 2008 and through the date of this
16 Order.
17

18 **DIRECTIVES**

19 Water System is hereby directed to take the following actions:

- 20 1. On or before June 30, 2018, comply with Title 22, CCR, Section 64431 and
21 remain in compliance.
22
- 23 2. On or before July 1, 2015, submit a written response to the Division indicating
24 its agreement to comply with the directives of this Order and with the Corrective
25 Action Plan addressed herein.
26
27

- 1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
3. Commencing on the date of service of this Order, provide quarterly public notification in English and Spanish in accordance with Attachment A, hereto, of Water System's failure to meet the arsenic MCL during any calendar quarter that the four-quarter running annual average exceeds the MCL.
4. Commencing on the date of service of this Order, submit proof of each public notification conducted in compliance with Directive No. 3, herein above, within 10 days following each such notification, using the form provided as Attachment B, hereto.
5. Commencing on the date of service of this Order collect quarterly samples for arsenic from each well, as required by Section 64432(g), and ensure that the analytical results are reported to the Division electronically by the analyzing laboratory no later than the 10th day following the month in which the analysis was completed.
6. Prepare for Division approval a Corrective Action Plan identifying improvements to the water system designed to correct the water quality problem (violation of the arsenic MCL) and ensure that the Water System delivers water to consumers that meets primary drinking water standards. The plan shall include a time schedule for completion of each of the phases of the project such as design, construction, and startup, and a date as of which the Water System will be in compliance with the arsenic MCL, which date shall be no later than June 30, 2018.

- 1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
7. On or before August 1, 2015, present the Corrective Action Plan required under Directive No. 6, above, to the Division in person at the Division's offices located at 265 W. Bullard, Suite 101, Fresno, CA 93704.
8. Timely perform the Division approved Corrective Action Plan and each and every element of said plan according to the time schedule set forth therein.
9. On or before August 10, 2015 and every three months thereafter, submit a report to the Division in the form provided as Attachment C, hereto, showing actions taken during the previous calendar three months to comply with the Corrective Action Plan.
10. Not later than ten (10) days following the date of compliance with the arsenic MCL, demonstrate to the Division that the water delivered by Water System complies with the arsenic MCL.
11. Notify the Division in writing no later than five (5) days prior to the deadline for performance of any Directive set forth herein if Water System anticipates it will not timely meet such performance deadline.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

All submittals required by this Order shall be addressed to:

Tricia Wathen, Senior Sanitary Engineer
State Water Resources Control Board
Division of Drinking Water, Visalia District
265 W. Bullard Ave, Suite 101
Fresno, CA 93704

As used in this Order, the date of issuance shall be the date of this Order; and the date of service shall be the date of service of this Order, personal or by certified mail, on the Water System.

The Division reserves the right to make such modifications to this Order and/or to issue such further order(s) as it may deem necessary to protect public health and safety. Such modifications may be issued as amendments to this Order and shall be deemed effective upon issuance.

Nothing in this Order relieves Water System of its obligation to meet the requirements of the California SDWA, or any regulation, standard, permit or order issued thereunder.

PARTIES BOUND

This Order shall apply to and be binding upon Water System, its owners, shareholders, officers, directors, agents, employees, contractors, successors, and assignees.

SEVERABILITY

The Directives of this Order are severable, and Water System shall comply with each and every provision hereof, notwithstanding the effectiveness of any other provision.

FURTHER ENFORCEMENT ACTION

The California SDWA authorizes the Board to: issue a citation with assessment of administrative penalties to a public water system for violation or continued violation of the requirements of the California SDWA or any regulation, permit, standard, citation, or order issued or adopted thereunder including, but not limited to, failure to correct a violation identified in a citation or compliance order. The California SDWA also authorizes the Board to take action to suspend or revoke a permit that has been issued to a public water system if the public water system has violated applicable law or regulations or has failed to comply with an order of the Board; and to petition the superior court to take various enforcement measures against a public water system that has failed to comply with an order of the Board. The Board does not waive any further enforcement action by issuance of this Order.



Carl Carlucci, P.E., Chief
Central Valley Section
State Water Resources Control Board
Division of Drinking Water

5-18-2015

Date

Certified Mail No. 7014 3490 0001 7868 9597



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

- Attachments:
Attachment A: Public Notification Notice
Attachment B: Proof of Notification Form
Attachment C: Quarterly Progress Report
Attachment D: Historic Arsenic Monitoring Results

Instructions for Tier 2 Arsenic MCL Notice Template

Template Attached as Attachment A

Since exceeding the arsenic maximum contaminant level (MCL) is a Tier 2 violation, you must provide public notice to persons served as soon as practical but within 30 days after you learn of the violation [California Code of Regulations Title 22, Chapter 15, Section 64463.4(b)]. **Each water system required to give public notice must submit the notice to the Department for approval prior to distribution or posting, unless otherwise directed by the Department [64463(b)].**

Notification Methods

You must use the methods summarized in the table below to deliver the notice to consumers. If you mail, post, or hand deliver, print your notice on letterhead, if available.

<i>If You Are a...</i>	<i>You Must Notify Consumers by...</i>	<i>...and By One or More of the Following Methods to Reach Persons Not Likely to be Reached by the Previous Method...</i>
Community Water System [64463.4(c)(1)]	Mail or direct delivery ^(a)	Publication in a local newspaper
		Posting in public places served by the water system or on the Internet ^(b)
		Delivery to community organizations
Non-Community Water System [64463.4(c)(2)]	Posting in conspicuous locations throughout the area served by the water system ^(b)	Publication in a local newspaper or newsletter distributed to customers
		Email message to employees or students
		Posting on the Internet or intranet ^(b)
		Direct delivery to each customer

(a) Notice must be distributed to each customer receiving a bill including those that provide their drinking water to others (e.g., schools or school systems, apartment building owners, or large private employers), and other service connections to which water is delivered by the water system.

(b) Notice must be posted in place for as long as the violation or occurrence continues, but in no case less than seven days.

The notice attached is appropriate for the methods described above. However, you may wish to modify it before using it for posting. If you do, you must still include all the required elements and leave the health effects and notification language in italics unchanged. This language is mandatory [64465].

Multilingual Requirement

Spanish. Each public notice must contain information in Spanish regarding (1) the importance of the notice or (2) contain a telephone number or address where Spanish-speaking residents may contact the water system to obtain a translated copy of the public notice or assistance in Spanish.

Non-English Speaking Groups Other than Spanish-Speaking. For each group that exceeds 1,000 residents or 10% of the residents in the community served, whichever is less, the public notice must (1) contain information in the appropriate language(s) regarding the importance of

the notice or (2) contain a telephone number or address where such residents may contact the water system to obtain a translated copy of the notice or assistance in the appropriate language.

Population Served

Make sure it is clear who is served by your water system -- you may need to list the areas you serve.

Corrective Action

In your notice, describe corrective actions you are taking. Do not use overly technical terminology when describing treatment methods. Listed below are some steps commonly taken by water systems with chemical or radiological violations. Use one or more of the following actions, if appropriate, or develop your own:

- "We are working with [local/state agency] to evaluate the water supply and researching options to correct the problem. These options may include treating the water to remove arsenic or connecting to [system]'s water supply."
- "We have stopped using the contaminated well. We have increased pumping from other wells, and we are investigating drilling a new well."
- "We will increase the frequency at which we test the water for arsenic."
- "We have since taken samples at this location and had them tested. They show that we meet the standards."

After Issuing the Notice

Send a copy of each type of notice and a certification that you have met all the public notice requirements to the Department within ten days after you issue the notice [64451(d)]. You should also issue a follow-up notice in addition to meeting any repeat notice requirements the Department sets.

It is recommended that you notify health professionals in the area of the violation. People may call their doctors with questions about how the violation may affect their health, and the doctors should have the information they need to respond appropriately.

It is a good idea to issue a "problem corrected" notice when the violation is resolved.

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable.
Tradúzcalo o hable con alguien que lo entienda bien.

**Pixley Public Utility District Has Levels
of Arsenic Above Drinking Water Standards**

Our water system recently failed a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what you should do, what happened and what we are doing to correct this situation.

We routinely monitor for the presence of drinking water contaminants. The maximum contaminant level (MCL) for arsenic is 0.010 mg/L. Compliance is based on a running annual average (RAA) of four consecutive quarterly samples for each well. The arsenic RAA for Well No. 02A is _____ mg/L and the arsenic RAA for Well No. 03A is _____ mg/L for the _____ [1st, 2nd, 3rd, 4th] quarter of _____ [year].

What should I do?

- **You do not need to use an alternative (e.g. , bottled) water supply.** However, if you have specific health concerns, consult your doctor.
- This is not an emergency. If it had been, you would have been notified immediately. However, *some people who drink water containing arsenic in excess of the MCL over many years may experience skin damage or circulatory system problems, and may have an increased risk of getting cancer.*
- If you have other health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What was done?

The District is in the process of planning and constructing new wells that meet drinking water standards. We anticipate resolving the problem within 3 years.

For more information, please contact _____ [insert name of contact] at _____ [insert phone number] or at the following mailing address: [insert mailing address] _____.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS** (including nursing homes and care facilities): Must notify tenants.
- **BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS:** Must notify employees of businesses located on the property.

This notice is being sent to you by Pixley PUD.

Date distributed: _____.

INFORMACIÓN IMPORTANTE SOBRE SU AGUA POTABLE

El Distrito de Agua de Pixley tiene niveles de Arsénico que sobrepasa niveles aceptables de agua potable

Nuestro sistema de agua recientemente falló un estándar de agua potable. Aunque esto no es una emergencia, como nuestros clientes, tienen el derecho de saber que deben de hacer, que pasó, y que estamos haciendo para resolver esta situación.

Rutinariamente tomamos pruebas de agua para contaminantes en el agua potable de nuestro sistema. El estándar estatal y federal, o Máximo Nivel de Contaminante, para arsénico es 0.010 microgramos por litro (mg/L). Cumplimiento con el estándar de arsénico se basa en la concentración promedio de cuatro trimestres consecutivos (o un promedio anual) para cada noria. El promedio anual de concentración de arsénico de Noria 02A fue _____ mg/L [Insert the arsenic concentration for Well No. 02A] y Noria 03A fue _____ mg/L [Insert the arsenic concentration for Well No. 03A] para el [Select the quarter that pertains; delete the others: <1st> primero, <2nd> segundo, <3rd> tercero, <4th> cuarto] trimestre del _____ [year].

¿Qué es lo que debo de hacer?

- Usted no necesita usar una fuente alternativa de agua (por ejemplo, agua embotellada). Aunque, si tiene preocupación específica de salubridad, consulte con su doctor.
- Esto no es una emergencia. Si fuese, habría sido informado inmediatamente. Aunque, algunas personas que toman agua que tiene arsénico en exceso del MCL por muchos años puedan tener la piel dañada, o problemas del sistema circulatorio, y puedan tener un nivel más alto de riesgo de contraer cáncer.
- Si acaso tiene preocupaciones de salubridad, o le concierne el consumo de agua, puede consultar con su doctor.

¿Que pasó? ¿Que se hizo?

El Distrito está en el proceso de planeando y construyendo nuevas norias que tiene calidad de agua que satisfecha los estándares estatales y federales. Nos anticipamos que este problema esté resuelto en 3 años.

Para más información, favor de ponerse en contacto con _____ <Insert contact name> al (____) _____ - _____ o a la siguiente dirección: _____ <Insert address>.

Por favor comparta esta información con todos aquellos que usen este sistema de agua, especialmente con aquellos que no hayan recibido esta noticia directamente (por ejemplo, gente que viva en apartamentos, hogares de cuidado, escuelas, y negocios). Usted puede hacer esto poniendo éste aviso en un lugar público o distribuyendo copias directamente o por correo.

Requerimientos de Notificación Secundaria

Al recibir notificación del operador del sistema del agua, la siguiente noticia debe ser dada en 10 días [Sección 11645(g) del Código de Salubridad y Sanidad]:

- Escuelas: Deben notificar a los empleados escolares, estudiantes, y padres (si los estudiantes son menores).
- Dueños o Manejadores de Propiedades de Renta Residenciales (incluyendo residencia de ancianos y otras facilidades de asistencia) deben notificar a los inquilinos.
- Dueños, Manejadores, u Operadores: Deben notificar a los empleados de negocios localizados en las propiedades.

Esta noticia se las manda el Distrito de la Agua de Pixley.

Fecha: _____ [date]

Certification of Completion of Public Notification

This form, when completed and returned to the Division of Drinking Water - Visalia District (265 W. Bullard Ave. #101, Fresno, CA 93704 or fax to 559-447-3304), serves as certification that public notification to water users was completed as required by Title 22, California Code of Regulations, Sections 64463-64465.

Public Water System Name: Pixley Public Utility District

Public Water System No.: 5410009

Public notification for failure to comply with the **Arsenic MCL** was conducted on:

(Circle one): 1st 2nd 3rd 4th quarter of _____ (year).

Notification was made on _____ (date).

To summarize report delivery used and good-faith efforts taken, please check all items below that apply and fill-in where appropriate:

The notice was distributed by mail or direct delivery to each customer on: _____

One or more of the following methods were used to reach persons not likely to be reached by a mailing or direct delivery (renters, nursing home patients, prison inmates, etc.):

Posted the notice at the following conspicuous locations served by the water system. (If needed, please attach a list of locations). _____

Publication of the notice in a local newspaper or newsletter of general circulation (attach a copy of the published notice, including name of newspaper and date published).

Posted the notice on the Internet at www. _____

Other method used to notify customers. _____

I hereby certify that the above information is factual.

Certified by: Printed Name _____

Signature _____

Title _____

Date _____

DISCLOSURE: Be advised that Section 116725 and 116730 of the California Health and Safety Code state that any person who knowingly makes any false statement on any report or document submitted for the purpose of compliance with the attached order may be liable for a civil penalty not to exceed five thousand dollars (\$5,000) for separate violation for each day that violation continues. In addition, the violators may be prosecuted in criminal court and upon conviction, be punished by a fine of not more than \$25,000 for each day of violation, or be imprisoned in the county jail not to exceed one year, or by both the fine and imprisonment.

Due to the Division of Drinking Water within 10 days of notification to the public
Arsenic MCL Exceedance / Enforcement Action No.: _CO No. 03-12-15R-007

Quarterly Progress Report

Water System:	Pixley PUD	Water System No.:	5410009
Compliance Order No.:	03-12-15R-007	Violation:	Arsenic
Calendar Quarter:		Date Prepared:	

This form should be prepared and signed by Water System personnel with appropriate authority to implement the directives of the Compliance Order and the Corrective Action Plan. Please attach additional sheets as necessary. The quarterly progress report must be submitted by the 10th day of each subsequent quarter, to the Division of Drinking Water, Fresno District Office.

Summary of Compliance Plan:

Tasks completed in the reporting quarter:

Tasks remaining to complete:

Anticipate compliance date:

Name

Signature

Title

Date

DATE: 05/13/15
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

PAGE: 1

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19940101 THRU 20150513
REPORT OF COUNTY: 54 TULARE

SYSTEM NO: 5410009 NAME: PIXLEY PUBLIC UTIL DIST COUNTY: TULARE
SOURCE NO: 005 NAME: WELL 02A PSCODE: 5410009-005 CLASS: CMGA STATUS: AU

GROUP IDENTIFICATION SAMPLE DATE RESULT * MCL DLR TRIGGER UNIT
CONSTITUENT IDENTIFICATION

GROUP IDENTIFICATION	SAMPLE DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
IO INORGANIC						
01002 ARSENIC	03/26/2002 .	20.0000 *	50.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/21/2005 .	23.0000 *	50.0000	2.0000	5.0000	UG/L
01002 ARSENIC	12/18/2007	14.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/21/2008	20.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/15/2008	19.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	01/20/2009	18.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	04/09/2009	20.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/08/2009	4.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/28/2009	24.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	01/28/2010	22.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	04/29/2010	23.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/26/2010	20.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/18/2010	22.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	01/12/2011 .	24.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	04/26/2011 .	23.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/26/2011 .	19.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/28/2011 .	21.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	01/19/2012 .	22.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	04/16/2012 .	20.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/12/2012 .	20.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/16/2012 .	16.0000 *	10.0000	2.0000	5.0000	UG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DATE: 05/13/15
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

PAGE: 2

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19940101 THRU 20150513
REPORT OF COUNTY: 54 TULARE

SYSTEM NO: 5410009 NAME: PIXLEY PUBLIC UTIL DIST
SOURCE NO: 005 NAME: WELL 02A

COUNTY: TULARE
PSCODE: 5410009-005 CLASS: CMGA STATUS: AU

GROUP IDENTIFICATION CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
01002 ARSENIC	01/18/2013 .	20.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	05/14/2013 .	21.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	08/15/2013 .	16.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/29/2013 .	24.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	04/30/2014 .	22.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/31/2014 .	23.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/23/2014 .	21.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	01/21/2015 .	20.0000 *	10.0000	2.0000	5.0000	UG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER

NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DATE: 05/13/15
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

PAGE: 1

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19940101 THRU 20150513
REPORT OF COUNTY: 54 TULARE

SYSTEM NO: 5410009 NAME: PIXLEY PUBLIC UTIL DIST COUNTY: TULARE
SOURCE NO: 004 NAME: WELL 04 PSCODE: 5410009-004 CLASS: CMGA STATUS: AU

GROUP IDENTIFICATION	SAMPLE	RESULT *	MCL	DLR	TRIGGER	UNIT
CONSTITUENT IDENTIFICATION	DATE					

IO INORGANIC						
01002 ARSENIC	04/25/1995	3.0000	50.0000	2.0000	5.0000	UG/L
01002 ARSENIC	09/09/1998	4.0000	50.0000	2.0000	5.0000	UG/L
01002 ARSENIC	03/26/2002	3.0000	50.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/21/2005	4.0000	50.0000	2.0000	5.0000	UG/L
01002 ARSENIC	12/18/2007	4.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/21/2008	4.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/15/2008	3.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	01/20/2009	4.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	04/09/2009	3.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/08/2009	4.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/28/2009	3.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	01/28/2010	5.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	04/29/2010	3.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/26/2010	3.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/18/2010	3.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	01/12/2011	6.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	04/26/2011	5.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/26/2011	5.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/12/2012	4.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	02/04/2014	5.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/31/2014	4.0000	10.0000	2.0000	5.0000	UG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER

NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DATE: 05/13/15
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

PAGE: 1

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19940101 THRU 20150513
REPORT OF COUNTY: 54 TULARE

SYSTEM NO: 5410009 NAME: PIXLEY PUBLIC UTIL DIST COUNTY: TULARE
SOURCE NO: 006 NAME: WELL 03A PSCODE: 5410009-006 CLASS: CMGA STATUS: AU

GROUP IDENTIFICATION	SAMPLE	RESULT *	MCL	DLR	TRIGGER	UNIT
CONSTITUENT IDENTIFICATION	DATE					

IO INORGANIC						
01002 ARSENIC	03/26/2002 .	18.0000 *	50.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/21/2005 .	21.0000 *	50.0000	2.0000	5.0000	UG/L
01002 ARSENIC	12/18/2007	17.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/21/2008	11.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/15/2008	11.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	01/20/2009	15.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	04/09/2009	18.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/08/2009	3.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/28/2009	15.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	01/28/2010	13.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	04/29/2010	24.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/26/2010	6.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/18/2010	9.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	01/12/2011 .	17.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	04/26/2011 .	21.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/26/2011 .	14.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/28/2011 .	21.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	01/19/2012 .	19.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	04/16/2012 .	17.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/12/2012 .	4.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/16/2012 .	11.0000 *	10.0000	2.0000	5.0000	UG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER

NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD

DATE: 05/13/15
REPORT: R-040/2-3

STATE OF CALIFORNIA
DRINKING WATER PROGRAM

PAGE: 2

DRINKING WATER ANALYSES RESULTS REPORT
ALL SAMPLES FOR SELECTED CONSTITUENTS - ALL RESULTS
FOR SAMPLE DATE RANGE OF 19940101 THRU 20150513
REPORT OF COUNTY: 54 TULARE

SYSTEM NO: 5410009 NAME: PIXLEY PUBLIC UTIL DIST COUNTY: TULARE
SOURCE NO: 006 NAME: WELL 03A PSCODE: 5410009-006 CLASS: CMGA STATUS: AU

GROUP IDENTIFICATION CONSTITUENT IDENTIFICATION	SAMPLE DATE	RESULT *	MCL	DLR	TRIGGER	UNIT
01002 ARSENIC	01/18/2013 .	21.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	05/14/2013 .	3.0000	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	08/15/2013 .	22.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/29/2013 .	26.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	02/04/2014 .	20.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	07/31/2014 .	10.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	10/23/2014 .	12.0000 *	10.0000	2.0000	5.0000	UG/L
01002 ARSENIC	01/21/2015 .	13.0000 *	10.0000	2.0000	5.0000	UG/L

NOTE1: * = RESULT IS EQUAL TO OR GREATER THAN TRIGGER
NOTE2: .000 = RESULT WAS REPORTED AS NON-DETECTED EXCEPT FOR RAD