

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

STATE OF CALIFORNIA
STATE WATER RESOURCES CONTROL BOARD

IN RE: Glenview Mobile Park
3438 Siesta Way
Oxnard, CA 93033

TO: Mr. Ernie Hayes, Manager
Mr. Jose Garcia, Owner

SYSTEM NO.: 5602109

CITATION NO.: 04_06_16C_008_5602109_23

CITATION

Section 116650 of Chapter 4, Part 12, Division 104 of the California Health and Safety Code (H&S Code), authorizes the issuance of a citation for failure to comply with the requirements of the California Safe Drinking Water Act, or any regulation, standard, permit or order issued thereunder.

VIOLATION

The State Water Resources Control Board, Division of Drinking Water, (hereinafter Division) hereby issues a citation to the Glenview Mobile Park (hereinafter GMP) for the following violation:



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

1. Section 64423, Title 22, CCR. Specifically, the GMP failed to collect and/or report a routine distribution coliform sample for the month of March 2016.

BACKGROUND

The GMP is a community water system as it serves approximately 100 people through 26 service connections. The system water supply is obtained from one active well (Well No. 02), which is 550 feet deep and has an 8-inch diameter steel casing. The perforations begin at 400 feet. The well has an annular cement seal depth of 370 feet. The water is pumped to a storage tank of 4,500 gallons and then boosted to the distribution system. The well is chlorinated prior to storage.

The Total Coliform Rule requires the GMP to collect one routine coliform sample every month from the system. During the month of March 2016, the GMP failed to collect and/or report the required routine coliform sample, which resulted in non-compliance with Section 64423, Title 22, CCR.

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27


DIRECTIVES

The GMP is hereby directed to take the following actions:

- 1. Immediately, follow proper TCR routine and repeat sampling/reporting procedures in accordance with Article 3, Title 22, CCR, Sections 64423, 64424.
- 2. Within 30 days, the system shall notify the public of the monitoring failure to collect and analyze the required routine bacteriological distribution sample for the month of March 2016.
- 3. A copy of the notification and certification form shall be submitted to:

Jeff Densmore, P.E., District Engineer
 Division of Drinking Water
 Santa Barbara District
 1180 Eugenia, Suite 200
 Carpinteria, CA 93013-2000

APRIL 28, 2016
 Date


 Jeff Densmore, P.E., District Engineer
 Southern California Section
 Santa Barbara District (SWRCB-DDW)

cc: Ventura County Environmental Health



