

- 1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
1. Section 64423, Title 22, CCR. Specifically, the SCMWC failed to collect and/or report a routine distribution coliform sample for the month of September 2016.

BACKGROUND

The CMWC is a community water system as it serves approximately 221 residential customers through 68 service connections, and operates by the authority of a drinking water supply permit, issued by the Division on March 20, 2003. The water supply is obtained from, and is fully treated by the United Water Conservation District. The treated surface water complies with the primary and secondary drinking water standards. The connection to United Water Conservation District provides approximately 90 gallons per minute (gpm) through a 6-inch master meter connection. The CMWC also maintains an emergency connection to the City of Oxnard. Two inactive wells are physically disconnected from the distribution system. The wells are known to have high total dissolved solids (TDS).

The Total Coliform Rule requires CMWC to collect one routine coliform sample every month from the system. During the month of September 2016, CMWC failed to collect and/or report the required routine coliform sample, which resulted in non-compliance with Section 64423, Title 22, CCR.



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

DIRECTIVES

The CMWC is hereby directed to take the following actions:

1. Immediately, follow proper TCR routine and repeat sampling/reporting procedures in accordance with Article 3, Title 22, CCR, Sections 64423, 64424.
2. As soon as possible, but no later than October 1, 2017, the system shall notify the public of the monitoring failure to collect and analyze the required routine bacteriological distribution sample for the month of September 2016.
3. Submit a signed copy of the notice and Proof of Public Notification (attached).
4. A copy of the notification and certification form shall be submitted to:

Jeff Densmore, P.E., District Engineer
 Division of Drinking Water
 Santa Barbara District
 1180 Eugenia, Suite 200
 Carpinteria, CA 93013-2000

OCTOBER 12, 2016
 Date


 Jeff Densmore, P.E., District Engineer
 Southern California Section
 Santa Barbara District (SWRCB-DDW)

cc: Ventura County Environmental Health



