

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LAHONTAN REGION**

**MEETING OF OCTOBER 13 AND 14, 2010
BARSTOW, CALIFORNIA**

- ITEM:** 14
- SUBJECT:** CITY OF VICTORVILLE; WESTWINDS GOLF COURSE, SAN BERNARDINO COUNTY
- CHRONOLOGY:** June 11, 2003 Water Recycling Requirements (Board Order No. R6V-2003-0028)
- March 10, 2010 Amended Water Recycling Requirements (Board Order No. R6V-2003-028A1)
- ISSUE:** Should the Regional Board amend Water Recycling Requirements for Westwinds Golf Course allowing the golf course to use title 22 tertiary treated recycled water produced by the City of Victorville Southern California Logistics Airport Central Wastewater Treatment Plant (SCLA CWTP)?
- DISCUSSION:** Under Board Order No. R6V-2003-028, the City of Victorville Westwinds Golf Course is currently authorized to use title 22 standard tertiary treated recycled water produced by the Victor Valley Wastewater Reclamation Authority (VWVRA) Wastewater Treatment Plant. Under this amendment, the City of Victorville Westwinds Golf Course will be authorized to use title 22 tertiary treated recycled water produced by the City's SCLA CWTP. The proposed Board Order amends Board Order No. R6V-2003-028 to allow the use of recycled water by the Westwinds Golf Course produced by the SCLA CWTP.
- Comments on the Tentative Order were solicited from interested parties. Comments were received from the City of Victorville concurring with the proposed Order.
- RECOMMENDATION:** Adoption of the Order as proposed.
- Enclosures:** 1. Proposed Board Order
2. Comments received from Interested Parties

ENCLOSURE 1

14-0002

CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LAHONTAN REGION

BOARD ORDER NO. R6V-2003-0028A2 (PROPOSED)
WDID NO. 6B360207001

AMENDED WATER RECYCLING REQUIREMENTS

FOR

CITY OF VICTORVILLE
WESTWINDS GOLF COURSE

San Bernardino County

The California Regional Water Quality Control Board, Lahontan Region (Water Board) finds:

1. User – Producer - Distributor

The City of Victorville Westwinds Golf Course hereafter "User," proposes to receive title 22 tertiary treated recycled water from the City of Victorville Southern California Logistics Airport Central Wastewater Treatment Plant (SCLA CWTP), hereinafter "Producer". The City of Victorville is the "Distributor" for conveying recycled water from the SCLA CWTP to the User. For purposes of this Order, "recycled water" is defined in the California Water Code (CWC), section 13050(n) as water that as a result of waste treatment, is suitable for a direct beneficial use or a controlled use that would not otherwise occur and is therefore considered a valuable resource. Recycled water defined in section 13050(n) and "reclaimed water" as used in CWC section 13523 are synonymous.

2. Other Related Requirements

Board Order No. R6V-2003-028, adopted on June 11, 2003, authorizes the Victor Valley Wastewater Reclamation Authority (VWRA), as a producer, to provide title 22 tertiary treated wastewater from the Victor Valley Municipal Wastewater Treatment Plant for use at the Westwinds Golf Course. The Order also authorizes the City of Victorville, as the User, to receive VWRA supplied recycled water for irrigation use at the City of Victorville Westwinds Golf Course.

Board Order No. R6V-2010-0023, adopted on June 9, 2010, authorizes the City of Victorville, to produce and provide title 22 tertiary treated wastewater from the SCLA CWTP for use at both the Westwinds Golf Course and the High Desert Power Plant.

3. Reason for Action

The purpose of this Amendment is to authorize the City of Victorville Westwinds Golf Course to receive and use title 22 recycled water supplied from the City of Victorville SCLA CWTP. CWC, section 13523 provides the authority by which the Water Board can prescribe water reclamation (recycling) requirements for users and/or producers of recycled water, following consultation with the California Department of Public Health (CDPH).

California Code of Regulations (CCR), title 22, section 60323 requires the submittal of an Engineering Report to the CDPH for any proposed wastewater reuse. On February 25, 2010, the Producer submitted an Engineering Report for production of recycled water from the SCLA CWTP. In the report, the Producer identified Westwinds Golf Course as a user. CDPH provided its comments and accepted the Engineering Report on April 8, 2010.

4. Recycled Water Transmission and Distribution

The City of Victorville will deliver recycled water from the SCLA CWTP to the Westwinds recycled water elevated tank through a recycled water pipeline. The delivery of recycled water to the Westwinds Golf Course is through the City's recycled water distribution system.

5. Description of Producer's Treatment Plant

The City of Victorville will produce disinfected tertiary wastewater from the SCLA CWTP. The treated wastewater must meet CCR title 22 requirements for irrigation use.

6. California Environmental Quality Act (CEQA)

The continued operation of this existing facility with minor modifications under these amended Water Recycling Requirements is exempt from the provisions of the CEQA (Public Resources Code, section 21000 et seq.) in accordance with title 14, CCR, section 15301.

7. Notice of Interested Parties

The Water Board has notified the User, Producer, Distributor, and interested persons of its intent to amend Water Recycling Requirements for the Westwinds Golf Course.

8. Consideration of Public Comments

The Water Board, in a public meeting, heard and considered all comments pertaining to the recycled water use project.

IT IS HEREBY ORDERED pursuant to CWC, sections 13523, 13263, and 13267 that the User must comply with the following amended requirements:

Replace the language of item "C" in Section III. of Board Order No. R6V-2003-0028 as follows. Add new items "K", "L" and "M".

III. General Requirements and Prohibitions for Recycled Water Use Applicable to Both the Producer and User

- C. A copy of these requirements shall be maintained at the Producer's Facilities and at the Westwinds Golf Course to be available at all times to operating personnel.
- K. All requirements contained in Board Order No. R6V-2003-028 and R6V-2003-028A1 remain in effect.
- L. Pursuant to CWC, section 13267, sub-division (b), the User must comply with the Monitoring and Reporting Program of Board Order No. R6V-2003-028.
- M. The Water Board may change all or any portion of this Order upon legal notice to and after opportunity to be heard is given to all concerned parties.

I, Harold J. Singer, Executive Officer, do hereby certify that the foregoing is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, Lahontan Region, on October 14, 2010.

HAROLD J. SINGER
EXECUTIVE OFFICER

ENCLOSURE 2

14-0006

CRWQCB REGS

REC'D	DECEMBER
JM	SEP 9
FILE	2010
By	

Notice
Submittal of Written Material for Regional Board Consideration

In order to ensure that the State of California Lahontan Regional Water Quality Control Board has the opportunity to fully study and consider written material, it is necessary to submit it at least ten (10) days before the Regional Board Meeting. Pursuant to Title 23 of the California Code of Regulations, Section 648.2, the Regional Board may refuse to admit written testimony into evidence unless the proponent can demonstrate why he or she was unable to submit the material on time or that compliance with the deadline would otherwise create a hardship. If any other party demonstrates prejudice resulting from admission of the written testimony, the Regional Board may refuse to admit it.

COMPLETE FORM AND RETURN

To: CA Regional Water Quality Control Board, Lahontan Region
 14440 Civic Drive, Suite 200
 Victorville, CA 92392
 ATTN: John Morales

Comments on WASTE DISCHARGE REQUIREMENTS FOR WESTWINDS GOLF COURSE, SAN BERNARDINO COUNTY

We concur with proposed requirements

We concur; comments attached

We do not concur; comments attached

Jan Carlson (Sign)

Laine Carlson (on behalf of Reggie Lamson) (Type or print name)

City of Victorville (Organization)

14343 Civic Dr. (Address)

Victorville, CA 92392 (City and State)

760 955 2741 (Telephone)

14-0007

CITY OF
VICTORVILLE



760.955.5000
FAX 760.245.7243
vville@ci.victorville.ca.us
http://ci.victorville.ca.us

14343 Civic Drive
P.O. Box 5001
Victorville, California 92393-5001

September 2, 2010

John Morales, P.E.
Water Resources Control Engineer
California Regional Water Quality Control Board, Lahontan Region
14440 Civic Drive, Suite 200
Victorville, CA 92392

Re: Comments on Tentative Amended Waste Discharge Requirements for Westwinds Golf Course
WDID 6B360207001

Dear Mr. Morales,

City staff has reviewed the Tentative Amended Waste Discharge Requirements for Westwinds Golf Course dated August 5, 2010 and would like to suggest a modification to Section 4, Recycled Water Transmission and Distribution. This section states "The City of Victorville will deliver recycled water from the SCLA CWTP to the Westwinds wastewater elevated tank through the receiving pond." To more accurately describe our transmission system, we recommend that sentence be replaced with the following:

"The City of Victorville will deliver recycled water from the SCLA CWTP to the recycled water elevated tank located near Westwinds Golf Course through a reclaimed water pipeline."

Thank you for the opportunity to comment and please feel free to contact me if you have any questions.

Sincerely,

Laine Carlson
Assistant Engineer

14-0008