

Attachment B – Monitoring for Constituents of Emerging Concerns (CECs) ^[1]

Constituent	Reporting Limit (µg/L)
17β-Estradiol	0.001
Caffeine	0.05
NDMA	0.002
Triclosan	0.05
DEET	0.05
Sucralose	0.1

^[1]CECs are based on Table 1 Groundwater Recharge Reuse – Subsurface Application of State Water Board Resolution 2013-003