

Chou, Rebecca@Waterboards

From: Chou, Rebecca@Waterboards
Sent: Friday, August 26, 2016 3:58 PM
To: Steve Dahlberg (stevendahlberg@msn.com); Rita Kampalath (rkampalath@healthebay.org)
Cc: Barbara Bradley (Barbara.bradley@advonsys.com); Craig George (cgeorge@malibucity.org); Michelle Tsiebos (mtsiebos@ph.lacounty.gov); Steve Brabant (sbrabant@biosolutions.org); Wu, Eric@Waterboards; Zhang, Luyue@Waterboards; Carlos, Alex@Waterboards; Smith, Deborah@Waterboards (Deborah.Smith@waterboards.ca.gov); Fordyce, Jennifer@Waterboards; Unger, Samuel@Waterboards (Samuel.Unger@waterboards.ca.gov); Quidilla, Clarita@Waterboards (Clarita.Quidilla@waterboards.ca.gov)
Subject: RE: Paradise Cove MHP_Revised Tent WDRs-WRRs, MRP and CDO, CI 8342_2016-08-25
Attachments: CI 8342 RevTentative WDRs-WRRs ParadiseCove 2016.08.26 Final Beach Cafe GW and effluent limites.pdf

On Thursday, August 25, 2016, you were sent electronic versions of the following items related to Paradise Cove in preparation for the September 8th Board meeting:

1. Response to Comments;
2. Revised tentative WDRs/WRRs Order No. R4-2016-XXXX;
3. Revised tentative Monitoring and Reporting Program No.8342; and,
4. Revised tentative Cease and Desist Order No.R4-2016-XXX

We hereby submit a 2nd revised tentative WDRs/WRRs (Order No. R4-2016-XXXX) dated August 26, 2016 (attached) to replace the one dated August 25, 2016 that you received yesterday. Two changes have been made to this order. They are notated in track changes.

The first change is a clarifying change that revises the title to Table 6. **Groundwater Limitations for Paradise Cove Mobile Home Park and Paradise Cove Wastewater Treatment Plant (combined system)** and that adds a new Table 7. **Groundwater Limitations for Paradise Cove Beach Café from September 8, 2016 to August 31, 2018 only.** These changes clarify what groundwater limitations apply to groundwater wells that are used for the currently used separate treatment and disposal systems vs. what groundwater limitations apply to the wells used for the planned combined system. This was described in Finding 54, but was not fully integrated into the section B. GROUNDWATER LIMITATIONS.

The second change is adding an effluent limit for *Enterococcus* to Table 5. This limit is applicable to Beach Café effluent from September 8, 2016 to August 31, 2018. There is currently a groundwater limit for *Enterococcus* but not an effluent limit. This effluent limit is proposed following the review of recently submitted effluent monitoring data that show a previous period of discharging at levels that met the Ocean Plan standards for *Enterococcus* followed by recent higher levels in the second quarter 2016. This illustrates that the disinfection system can operate properly to meet the limits, but that operational changes are needed to bring the system back into proper operation to be able to comply with Ocean Plan standards for *Enterococcus*.

Written comments will be accepted on these two changes only by 5pm, Thursday, September 1, 2016.

If you have any questions, please contact Chief of Groundwater Permitting, Dr. Eric Wu at 213-576-6683 or Eric.Wu@waterboards.ca.gov.

Rebecca Chou, Ph.D., P.E.
Section Chief of Groundwater Permitting and Land Disposal
Regional Water Quality Control Board – Los Angeles Region
California Environmental Protection Agency
320 W. 4th Street, Suite 200
Los Angeles, CA 90013
Phone: 213-576-6618
Fax: 213-576-5777
Email: Rebecca.Chou@waterboards.ca.gov



From: Quidilla, Clarita@Waterboards
Sent: Thursday, August 25, 2016 1:01 PM
To: Steve Dahlberg (stevendahlberg@msn.com); Rita Kampalath (rkampalath@healthebay.org)
Cc: Barbara Bradley (Barbara.bradley@advonsys.com); Craig George (cgeorge@malibucity.org); Michelle Tsiebos (mtsiebos@ph.lacounty.gov); Steve Brabant (sbraband@biosolutions.org); Chou, Rebecca@Waterboards; Wu, Eric@Waterboards; Zhang, Luyue@Waterboards; Carlos, Alex@Waterboards
Subject: Paradise Cove MHP_Revised Tent WDRs-WRRs, MRP and CDO, CI 8342_2016-08-25

The California Regional Quality Control Board for the Los Angeles Region (Regional Board) provides copies of correspondence through e-mail. The attached is your copy of recent correspondence; only the addressee will receive a hard copy.

The letter is in Adobe Acrobat PDF format. You can obtain an Acrobat Reader free of charge at <http://www.adobe.com/products/acrobat/readstep2.html>.

Please contact the project manager, Dr. Eric Wu at (213) 576-6683 if you have any questions.

Thank you,

Clarita S. Quidilla
Staff Services Analyst
CA Regional Water Quality Control Board
Los Angeles Region 4
Phone #: (213) 576-6632
Fax #: (213) 576-6640