



**California Regional Water Quality Control Board
North Coast Region
John W. Corbett, Chairman**



Arnold Schwarzenegger
Governor

Linda S. Adams
**Secretary for
Environmental Protection**

www.waterboards.ca.gov/northcoast
5550 Skylane Boulevard, Suite A, Santa Rosa, California 95403
Phone: (877) 721-9203 (toll free) • Office: (707) 576-2220 • FAX: (707) 523-0135

**ORDER NO. R1-2008-0001
NPDES NO. CA0023671
WDID NO. 1B80081OHUM**

**WASTE DISCHARGE REQUIREMENTS
FOR THE
LOLETA COMMUNITY SERVICES DISTRICT
WASTEWATER TREATMENT FACILITY**

The following Discharger is subject to waste discharge requirements as set forth in this Order:

Table 1. Discharger Information

Discharger	Loleta Community Services District
Name of Facility	Wastewater Treatment Facility
Facility Address	298 Eel River Drive
	Loleta, CA 95551
	Humboldt County
The U.S. Environmental Protection Agency (USEPA) and the Regional Water Quality Control Board have classified this discharge as a minor discharge.	

The discharge by the Loleta Community Services District from the discharge points identified below is subject to waste discharge requirements as set forth in this Order:

Table 2. Discharge Location

Discharge Point	Effluent Description	Discharge Point Latitude	Discharge Point Longitude	Receiving Water
001	Secondary Treated Municipal Wastewater	40 ° , 38 ' , 23" N	124 ° , 13 ' , 37 " W	Wetland Tributary to the Eel River

Table 3. Administrative Information

This Order was adopted by the Regional Water Quality Control Board on:	March 6, 2008
This Order shall become effective on:	May 1, 2008
This Order shall expire on:	May 1, 2013
The Discharger shall file a Report of Waste Discharge in accordance with title 23, California Code of Regulations, as application for issuance of new waste discharge requirements no later than:	180 days prior to the Order expiration date (November 1, 2012)

IT IS HEREBY ORDERED, that Order No. R1-2001-59 is rescinded upon the effective date of this Order except for enforcement purposes, and, in order to meet the provisions contained in division 7 of the California Water Code (commencing with section 13000)

and regulations adopted thereunder, and the provisions of the federal Clean Water Act (CWA) and regulations and guidelines adopted thereunder, the Discharger shall comply with the requirements in this Order.

I, Robert R. Klamt, Interim Executive Officer, do hereby certify that this Order with all attachments is a full, true, and correct copy of an Order adopted by the California Regional Water Quality Control Board, North Coast Region, on **March 6, 2008**.

Robert R. Klamt
Interim Executive Officer

DRAFT

Table of Contents

I.	Facility Information	A-5
II.	Findings.....	A-2
III.	Discharge Prohibitions	A-8
IV.	Effluent Limitations and Discharge Specifications	A-9
	A. Effluent Limitations – Discharge Point 001	A-9
	1. Final Effluent Limitations – Discharge Point 001	A-9
	2. Interim Effluent Limitations	A-10
	B. Land Discharge Specifications	A-10
	C. Reclamation Specifications	A-10
V.	Receiving Water Limitations.....	A-10
	A. Surface Water Limitations	A-11
	B. Groundwater Limitations.....	A-11
VI.	Provisions.....	A-13
	A. Standard Provisions	A-13
	B. Monitoring and Reporting Program (MRP) Requirements	A-13
	C. Special Provisions	A-13
	1. Reopener Provisions	A-13
	2. Special Studies, Technical Reports and Additional Monitoring Requirements ..	A-14
	3. Best Management Practices and Pollution Prevention.....	A-18
	4. Construction, Operation and Maintenance Specifications	A-18
	5. Special Provisions for Municipal Facilities (POTWs Only).....	A-19
	6. Other Special Provisions	A-23
	7. Compliance Schedules.....	A-23
VII.	Compliance Determination	A-24
	A. General.....	A-24
	B. Multiple Sample Data	A-24
	C. Average Monthly Effluent Limitation (AMEL).....	A-24
	D. Average Weekly Effluent Limitation (AWEL).....	A-24
	E. Maximum Daily Effluent Limitation (MDEL).....	A-24
	F. Instantaneous Minimum Effluent Limitation.....	A-25
	G. Instantaneous Maximum Effluent Limitation.....	A-25

List of Tables

Table 1.	Discharger Information	1
Table 2.	Discharge Location.....	1
Table 3.	Administrative Information.....	1
Table 4.	Facility Information	A-5
Table 5.	Basin Plan Beneficial Uses.....	A-5
Table 6.	Effluent Limitations	A-9

List of Attachments

Attachment A – Definitions A-1
Attachment B – Map..... B-1
Attachment C – Flow Schematic C-1
Attachment D – Standard Provisions..... D-1
Attachment E – Monitoring and Reporting Program (MRP)..... E-1
Attachment F – Fact Sheet..... F-1

DRAFT

I. FACILITY INFORMATION

The following Discharger is subject to waste discharge requirements as set forth in this Order:

Table 4. Facility Information

Discharger	Loleta Community Services District
Name of Facility	Wastewater Treatment Facility
Facility Address	298 Eel River Drive
	Loleta, CA 95551
	Humboldt County
Facility Contact, Title, and Phone	Marcus Drumm, (707) 733-1717
Mailing Address	Loleta Community Services District, P.O. Box 236, Loleta, CA 95551
Type of Facility	Publicly Owned Treatment Works
Facility Design Flow	0.081 millions of gallons per day (MGD) (average dry weather)
	0.143 MGD (average wet weather)

II. FINDINGS

The California Regional Water Quality Control Board, North Coast Region (hereinafter the Regional Water Board), finds:

- A. Background.** The Loleta Community Services District (hereinafter the Discharger) is currently discharging pursuant to Order No. R1-2001-59 and National Pollutant Discharge Elimination System (NPDES) Permit No. CA0023671. The Discharger submitted a Report of Waste Discharge, dated December 28, 2005, and applied for an NPDES permit renewal to discharge up to 0.1 MGD (average dry weather design rate) of secondary treated wastewater from the Loleta Community Services District Wastewater Treatment Facility (hereinafter Facility or WWTF). For the purposes of this Order, references to the “discharger” or “permittee” in applicable federal and State laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.
- B. Facility Description.** The Discharger owns and operates a municipal wastewater collection system and treatment facility which serves a residential population of less than 1000 and two significant industrial facilities – a cheese making plant owned by the Loleta Cheese Company and a creamery owned by the Humboldt Creamery Association, a cooperative of local dairy farmers. The treatment facility has a design capacity of 100,000 gallons per day (GPD) and includes an aeration basin, clarifier, sludge storage vault, and chlorination/dechlorination capability. Treated wastewater is currently discharged to a wetland, which is tributary to an unnamed slough (hereinafter slough), and the Eel River, at Discharge Point 001, approximately 3,500 feet southwest of the treatment plant. The receiving water is located within the Eel River Hydrologic Unit and is a water of the United States. Attachment B provides a map of the area around the facility. Attachment C provides a flow schematic of the facility.
- C. Legal Authorities.** This Order is issued pursuant to section 402 of the federal Clean Water Act (CWA) and implementing regulations adopted by the USEPA and chapter 5.5, division 7 of the California Water Code (commencing with section 13370). It shall serve as an NPDES permit for point source discharges from this facility to surface waters. This Order also serves as Waste Discharge Requirements (WDRs) pursuant to article 4, chapter 4, division 7 of the Water Code (commencing with section 13260).

The CWA authorizes the USEPA to permit a state to serve as the NPDES permitting authority in lieu of the USEPA. The State of California has an in-lieu authority of the NPDES program. The State Water Board entered into a Memorandum of Agreement with the USEPA on September 22, 1989, to administer the NPDES program governing discharges to waters of the United States. The Porter-Cologne Water Quality Control Act authorizes the State Water

Board, through the Regional Water Board, to regulate and control the discharge of pollutants to waters of the state.

- D. Background and Rationale for Requirements.** The Regional Water Board developed the requirements in this Order based on information submitted as part of the application, through monitoring and reporting programs, and other available information. The Fact Sheet (Attachment F), which contains background information and rationale for Order requirements, is hereby incorporated into this Order and constitutes part of the Findings for this Order. Attachments A through E are also incorporated into this Order.
- E. California Environmental Quality Act (CEQA).** Under Water Code section 13389, this action to adopt an NPDES permit is exempt from the provisions of CEQA, Public Resources Code sections 21100 - 21177.
- F. Technology-Based Effluent Limitations.** Section 301(b) of the CWA and implementing USEPA permit regulations at section 122.44, title 40 of the Code of Federal Regulations¹, require that permits include conditions meeting applicable technology-based requirements at a minimum, and any more stringent effluent limitations necessary to meet applicable water quality standards. The discharge authorized by this Order must meet minimum federal technology-based requirements based on Secondary Treatment Standards at 40 CFR Part 133 and/or Best Professional Judgment (BPJ) in accordance with 40 CFR Part 125, section 125.3. A detailed discussion of the technology-based effluent limitations development is included in the Fact Sheet.
- G. Water Quality-Based Effluent Limitations.** Section 301(b) of the CWA and section 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards. Section 122.44(d)(1)(i) mandates that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, water quality-based effluent limitations (WQBELs) must be established using: (1) USEPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, such as a proposed state criterion or policy interpreting the state's narrative criterion, supplemented with other relevant information, as provided in section 122.44(d)(1)(vi).

¹ All further statutory references are to title 40 of the Code of Federal Regulations unless otherwise indicated.

H. Water Quality Control Plans. The Regional Water Board adopted a *Water Quality Control Plan for the North Coast Region* (hereinafter Basin Plan) that designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. The Basin Plan at page 2-1 states that the beneficial uses of any specifically identified water body generally apply to its tributary streams. The Basin Plan specifies some beneficial uses for the wetland, but does not specifically identify beneficial uses for the slough conveying discharges from the Loleta Community Services District wastewater treatment facility once they have entered the wetland. However, the Basin Plan does identify present and potential uses for the Eel River, to which both the wetland and slough are tributary. The Basin Plan implements State Water Resources Control Board (State Water Board) Resolution No. 88-63, which establishes state policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply. Beneficial uses applicable to the receiving water for discharges from the Loleta Community Services District wastewater treatment facility, being tributary to the Eel River, are described in Table 5, below.

DRAFT

Table 5. Basin Plan Beneficial Uses

Discharge Point	Receiving Water	Beneficial Use(s)
001	Wetland, tributary to the Eel River	<p><u>Existing:</u> MUN – Municipal and Domestic Supply AGR – Agricultural Supply IND – Industrial Service Supply GWR – Groundwater Recharge FRSH – Freshwater Replenishment NAV – Navigation REC1 – Water Contact Recreation REC2 – Non-Contact Water Recreation COMM – Commercial and Sport Fishing COLD – Cold Freshwater Habitat WILD – Wildlife Habitat RARE – Preservation of Rare, Threatened, or Endangered Species MIGR – Migration of Aquatic Organisms SPWN – Spawning, Reproduction, and/or Early Development SHELL – Shellfish Harvesting EST – Estuarine Habitat CUL – Native American Culture WET – Wetland Habitat</p> <p><u>Potential:</u> PRO – Industrial Process Supply POW – Hydropower Generation MAR – Marine Habitat AQUA – Aquaculture FLD – Flood Peak Attenuation/Flood Water Storage WQE – Water Quality Enhancement</p>

Section 303(d) of the federal Clean Water Act requires that states identify waters within its boundaries for which technology-based effluent limitations are not stringent enough to achieve applicable water quality standards for those waters. Although the main stem of the Lower Eel River is identified on the State’s 303(d) list as impaired by sediment and temperature, the specific receiving water for this discharge is not 303(d) listed. Requirements of this Order implement the Basin Plan.

- I. **National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on December 22, 1992, and later amended it on May 4, 1995 and November 9, 1999. About forty criteria in the NTR applied in California. On May 18, 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the state. The CTR was amended on February 13, 2001. These rules contain water quality criteria for priority pollutants, which are applicable to the receiving water for discharges from the Loleta Community Services District wastewater treatment facility.

- J. State Implementation Policy.** On March 2, 2000, the State Water Board adopted the *Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California* (State Implementation Policy or SIP). The SIP became effective on April 28, 2000 with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on May 18, 2000 with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005 that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.
- K. Compliance Schedules and Interim Requirements.** Section 2.1 of the SIP provides that, based on a Discharger's request and demonstration that it is infeasible for an existing Discharger to achieve immediate compliance with an effluent limitation derived from a CTR criterion, compliance schedules may be allowed in an NPDES permit. Unless an exception has been granted under section 5.3 of the SIP, a compliance schedule may not exceed 5 years from the date that the permit is issued or reissued, nor may it extend beyond 10 years from the effective date of the SIP (or May 18, 2010) to establish and comply with CTR criterion-based effluent limitations. Where a compliance schedule for a final effluent limitation exceeds 1 year, the Order must include interim numeric limitations for that constituent or parameter. Where allowed by the Basin Plan, compliance schedules and interim effluent limitations or discharge specifications may also be granted to allow time to implement a new or revised water quality objective. This Order does not include interim effluent limitations or schedules for compliance with final limitations.
- L. Alaska Rule.** On March 30, 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards (WQS) become effective for CWA purposes. (40 C.F.R. § 131.21; 65 Fed. Reg. 24641 (April 27, 2000).) Under the revised regulation (also known as the Alaska Rule), new and revised standards submitted to USEPA after May 30, 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by May 30, 2000 may be used for CWA purposes, whether or not approved by USEPA.
- M. Stringency of Requirements for Individual Pollutants.** This Order contains both technology-based and water quality-based effluent limitations for individual pollutants. The technology-based effluent limitations consist of restrictions on biological oxygen demand (BOD), suspended solids, settleable solids, and total coliform bacteria. Restrictions on BOD, suspended solids, settleable solids, and

total coliform bacteria are discussed in Section IV.B of the Fact Sheet. This Order's technology-based pollutant restrictions implement the minimum, applicable federal technology-based requirements.

Water quality-based effluent limitations have been scientifically derived to implement water quality objectives that protect beneficial uses. Both the beneficial uses and the water quality objectives have been approved pursuant to federal law and are the applicable federal water quality standards. To the extent that toxic pollutant water quality-based effluent limitations are derived from the CTR, the CTR is the applicable standard pursuant to 40 CFR section 131.38. The scientific procedures for calculating the individual water quality-based effluent limitations for priority pollutants are based on the CTR-SIP, which was approved by USEPA on May 18, 2000. Most beneficial uses and water quality objectives contained in the Basin Plan were approved under state law and submitted to and approved by USEPA prior to May 30, 2000. Any water quality objectives and beneficial uses not submitted to USEPA prior to May 30, 2000, or not approved by USEPA before that date, are nonetheless "applicable water quality standards for purposes of the CWA" pursuant to section 131.21(c)(1). Collectively, this Order's restrictions on individual pollutants are no more stringent than required to implement the requirements of the CWA.

- N. Antidegradation Policy.** Section 131.12 requires that the state water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution No. 68-16. Resolution No. 68-16 incorporates the federal antidegradation policy where the federal policy applies under federal law. Resolution No. 68-16 requires that existing quality of waters be maintained unless degradation is justified based on specific findings. The Regional Water Board's Basin Plan implements, and incorporates by reference, both the state and federal antidegradation policies. As discussed in detail in the Fact Sheet under sections III.C.6. and IV.D.2. the permitted discharge is consistent with the antidegradation provisions of section 131.12 and State Water Board Resolution No. 68-16.
- O. Anti-Backsliding Requirements.** Sections 402(o)(2) and 303(d)(4) of the CWA and federal regulations at title 40, Code of Federal Regulations section 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require effluent limitations in a reissued permit to be as stringent as those in the previous permit, with some exceptions where limitations may be relaxed. All effluent limitations in this Order are at least as stringent as the effluent limitations in the previous Order (see sections III.C.7. and IV.D.1. of the Fact Sheet).
- P. Endangered Species Act.** This Order does not authorize any act that can result in the taking of a threatened or endangered specie or any act that is now prohibited, or becomes prohibited in the future, under either the California Endangered

Species Act (Fish and Game Code sections 2050 to 2097) or the Federal Endangered Species Act (16 U.S.C.A. sections 1531 to 1544). This order requires compliance with effluent limits, receiving water limits, and other requirements to protect the beneficial uses of waters of the state. The discharger is responsible for meeting all requirements of the applicable Endangered Species Act.

- Q. Monitoring and Reporting.** Section 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. Water Code sections 13267 and 13383 authorize the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program establishes monitoring and reporting requirements to implement federal and State requirements. This Monitoring and Reporting Program is provided in Attachment E.
- R. Standard and Special Provisions.** Standard Provisions, which apply to all NPDES permits in accordance with section 122.41, and additional conditions applicable to specified categories of permits in accordance with section 122.42, are provided in Attachment D. The discharger must comply with all standard provisions and with those additional conditions that are applicable under section 122.42. The Regional Water Board has also included in this Order special provisions applicable to the Discharger. Rationale for the special provisions contained in this Order is provided in section VII.C.2. of the attached Fact Sheet.
- S. Provisions and Requirements Implementing State Law.** The provisions/requirements in subsection VI.C.2 of this Order are included to implement state law only. These provisions/requirements are not required or authorized under the federal CWA; consequently, violations of these provisions/requirements are not subject to the enforcement remedies that are available for NPDES violations, but may be subject to enforcement remedies under the California Water Code.
- T. Notification of Interested Parties.** The Regional Water Board has notified the Discharger and interested agencies and persons of its intent to prescribe Waste Discharge Requirements for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Details of notification are provided in the Fact Sheet of this Order.
- U. Consideration of Public Comment.** The Regional Water Board, in a public meeting, heard and considered all comments pertaining to the discharge. Details of the Public Hearing are provided in the Fact Sheet of this Order.

III. DISCHARGE PROHIBITIONS

- A. The discharge of any waste not disclosed by the Discharger or not within the reasonable contemplation of the Regional Water Board is prohibited.

- B. Creation of a pollution, contamination, or nuisance, as defined by CWC Section 13050 is prohibited.
- C. The discharge of sludge or digester supernatant is prohibited, except as authorized under Section VI.C.5.d. (Solids Disposal and Handling).
- D. The discharge or reclamation of untreated or partially treated waste (receiving a lower level of treatment than described in Section II.A of the Fact Sheet) from anywhere within the collection, treatment, or disposal facility is prohibited, except as provided for in Attachment D, Standard Provision I.G (Bypass Provision).
- E. Discharges of waste to the Eel River and its tributaries are prohibited during the period May 15 through September 30 each year.
- F. During the period of October 1 through May 14, discharges of wastewater shall not exceed one percent of the flow of the receiving water. To comply with this flow prohibition, (1) the Discharger shall adjust the discharge rate of treated wastewater at least once daily to avoid exceeding one percent of the most recent daily flow measurement of the Eel River as measured at the Scotia gauging station (USGS Station 11477000) combined with the flow as measured at the Grizzly Creek gauging station (USGS Station 11478500); and (2) the total volume of treated wastewater discharged in a calendar month shall not exceed, in any circumstances, one percent of the total volume of the Eel River passing the Scotia and Grizzly Creek gauging stations in the same calendar month.
- G. The discharge of waste to land that is not owned by or under agreement for use by the Discharger is prohibited.
- H. The discharge of waste at any point not described in Finding II.B. or authorized by the State Water Board or another Regional Water Board permit is prohibited.

IV. EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

A. Effluent Limitations – Discharge Point 001

1. Final Effluent Limitations – Discharge Point 001

- a. The Discharger shall maintain compliance with the following effluent limitations at Discharge Point 001, with compliance measured at Monitoring Location M-001 as described in the attached Monitoring and Reporting Program (MRP):

Table 6. Effluent Limitations

Parameter	Units	Effluent Limitations		
		Average Monthly ^a	Average Weekly ^a	Maximum Daily ^a
Biochemical Oxygen Demand 5-Day @ 20°C (BOD ₅)	mg/L	30	45	60
	lbs/day	25	38	50
Total Suspended Solids (TSS)	mg/L	30	45	60
	lbs/day	25	38	50
Settleable Solids	ml/L	0.1	--	0.2
pH	standard units	Not less than 6.5 nor greater than 8.5		
Total Coliform Bacteria	MPN/100 mL	23 ^b	--	230 ^c
Chronic Toxicity	TUc	1.0	--	--

Parameter	Units	Effluent Limitations		
		Average Monthly ^a	Average Weekly ^a	Maximum Daily ^a
Total Residual Chlorine	mg/L	No detectable levels using a minimum detection limit of 0.1 mg/L		

^a See attachment A for definitions.

^b The monthly total coliform bacteria limitation is expressed as the 30-day median - the median of all effluent samples collected in a 30-day calendar period.

^c No sample shall exceed an MPN (most probable number) of 230 total coliform bacteria per 100 mL.

- b. **Percent Removal:** The average monthly percent removal of BOD₅ and TSS shall not be less than 85 percent. Percent removal shall be determined from the 30-day average value of influent wastewater concentration in comparison to the 30-day average value of effluent concentration for the same constituent over the same time period. [40 CFR 133.101(j)].
- c. **Total residual chlorine** concentration shall be maintained at 1.5 mg/L at the end of the disinfection process; and, using a minimum detection level of 0.1 mg/L, there shall be no detectable level of chlorine in effluent at Discharge Point 001.
- d. **Acute Toxicity:** As measured at Monitoring Location M-001, there shall be no acute toxicity in the effluent when discharging to the wetland, which is tributary to a slough and the Eel River. The Discharger will be considered in compliance with this limitation when the survival of aquatic organisms in a 96-hour bioassay, using undiluted effluent, complies with the following:
 - (1) Minimum for any one bioassay: 70 percent survival, and
 - (2) Median for any three or more consecutive bioassays: at least 90 percent survival.
 Compliance with this effluent limitation shall be determined in accordance with Section V. A of the MRP (Attachment E).

2. Interim Effluent Limitations

This Section does not apply to the Loleta Wastewater Treatment Facility.

B. Land Discharge Specifications

This Section does not apply to the Loleta Wastewater Treatment Facility.

C. Reclamation Specifications

This Section does not apply to the Loleta Wastewater Treatment Facility.

V. RECEIVING WATER LIMITATIONS

A. Surface Water Limitations

Receiving water limitations are based on water quality objectives contained in the Basin Plan and are a required part of this Order. The discharge shall not cause the following in the Eel River or tributaries to the Eel River:

1. The waste discharge shall not cause the dissolved oxygen concentration of the receiving waters to be depressed below 7.0 mg/L. Additionally, the discharge shall not cause the dissolved oxygen content of the receiving water to fall below 10.0 mg/L more than 50 percent of the time, or below 7.5 mg/L more than 10 percent of the time. In the event that the receiving waters are determined to have dissolved oxygen concentration of less than 7.0 mg/L, the discharge shall not depress the dissolved oxygen concentration below the existing level.
2. The waste discharge shall not cause the specific conductance (micromhos²) concentration of the receiving waters to increase above 225 micromhos 50 percent of the time, or above 375 micromhos more than 10 percent of the time.
3. The waste discharge shall not cause the total dissolved solids concentration of the receiving waters to increase above 140 mg/l more than 50 percent of the time, or above 275 mg/l more than 10 percent of the time.
4. The discharge shall not cause the pH of the receiving waters to be depressed below 6.5 nor raised above 8.5. Within this range, the discharge shall not cause the pH of the receiving waters to be changed at any time more than 0.5 units from normal ambient pH levels. If the pH of the receiving water is less than 6.5, the discharge shall not cause a further depression of the pH of the receiving water. If the pH of the receiving water is greater than 8.5, the discharge shall not cause a further increase in the pH of the receiving water.
5. The discharge shall not cause the turbidity of the receiving waters to be increased more than 20 percent above naturally occurring background levels.
6. The discharge shall not cause the receiving waters to contain floating materials, including, but not limited to, solids, liquids, foams, and scum, in concentrations that cause nuisance or adversely affect beneficial uses.
7. The discharge shall not cause the receiving waters to contain taste- or odor-producing substances in concentrations that impart undesirable tastes or odors to fish flesh or other edible products of aquatic origin, that cause nuisance, or that adversely affect beneficial uses.

² Measured at 77° F.

8. The discharge shall not cause coloration of the receiving waters that causes nuisance or adversely affects beneficial uses.
9. The discharge shall not cause bottom deposits in the receiving waters to the extent that such deposits cause nuisance or adversely affect beneficial uses.
10. The discharge shall not cause or contribute to receiving water concentrations of biostimulants that promote objectionable aquatic growths to the extent that such growths cause nuisance or adversely affect beneficial uses of the receiving waters.
11. The discharge shall not cause the receiving waters to contain toxic substances in concentrations that are toxic to, or that produce detrimental physiological responses in human, plant, animal, or aquatic life. Compliance with this objective will be determined by use of indicator organisms, analyses of species diversity, population density, growth anomalies, bioassays of appropriate duration, or other appropriate methods as specified by the Regional Water Board. (See Order section IV.A.1.g and Monitoring and Reporting Program section V.)
12. The discharge shall not alter the natural temperature of the receiving waters.
13. The discharge shall not cause an individual pesticide or combination of pesticides to be present in concentrations that adversely affect beneficial uses. There shall be no bioaccumulation of pesticide concentrations found in bottom sediments or aquatic life as a result of the discharge. The discharge shall not cause the receiving waters to contain concentrations of pesticides in excess of the limiting concentrations set forth in Table 3-2 of the Basin Plan.
14. The discharge shall not cause the receiving waters to contain oils, greases, waxes, or other materials in concentrations that result in a visible film or coating on the surface of the water or on objects in the water that cause nuisance or that otherwise adversely affect beneficial uses.
15. This discharge shall not cause a violation of any applicable water quality standard for receiving waters adopted by the Regional Water Board or the State Water Board, as required by the CWA and regulations adopted thereunder. If more stringent applicable water quality standards are promulgated or approved pursuant to section 303 of the CWA, or amendments thereto, the Regional Water Board will revise and modify this Order in accordance with the more stringent standards.

16. The discharge shall not cause concentrations of chemical constituents to occur in excess of limiting concentrations specified in Table 3-2 of the Basin Plan or in excess of more stringent MCLs established for these pollutants in title 22, California Code of Regulations.

B. Groundwater Limitations

1. The collection, storage, use, and disposal of wastewater or recycled water shall not cause or contribute to a statistically significant degradation of groundwater quality.
2. The collection, storage, use, and disposal of wastewater or recycled water shall not cause alterations of groundwater that result in taste or odor producing substances in concentrations that cause nuisance or adversely affect beneficial uses.

VI. PROVISIONS

A. Standard Provisions

1. The Discharger shall comply with all Standard Provisions included in Attachment D of this Order.
2. The Discharger shall comply with the following provisions:
 - a. A minimum total chlorine residual of 1.5 mg/L shall be maintained at the end of the disinfection process.
 - b. Failure to comply with provisions or requirements of this Order, or violation of other applicable laws or regulations governing discharges from this facility, may subject the Discharger to administrative or civil liabilities, criminal penalties, and/or other enforcement remedies to ensure compliance. Additionally, certain violations may subject the Discharger to civil or criminal enforcement from appropriate local, state, or federal law enforcement entities.
 - c. Prior to making any change in the point of discharge, place of use, or purpose of use of treated wastewater that results in a decrease of flow in any portion of a watercourse, the Discharger must file a petition with the State Water Board, Division of Water Rights, and receive approval for such a change. (Water Code § 1211.)

B. Monitoring and Reporting Program (MRP) Requirements

The Discharger shall comply with the MRP, and future revisions thereto, in Attachment E of this Order.

C. Special Provisions

1. Reopener Provisions

The Regional Water Board may modify or revoke and reissue this Order if on-going or future investigations demonstrate that the Discharger governed by

this Order is causing or significantly contributing to adverse impacts to water quality and/or beneficial uses of receiving water.

In the event that the Regional Water Board's interpretation of the narrative toxicity objective in the Basin Plan is modified or invalidated by an order of the State Water Board, a court decision, State or federal statute or regulation, effluent limitations for toxic pollutants established by this Order may be revised to be consistent with the order, decision, statute, or regulation.

The Regional Water Board may reopen this order within 5 years of its adoption, if effluent monitoring results or other new information demonstrates reasonable potential for any pollutant or pollutant parameter with applicable water quality criteria established by the CTR, NTR, or Basin Plan.

2. Special Studies, Technical Reports and Additional Monitoring Requirements

- a. The Discharger shall comply with one of the following special study tracks in order to assure compliance with the Basin Plan's seasonal discharge prohibition period from May 15 to September 30 each year for the Eel River and its tributaries, as described in Finding II.H. of this Order:

Option 1

- i. By **August 1, 2008**, submit for Executive Officer approval, a workplan to evaluate the characteristics of the summertime discharge location in order to ensure compliance with the Basin Plan prohibition on discharges to the Eel River and its tributaries. The workplan proposal shall contain milestones and a time schedule for completion of the study. The study time schedule shall be as short as practicable, and in no case, extend beyond 2 years following the effective date of this Order.
- ii. If the discharge point characteristics study demonstrates that either the discharge location is a wetland or other area constituting a direct discharge to surface water during the prohibition season, by **August 1, 2010**, the Discharger shall submit a written proposal for Executive Officer approval to study disposal alternatives to comply with the Basin Plan's seasonal discharge prohibition that is applicable to the Eel River and its tributaries. The study plan shall contain milestones and a time schedule for selection and implementation of an alternative disposal method. The study time schedule shall be as short as practicable but no longer than 5 years from this Order's adoption.

OR

Option 2

- i. By **August 1, 2008**, submit for Executive Officer approval, a written commitment to modify existing disposal methods in order to ensure compliance with the Basin Plan's seasonal discharge prohibition that is applicable to the Eel River and its tributaries. The commitment shall include a preliminary schedule of tasks necessary to develop a detailed study plan containing milestones and a time schedule for selection and implementation of an alternative disposal method.
 - ii. By **August 1, 2009**, submit for Executive Officer approval a written proposal to study disposal alternatives to comply with the Basin Plan's seasonal discharge prohibition that is applicable to the Eel River and its tributaries. The study plan shall contain milestones and a time schedule for selection and implementation of an alternative disposal method. The study time schedule shall be as short as practicable but no longer than 5 years from the effective date of this Order.
- b. The Discharger shall comply with one of the following special study tracks to assure compliance with the Basin Plan's requirement, as described by Finding II.H., that discharges to the Eel River and its tributaries receive a minimum dilution of 100 to 1 (receiving water to effluent) at all times outside of the period when discharges are prohibited (May 15 to September 30).

Option 1

- i. By **November 1, 2008**, submit for Executive Officer approval, a workplan for a hydraulic study to determine the ratio of wastewater discharge to receiving water flow at the discharge point in order to ensure compliance with the Basin Plan discharge rate restrictions. The workplan proposal shall contain milestones and a time schedule for completion of the study. The study time schedule shall be as short as practicable, and in no case, extend beyond 3 years following the effective date of this Order. The study time schedule shall include provision for the submittal of **semi-annual** progress reports.
- ii. By **June 1, 2010**, submit for Executive Officer approval a report describing the findings and conclusions of the hydraulic study determining the ratio of wastewater discharge to receiving water flow
- iii. If the hydraulic study demonstrates that wastewater discharges exceed a dilution ratio of 100:1, **by August 1, 2011**, the Discharger shall submit a written proposal for Executive Officer approval to study alternatives to comply with the Basin Plan discharge restrictions. The study plan shall be as short as practicable and contain milestones and

a time schedule for selection and implementation of alternative methods. The implementation time schedule shall be as short as practicable and implementation shall be completed no longer than five (5) years from the effective date of this Order.

OR

Option 2

- i. By **November 1, 2008**, submit for Executive Officer approval, a written commitment to modify existing disposal methods in order to ensure compliance with the Basin Plan's discharge rate requirements applicable to the Eel River and its tributaries. The commitment shall include a preliminary schedule of tasks necessary to develop a detailed study plan containing milestones and a time schedule for selection and implementation of an alternative disposal method.
- ii. By **November 1, 2009**, submit for Executive Officer approval a written proposal to study alternatives to comply with the Basin Plan's discharge rate requirements applicable to the Eel River and its tributaries. The study plan shall contain milestones and a time schedule for selection and implementation of an alternative to achieve compliance. The study time schedule shall be as short as practicable but no longer than 5 years from the effective date of this Order.

c. Toxicity Reduction Requirements

- i. **Whole Effluent Toxicity.** This Order contains effluent limitations for whole effluent acute and chronic toxicity; the Monitoring and Reporting Program (MRP) of this Order requires routine monitoring for whole effluent toxicity to determine compliance with the Basin Plan's narrative water quality objective for toxicity. As established by the MRP, if either the acute toxicity effluent limitation or the chronic toxicity limitation of 1.0 TUc is exceeded more than twenty percent of the time, the Discharger shall conduct a Toxicity Reduction Evaluation (TRE). TREs shall be conducted in accordance with the TRE workplan prepared by the Discharger pursuant to Section VI. C. 2. c.ii. of this Order, below.
- ii. **Toxicity Reduction Evaluations (TRE) workplan.** The Discharger shall prepare and submit to the Regional Water Board Executive Officer a TRE workplan within **180 days of the effective date of this Order**. This plan shall be reviewed and updated as necessary in order to remain current and applicable to the discharge and discharge facilities. The workplan shall describe the steps the Discharger intends to follow if toxicity is detected, and should include at least the following items:

- (a) A description of the investigation and evaluation techniques that would be used to identify potential causes and sources of toxicity, effluent variability, and treatment system efficiency.
- (b) A description of the facility's methods of maximizing in-house treatment efficiency and good housekeeping practices.
- (c) A description of follow-up or accelerated monitoring needed to confirm mitigation of toxicity was effective.
- (d) If a toxicity identification evaluation (TIE) is necessary, an indication of the person who would conduct the TIEs (i.e., an in-house expert or an outside contractor).

iii. **Toxicity Reduction Evaluations (TRE).** The TRE shall be conducted in accordance with the following:

- (a) The TRE shall be initiated within 30 days of the date of effluent violation, observed to exceed either the acute or chronic toxicity parameter.
- (b) The TRE shall be conducted in accordance with the Discharger's workplan.
- (c) The TRE shall be in accordance with current technical guidance and reference material including, at a minimum, the USEPA manual EPA/833B-99/002.
- (d) The TRE may end at any stage if, through monitoring results, it is determined that there is no longer consistent toxicity.
- (e) The Discharger may initiate a TIE as part of the TRE process to identify the cause(s) of toxicity. As guidance, the Discharger shall use the USEPA acute and chronic manuals, EPA/600/6-91/005F (Phase I), EPA/600/R-92/080 (Phase II), and EPA-600/R-92/081 (Phase III).
- (f) As toxic substances are identified or characterized, the Discharger shall continue the TRE by determining the source(s) and evaluating alternative strategies for reducing or eliminating the substances from the discharge. All reasonable steps shall be taken to reduce toxicity to levels consistent with effluent limitations.
- (g) Many recommended TRE elements accompany required efforts of source control, pollution prevention, and storm water control programs. TRE efforts should be coordinated with such efforts. To prevent duplication of efforts, evidence of complying with requirements of recommendations of such programs may be acceptable to comply with requirements of the TRE.
- (h) The Regional Water Board recognizes that chronic toxicity may be episodic and identification of a reduction of sources of chronic toxicity may not be successful in all cases. Consideration of enforcement action by the Regional Water Board will be based in

part on the Discharger's actions and efforts to identify and control or reduce sources of consistent toxicity.

3. Best Management Practices and Pollution Prevention

a. Pollutant Minimization Program

The Discharger shall, as required by the Executive Officer, develop and conduct a Pollutant Minimization Program (PMP) as further described below when there is evidence (e.g., sample results reported as does not quantify (DNQ) when the effluent limitation is less than the minimum detection limit (MDL), sample results from analytical methods more sensitive than those methods required by this Order, presence of whole effluent toxicity, health advisories for fish consumption, results of benthic or aquatic organism tissue sampling) that a priority pollutant is present in the effluent above an effluent limitation and either:

- i. A sample result is reported as DNQ and the effluent limitation is less than the RL; or
- ii. A sample result is reported as ND and the effluent limitation is less than the MDL, using definitions described in Attachment A and reporting protocols described in MRP section X.B.4.

The PMP shall include, but not be limited to, the following actions and submittals acceptable to the Executive Officer:

- i. An annual review and semi-annual monitoring of potential sources of the reportable priority pollutant(s), which may include fish tissue monitoring and other bio-uptake sampling;
- ii. Quarterly monitoring for the reportable priority pollutant(s) in the influent to the wastewater treatment system;
- iii. Submittal of a control strategy designed to proceed toward the goal of maintaining concentrations of the reportable priority pollutant(s) in the effluent at or below the effluent limitation;
- iv. Implementation of appropriate cost-effective control measures for the reportable priority pollutant(s), consistent with the control strategy; and
- v. An annual status report that shall be sent to the Regional Water Board including:
 1. All PMP monitoring results for the previous year;
 2. A list of potential sources of the reportable priority pollutant(s);
 3. A summary of all actions undertaken pursuant to the control strategy; and
 4. A description of actions to be taken in the following year.

4. Construction, Operation and Maintenance Specifications

- a. The Discharger shall maintain an updated Operation and Maintenance (O&M) Manual for the Facility. The Discharger shall update the O&M Manual, as necessary, to conform with changes in operation and

maintenance of the Facility. The O&M Manual shall be readily available to operating personnel onsite. The O&M Manual shall include the following:

- i. Description of the treatment plant table of organization showing the number of employees, duties and qualifications and plant attendance schedules (daily, weekends and holidays, part-time, etc). The description should include documentation that the personnel are knowledgeable and qualified to operate the treatment facility so as to achieve the required level of treatment at all times.
- ii. Detailed description of safe and effective operation and maintenance of treatment processes, process control instrumentation and equipment.
- iii. Description of laboratory and quality assurance procedures.
- iv. Process and equipment inspection and maintenance schedules.
- v. Description of safeguards to assure that, should there be reduction, loss, or failure of electric power, the Discharger will be able to comply with requirements of this Order.
- vi. Description of preventive (fail-safe) and contingency (response and cleanup) plans for controlling accidental discharges, and for minimizing the effect of such events. These plans shall identify the possible sources (such as loading and storage areas, power outage, waste treatment unit failure, process equipment failure, tank and piping failure) of accidental discharges, untreated or partially treated waste bypass, and polluted drainage.

5. Special Provisions for Municipal Facilities (POTWs Only)

- a. Statewide General WDRs for Sanitary Sewer Systems
 - i. On May 2, 2006, the State Water Board adopted State Water Board Order 2006-0003-DWQ, Statewide General WDRs for Sanitary Sewer Systems. Order 2006-0003-DWQ requires that all public agencies that currently own or operate sanitary sewer systems apply for coverage under the General WDRs. The deadline for the Discharger to apply for coverage under State Water Board Order 2006-0003-DWQ for operation of its wastewater collection system was November 2, 2006. The Discharger shall be subject to the requirements of Order 2006-0003-DWQ and any future revisions thereto.
 - ii. The Discharger's collection system is part of the system that is subject to this Order. As such, the Discharger must properly operate and maintain its collection system (40 C.F.R. § 122.41(e)). The Discharger must report any non-compliance (40 C.F.R. § 122.41(l)(6) and (7)) and mitigate any discharge from the collection system in violation of this Order (40 C.F.R. § 122.41(d)). Standard Provision VI.A.2. and Attachment D, subsections I.C, I.D, V.E, and V.H
- b. Sanitary Sewer Overflows

- i. The written report requirements as specified below in this subsection shall terminate when the Discharger commences electronic and/or telefax reporting of sanitary sewer overflows (SSOs) pursuant to Provision D.15 and General Monitoring and Reporting Requirement G.2 of Order No. 2006-0003-DWQ and Monitoring and Reporting Program No. 2006-0003-DWQ. Oral reporting of SSOs as specified below in this subsection shall continue through the term of this Order.
 - ii. SSOs shall be reported orally and in writing to the Regional Water Board staff in accordance with the following: SSOs in excess of 1,000 gallons or any SSO that results in sewage reaching surface waters, or if it is likely that more than 1,000 gallons has escaped the collection system, shall be reported immediately by telephone. A written description of the event shall be submitted in conjunction with the monthly monitoring report.
 - iii. SSOs that result in a sewage spill between 100 gallons and 1,000 gallons that do not reach a surface waterway shall be reported orally within 24 hours. A written description of the event shall be submitted with the next monthly monitoring report.
 - iv. Information to be provided orally includes:
 - a.) Name and contact information of caller.
 - b.) Date, time and location of SSO occurrence.
 - c.) Estimates of spill volume, rate of flow, and spill duration.
 - d.) Surface water bodies impacted.
 - e.) Cause of spill.
 - f.) Cleanup actions taken or repairs made.
 - g.) Responding agencies.
 - v. Information to be provided in writing includes:
 - a.) Information provided in verbal notification.
 - b.) Other agencies notified by phone.
 - c.) Detailed description of cleanup actions and repairs taken.
 - d.) Description of actions that will be taken to minimize or prevent future spills.
- c. Source Control Provisions
- Beginning **May 1, 2008**, the Discharger shall perform source control functions, to include the following:
- i. Implement the necessary legal authorities to monitor and enforce source control standards, restrict discharges of toxic materials to the collection system and inspect facilities connected to the system.
 - ii. If waste haulers are allowed to discharge to the Facility, establish a waste hauler permit system, to be reviewed by the Executive Officer, to regulate waste haulers discharging to the collection system or Facility.

- iii. Conduct a waste survey to identify all industrial dischargers that might discharge pollutants that could pass through or interfere with the operation or performance of the Facility
 - iv. Perform ongoing industrial inspections and monitoring, as necessary, to ensure adequate source control.
- d. Solids Disposal and Handling Requirements
- i. All collected screenings, sludges, and other solids removed from liquid wastes shall be disposed of in a municipal solid waste landfill, reused by land application, disposed of in a sludge only landfill, or incinerated in accordance with 40 CFR Parts 257, 258, 501, and 503, and the State Water Board promulgated provisions of Title 27 CCR Division 2. If the Discharger desires to dispose of solids or sludge by a different method, a request for Order modification shall be submitted to the USEPA and the Regional Water Board 180 days prior to the alternative disposal.
 - ii. The Discharger shall notify the Regional Water Board Executive Officer at least 60 days prior to the initiation of any disposal project, with the exception of regular disposal of screenings at a permitted landfill.
 - iii. All the requirements in 40 CFR 503 are enforceable by USEPA whether or not they are stated in an NPDES Order or other Order issued to the Discharger. The Regional Water Board shall be copied on relevant correspondence and reports forwarded to the USEPA regarding sludge management practices.
 - iv. Sludge that is disposed of in a municipal solid waste landfill or used as daily landfill cover shall meet the applicable requirements of 40 CFR 258. In the annual self-monitoring report, the Discharger shall report the amount of sludge placed in a landfill and the landfill(s) which received the sludge.
 - v. Sludge that is applied to land as soil amendment shall meet pollutant ceiling concentrations, pathogen reduction and vector attraction reduction requirements, and annual and cumulative discharge limitations of 40 CFR Part 503.
 - vi. Sludge that is disposed of through surface disposal, including but not limited to trench systems, area-fill systems, active waste piles, and active impoundments or lagoons shall meet the applicable requirements of 40 CFR 503. Sludge stored beyond two years may be considered as disposed and regulated as a waste pile or surface impoundment under Title 27 CCR Division 2.
 - vii. The Discharger is responsible for ensuring compliance with applicable regulations whether the Discharger uses or disposes of the sludge itself or contracts with another party for further treatment, use, or disposal. The Discharger is responsible for informing subsequent

- preparers, appliers, and disposers of the requirements they must meet under 40 CFR Parts 257, 258, and 503.
- viii. The Discharger shall take all reasonable steps to prevent and minimize any sludge use or disposal in violation of this Order that is likely to adversely affect human health or the environment.
 - ix. Solids and sludge treatment, storage, and disposal and reuse shall not create a nuisance, such as objectionable odors and flies, and shall not result in ground water contamination.
 - x. Solids and sludge treatment and storage sites shall have facilities adequate to divert surface water runoff from adjacent areas, to protect the boundaries of the site from erosion, and to prevent drainage from the treatment and storage site. Adequate protection is defined as protection from at least a 100-year storm and protection from the highest possible tidal stage that may occur.
 - xi. The discharge of sewage sludge and solids shall not cause waste material to be in a position where it is, or can be, conveyed from the treatment and storage sites and deposited in the waters of the State.
- e. **Operator Certification**
Supervisors and operators of municipal WWTPs shall possess a certificate of appropriate grade in accordance with Title 23, CCR, section 3680. The State Water Board may accept experience in lieu of qualification training. In lieu of a properly certified WWTP operator, the State Water Board may approve use of a water treatment plant operator of appropriate grade certified by the State Department of Health Services where water reclamation is involved.
- f. **Adequate Capacity**
Whenever a WWTP will reach capacity within four years, the Discharger shall notify the Regional Water Board. A copy of such notification shall be sent to appropriate local elected officials, local permitting agencies, and the press. Factors to be evaluated in assessing reserve capacity shall include, at a minimum, (1) comparison of the wet weather design flow with the highest daily flow, and (2) comparison of the average dry weather design flow with the lowest 30-day flow. The Discharger shall demonstrate that adequate steps are being taken to address the capacity problem. The Discharger shall submit a technical report to the Regional Water Board showing how flow volumes will be prevented from exceeding capacity, or how capacity will be increased, within 120 days after providing notification to the Regional Water Board, or within 120 days after receipt of Regional Water Board notification that the WWTP will reach capacity within four years. The time for filing the required technical report may be extended by the Regional Water Board. An extension of 30 days may be

granted by the Executive Officer, and longer extensions may be granted by the Regional Water Board itself. [CCR Title 23, section 2232]

6. Other Special Provisions

Storm Water. For the control of storm water discharged from the site of the wastewater treatment plant, if applicable, the Discharger shall seek authorization to discharge under and meet the requirements of the State Water Board's Water Quality Order 97-03-DWQ, NPDES General Permit No. CAS000001, *Waste Discharge Requirements for Discharges of Storm Water Associated with Industrial Activities Excluding Construction Activities* (or subsequent renewed permits).

7. Compliance Schedules

This Order does not establish interim effluent limitations or schedules of compliance for final numeric effluent limitations.

DRAFT

VII. COMPLIANCE DETERMINATION

Compliance with the effluent limitations contained in section IV of this Order will be determined as specified below:

A. General.

Compliance with effluent limitations for priority pollutants shall be determined using sample reporting protocols defined in the MRP and Attachment A of this Order. For purposes of reporting and administrative enforcement by the Regional and State Water Boards, the Discharger shall be deemed out of compliance with effluent limitations if the concentration of the priority pollutant in the monitoring sample is greater than the effluent limitation and greater than or equal to the reporting level (RL).

B. Multiple Sample Data.

When determining compliance with an AMEL, AWEL, or MDEL for priority pollutants and more than one sample result is available, the Discharger shall compute the arithmetic mean unless the data set contains one or more reported determinations of "Detected, but Not Quantified" (DNQ) or "Not Detected" (ND). In those cases, the Discharger shall compute the median in place of the arithmetic mean in accordance with the following procedure:

1. The data set shall be ranked from low to high, ranking the reported ND determinations lowest, DNQ determinations next, followed by quantified values (if any). The order of the individual ND or DNQ determinations is unimportant.
2. The median value of the data set shall be determined. If the data set has an odd number of data points, then the median is the middle value. If the data set has an even number of data points, then the median is the average of the two values around the middle unless one or both of the points are ND or DNQ, in which case the median value shall be the lower of the two data points where DNQ is lower than a value and ND is lower than DNQ.

C. Average Monthly Effluent Limitation (AMEL).

When less than daily monitoring is required, the monthly average shall be determined by summing the daily values and dividing by the number of days during the calendar month when monitoring occurred. If only one sample is collected in a calendar month, the value of the single sample shall constitute the monthly average.

D. Average Weekly Effluent Limitation (AWEL).

When less than daily monitoring is required, the weekly average shall be determined by summing the daily values and dividing by the number of days during the calendar week when monitoring occurred. If only one sample is collected in a calendar week, the value of the single sample shall constitute the weekly average.

For any one calendar week during which no sample is taken, no compliance determination can be made for that calendar week.

E. Maximum Daily Effluent Limitation (MDEL).

If a daily discharge <(or when applicable, the median determined by subsection B above for multiple sample data of a daily discharge)> exceeds the MDEL for a given parameter, the Discharger will be considered out of compliance for that parameter for that 1 day only within the reporting period. For any 1 day during which no sample is taken, no compliance determination can be made for that day.

F. Instantaneous Minimum Effluent Limitation.

If the analytical result of a single grab sample is lower than the instantaneous minimum effluent limitation for a parameter, the Discharger will be considered out of compliance for that parameter for that single sample. Non-compliance for each sample will be considered separately (e.g., the results of two grab samples taken within a calendar day that both are lower than the instantaneous minimum effluent limitation would result in two instances of non-compliance with the instantaneous minimum effluent limitation).

G. Instantaneous Maximum Effluent Limitation.

If the analytical result of a single grab sample is higher than the instantaneous maximum effluent limitation for a parameter, the Discharger will be considered out of compliance for that parameter for that single sample. Non-compliance for each sample will be considered separately (e.g., the results of two grab samples taken within a calendar day that both exceed the instantaneous maximum effluent limitation would result in two instances of non-compliance with the instantaneous maximum effluent limitation).

ATTACHMENT A – DEFINITIONS

Arithmetic Mean (μ), also called the average, is the sum of measured values divided by the number of samples. For ambient water concentrations, the arithmetic mean is calculated as follows:

$$\text{Arithmetic mean} = \mu = \Sigma x / n \quad \text{where:} \quad \Sigma x \text{ is the sum of the measured ambient water concentrations, and } n \text{ is the number of samples.}$$

Average Monthly Effluent Limitation (AMEL): the highest allowable average of daily discharges over a calendar month, calculated as the sum of all daily discharges measured during a calendar month divided by the number of daily discharges measured during that month.

Average Weekly Effluent Limitation (AWEL): the highest allowable average of daily discharges over a calendar week (Sunday through Saturday), calculated as the sum of all daily discharges measured during a calendar week divided by the number of daily discharges measured during that week.

Bioaccumulative pollutants are those substances taken up by an organism from its surrounding medium through gill membranes, epithelial tissue, or from food and subsequently concentrated and retained in the body of the organism.

Carcinogenic pollutants are substances that are known to cause cancer in living organisms.

Coefficient of Variation (CV) is a measure of the data variability and is calculated as the estimated standard deviation divided by the arithmetic mean of the observed values.

Daily Discharge: Daily Discharge is defined as either: (1) the total mass of the constituent discharged over the calendar day (12:00 am through 11:59 pm) or any 24-hour period that reasonably represents a calendar day for purposes of sampling (as specified in the permit), for a constituent with limitations expressed in units of mass or; (2) the unweighted arithmetic mean measurement of the constituent over the day for a constituent with limitations expressed in other units of measurement (e.g., concentration).

The daily discharge may be determined by the analytical results of a composite sample taken over the course of one day (a calendar day or other 24-hour period defined as a day) or by the arithmetic mean of analytical results from one or more grab samples taken over the course of the day.

For composite sampling, if 1 day is defined as a 24-hour period other than a calendar day, the analytical result for the 24-hour period will be considered as the result for the calendar day in which the 24-hour period ends.

Detected, but Not Quantified (DNQ) are those sample results less than the RL, but greater than or equal to the laboratory's MDL.

Dilution Credit is the amount of dilution granted to a discharge in the calculation of a water quality-based effluent limitation, based on the allowance of a specified mixing zone. It is calculated from the dilution ratio or determined through conducting a mixing zone study or modeling of the discharge and receiving water.

Effluent Concentration Allowance (ECA) is a value derived from the water quality criterion/objective, dilution credit, and ambient background concentration that is used, in conjunction with the coefficient of variation for the effluent monitoring data, to calculate a long-term average (LTA) discharge concentration. The ECA has the same meaning as waste load allocation (WLA) as used in U.S. EPA guidance (Technical Support Document For Water Quality-based Toxics Control, March 1991, second printing, EPA/505/2-90-001).

Enclosed Bays means indentations along the coast that enclose an area of oceanic water within distinct headlands or harbor works. Enclosed bays include all bays where the narrowest distance between the headlands or outermost harbor works is less than 75 percent of the greatest dimension of the enclosed portion of the bay. Enclosed bays include, but are not limited to, Humboldt Bay, Bodega Harbor, Tomales Bay, Drake's Estero, San Francisco Bay, Morro Bay, Los Angeles-Long Beach Harbor, Upper and Lower Newport Bay, Mission Bay, and San Diego Bay. Enclosed bays do not include inland surface waters or ocean waters.

Estimated Chemical Concentration is the estimated chemical concentration that results from the confirmed detection of the substance by the analytical method below the ML value.

Estuaries means waters, including coastal lagoons, located at the mouths of streams that serve as areas of mixing for fresh and ocean waters. Coastal lagoons and mouths of streams that are temporarily separated from the ocean by sandbars shall be considered estuaries. Estuarine waters shall be considered to extend from a bay or the open ocean to a point upstream where there is no significant mixing of fresh water and seawater. Estuarine waters included, but are not limited to, the Sacramento-San Joaquin Delta, as defined in Water Code section 12220, Suisun Bay, Carquinez Strait downstream to the Carquinez Bridge, and appropriate areas of the Smith, Mad, Eel, Noyo, Russian, Klamath, San Diego, and Otay rivers. Estuaries do not include inland surface waters or ocean waters.

Inland Surface Waters are all surface waters of the State that do not include the ocean, enclosed bays, or estuaries.

Instantaneous Maximum Effluent Limitation: the highest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous maximum limitation).

Instantaneous Minimum Effluent Limitation: the lowest allowable value for any single grab sample or aliquot (i.e., each grab sample or aliquot is independently compared to the instantaneous minimum limitation).

Maximum Daily Effluent Limitation (MDEL) means the highest allowable daily discharge of a pollutant, over a calendar day (or 24-hour period). For pollutants with limitations expressed in units of mass, the daily discharge is calculated as the total mass of the pollutant discharged over the day. For pollutants with limitations expressed in other units of measurement, the daily discharge is calculated as the arithmetic mean measurement of the pollutant over the day.

Median is the middle measurement in a set of data. The median of a set of data is found by first arranging the measurements in order of magnitude (either increasing or decreasing order). If the number of measurements (n) is odd, then the median = $X_{(n+1)/2}$. If n is even, then the median = $(X_{n/2} + X_{(n/2)+1})/2$ (i.e., the midpoint between the $n/2$ and $n/2+1$).

Method Detection Limit (MDL) is the minimum concentration of a substance that can be measured and reported with 99 percent confidence that the analyte concentration is greater than zero, as defined in title 40 of the Code of Federal Regulations, Part 136, Attachment B, revised as of July 3, 1999.

Minimum Level (ML) is the concentration at which the entire analytical system must give a recognizable signal and acceptable calibration point. The ML is the concentration in a sample that is equivalent to the concentration of the lowest calibration standard analyzed by a specific analytical procedure, assuming that all the method specified sample weights, volumes, and processing steps have been followed.

Mixing Zone is a limited volume of receiving water that is allocated for mixing with a wastewater discharge where water quality criteria can be exceeded without causing adverse effects to the overall water body.

Not Detected (ND) are those sample results less than the laboratory's MDL.

Ocean Waters are the territorial marine waters of the State as defined by California law to the extent these waters are outside of enclosed bays, estuaries, and coastal lagoons. Discharges to ocean waters are regulated in accordance with the State Water Board's California Ocean Plan.

Persistent pollutants are substances for which degradation or decomposition in the environment is nonexistent or very slow.

Pollutant Minimization Program (PMP) means waste minimization and pollution prevention actions that include, but are not limited to, product substitution, waste stream recycling, alternative waste management methods, and education of the public and businesses. The goal of the PMP shall be to reduce all potential sources of a priority pollutant(s) through pollutant minimization (control) strategies, including pollution prevention measures as appropriate, to maintain the effluent concentration at or below the water quality-based effluent limitation. Pollution prevention measures may be particularly appropriate for persistent bioaccumulative priority pollutants where there is evidence that beneficial uses are being impacted. The Regional Water Board may consider cost effectiveness when establishing the requirements of a PMP. The completion and implementation of a Pollution Prevention Plan, if required pursuant to Water Code section 13263.3(d), shall be considered to fulfill the PMP requirements.

Pollution Prevention means any action that causes a net reduction in the use or generation of a hazardous substance or other pollutant that is discharged into water and includes, but is not limited to, input change, operational improvement, production process change, and product reformulation (as defined in Water Code section 13263.3). Pollution prevention does not include actions that merely shift a pollutant in wastewater from one environmental medium to another environmental medium, unless clear environmental benefits of such an approach are identified to the satisfaction of the State or Regional Water Board.

Reporting Level (RL) is the ML (and its associated analytical method) chosen by the Discharger for reporting and compliance determination from the MLs included in this Order. The MLs included in this Order correspond to approved analytical methods for reporting a sample result that are selected by the Regional Water Board either from Appendix 4 of the SIP in accordance with section 2.4.2 of the SIP or established in accordance with section 2.4.3 of the SIP. The ML is based on the proper application of method-based analytical procedures for sample preparation and the absence of any matrix interferences. Other factors may be applied to the ML depending on the specific sample preparation steps employed. For example, the treatment typically applied in cases where there are matrix-effects is to dilute the sample or sample aliquot by a factor of ten. In such cases, this additional factor must be applied to the ML in the computation of the RL.

Satellite Collection System is the portion, if any, of a sanitary sewer system owned or operated by a different public agency than the agency that owns and operates the wastewater treatment facility that a sanitary sewer system is tributary to.

Source of Drinking Water is any water designated as municipal or domestic supply (MUN) in a Regional Water Board Basin Plan.

Standard Deviation (σ) is a measure of variability that is calculated as follows:

$$\sigma = \left(\frac{\sum[(x - \mu)^2]}{n - 1} \right)^{0.5}$$

where:

x is the observed value;

μ is the arithmetic mean of the observed values; and

n is the number of samples.

Toxicity Reduction Evaluation (TRE) is a study conducted in a step-wise process designed to identify the causative agents of effluent or ambient toxicity, isolate the sources of toxicity, evaluate the effectiveness of toxicity control options, and then confirm the reduction in toxicity. The first steps of the TRE consist of the collection of data relevant to the toxicity, including additional toxicity testing, and an evaluation of facility operations and maintenance practices, and best management practices. A Toxicity Identification Evaluation (TIE) may be required as part of the TRE, if appropriate. (A TIE is a set of procedures to identify the specific chemical(s) responsible for toxicity. These procedures are performed in three phases (characterization, identification, and confirmation) using aquatic organism toxicity tests.)

ATTACHMENT D –STANDARD PROVISIONS

I. STANDARD PROVISIONS – PERMIT COMPLIANCE

A. Duty to Comply

1. The Discharger must comply with all of the conditions of this Order. Any noncompliance constitutes a violation of the Clean Water Act (CWA) and the California Water Code and is grounds for enforcement action, for permit termination, revocation and reissuance, or modification; or denial of a permit renewal application. (40 C.F.R. § 122.41(a).)
2. The Discharger shall comply with effluent standards or prohibitions established under Section 307(a) of the CWA for toxic pollutants and with standards for sewage sludge use or disposal established under Section 405(d) of the CWA within the time provided in the regulations that establish these standards or prohibitions, even if this Order has not yet been modified to incorporate the requirement. (40 C.F.R. § 122.41(a)(1).)

B. Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for a Discharger in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this Order. (40 C.F.R. § 122.41(c).)

C. Duty to Mitigate

The Discharger shall take all reasonable steps to minimize or prevent any discharge or sludge use or disposal in violation of this Order that has a reasonable likelihood of adversely affecting human health or the environment. (40 C.F.R. § 122.41(d).)

D. Proper Operation and Maintenance

The Discharger shall at all times properly operate and maintain all facilities and systems of treatment and control (and related appurtenances) which are installed or used by the Discharger to achieve compliance with the conditions of this Order. Proper operation and maintenance also includes adequate laboratory controls and appropriate quality assurance procedures. This provision requires the operation of backup or auxiliary facilities or similar systems that are installed by a Discharger only when necessary to achieve compliance with the conditions of this Order. (40 C.F.R. § 122.41(e))

E. Property Rights

1. This Order does not convey any property rights of any sort or any exclusive privileges. (40 C.F.R. § 122.41(g).)
2. The issuance of this Order does not authorize any injury to persons or property or invasion of other private rights, or any infringement of state or local law or regulations. (40 C.F.R. § 122.5(c).)

F. Inspection and Entry

The Discharger shall allow the Regional Water Board, State Water Board, United States Environmental Protection Agency (USEPA), and/or their authorized representatives (including an authorized contractor acting as their representative),

upon the presentation of credentials and other documents, as may be required by law, to (40 C.F.R. § 122.41(i); Water Code, § 13383):

1. Enter upon the Discharger's premises where a regulated facility or activity is located or conducted, or where records are kept under the conditions of this Order (40 C.F.R. § 122.41(i)(1));
2. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this Order (40 C.F.R. § 122.41(i)(2));
3. Inspect and photograph, at reasonable times, any facilities, equipment (including monitoring and control equipment), practices, or operations regulated or required under this Order (40 C.F.R. § 122.41(i)(3)); and
4. Sample or monitor, at reasonable times, for the purposes of assuring Order compliance or as otherwise authorized by the CWA or the Water Code, any substances or parameters at any location. (40 C.F.R. § 122.41(i)(4).)

G. Bypass

1. Definitions
 - a. "Bypass" means the intentional diversion of waste streams from any portion of a treatment facility. (40 C.F.R. § 122.41(m)(1)(i).)
 - b. "Severe property damage" means substantial physical damage to property, damage to the treatment facilities, which causes them to become inoperable, or substantial and permanent loss of natural resources that can reasonably be expected to occur in the absence of a bypass. Severe property damage does not mean economic loss caused by delays in production. (40 C.F.R. § 122.41(m)(1)(ii).)
2. Bypass not exceeding limitations. The Discharger may allow any bypass to occur which does not cause exceedances of effluent limitations, but only if it is for essential maintenance to assure efficient operation. These bypasses are not subject to the provisions listed in Standard Provisions – Permit Compliance I.G.3, I.G.4, and I.G.5 below. (40 C.F.R. § 122.41(m)(2).)
3. Prohibition of bypass. Bypass is prohibited, and the Regional Water Board may take enforcement action against a Discharger for bypass, unless (40 C.F.R. § 122.41(m)(4)(i)):
 - a. Bypass was unavoidable to prevent loss of life, personal injury, or severe property damage (40 C.F.R. § 122.41(m)(4)(i)(A));
 - b. There were no feasible alternatives to the bypass, such as the use of auxiliary treatment facilities, retention of untreated wastes, or maintenance during normal periods of equipment downtime. This condition is not satisfied if adequate back-up equipment should have been installed in the exercise of reasonable engineering judgment to prevent a bypass that occurred during normal periods of equipment downtime or preventive maintenance (40 C.F.R. § 122.41(m)(4)(i)(B)); and

- c. The Discharger submitted notice to the Regional Water Board as required under Standard Provisions – Permit Compliance I.G.5 below. (40 C.F.R. § 122.41(m)(4)(i)(C).)
4. The Regional Water Board may approve an anticipated bypass, after considering its adverse effects, if the Regional Water Board determines that it will meet the three conditions listed in Standard Provisions – Permit Compliance I.G.3 above. (40 C.F.R. § 122.41(m)(4)(ii).)
5. Notice
 - a. Anticipated bypass. If the Discharger knows in advance of the need for a bypass, it shall submit a notice, if possible at least 10 days before the date of the bypass. (40 C.F.R. § 122.41(m)(3)(i).)
 - b. Unanticipated bypass. The Discharger shall submit notice of an unanticipated bypass as required in Standard Provisions - Reporting V.E below (24-hour notice). (40 C.F.R. § 122.41(m)(3)(ii).)

H. Upset

Upset means an exceptional incident in which there is unintentional and temporary noncompliance with technology based permit effluent limitations because of factors beyond the reasonable control of the Discharger. An upset does not include noncompliance to the extent caused by operational error, improperly designed treatment facilities, inadequate treatment facilities, lack of preventive maintenance, or careless or improper operation. (40 C.F.R. § 122.41(n)(1).)

1. Effect of an upset. An upset constitutes an affirmative defense to an action brought for noncompliance with such technology based permit effluent limitations if the requirements of Standard Provisions – Permit Compliance I.H.2 below are met. No determination made during administrative review of claims that noncompliance was caused by upset, and before an action for noncompliance, is final administrative action subject to judicial review. (40 C.F.R. § 122.41(n)(2).)
2. Conditions necessary for a demonstration of upset. A Discharger who wishes to establish the affirmative defense of upset shall demonstrate, through properly signed, contemporaneous operating logs or other relevant evidence that (40 C.F.R. § 122.41(n)(3)):
 - a. An upset occurred and that the Discharger can identify the cause(s) of the upset (40 C.F.R. § 122.41(n)(3)(i));
 - b. The permitted facility was, at the time, being properly operated (40 C.F.R. § 122.41(n)(3)(ii));

- c. The Discharger submitted notice of the upset as required in Standard Provisions – Reporting V.E.2.b below (24-hour notice) (40 C.F.R. § 122.41(n)(3)(iii)); and
 - d. The Discharger complied with any remedial measures required under Standard Provisions – Permit Compliance I.C above. (40 C.F.R. § 122.41(n)(3)(iv).)
3. Burden of proof. In any enforcement proceeding, the Discharger seeking to establish the occurrence of an upset has the burden of proof. (40 C.F.R. § 122.41(n)(4).)

II. STANDARD PROVISIONS – PERMIT ACTION

A. General

This Order may be modified, revoked and reissued, or terminated for cause. The filing of a request by the Discharger for modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any Order condition. (40 C.F.R. § 122.41(f).)

B. Duty to Reapply

If the Discharger wishes to continue an activity regulated by this Order after the expiration date of this Order, the Discharger must apply for and obtain a new permit. (40 C.F.R. § 122.41(b).)

C. Transfers

This Order is not transferable to any person except after notice to the Regional Water Board. The Regional Water Board may require modification or revocation and reissuance of the Order to change the name of the Discharger and incorporate such other requirements as may be necessary under the CWA and the Water Code. (40 C.F.R. § 122.41(l)(3); § 122.61.)

III. STANDARD PROVISIONS – MONITORING

- A. Samples and measurements taken for the purpose of monitoring shall be representative of the monitored activity. (40 C.F.R. § 122.41(j)(1).)
- B. Monitoring results must be conducted according to test procedures under Part 136 or, in the case of sludge use or disposal, approved under Part 136 unless otherwise specified in Part 503 unless other test procedures have been specified in this Order. (40 C.F.R. § 122.41(j)(4); § 122.44(i)(1)(iv).)

IV. STANDARD PROVISIONS – RECORDS

- A. Except for records of monitoring information required by this Order related to the Discharger's sewage sludge use and disposal activities, which shall be retained for a period of at least five years (or longer as required by Part 503), the Discharger shall retain records of all monitoring information, including all calibration and maintenance records and all original strip chart recordings for continuous monitoring instrumentation, copies of all reports required by this Order, and records of all data used to complete the application for this Order, for a period of at least three (3) years from the date of the sample, measurement, report or application. This period may be extended by request of the Regional Water Board Executive Officer at any time. (40 C.F.R. § 122.41(j)(2).)
- B. **Records of monitoring information shall include:**
 - 1. The date, exact place, and time of sampling or measurements (40 C.F.R. § 122.41(j)(3)(i));
 - 2. The individual(s) who performed the sampling or measurements (40 C.F.R. § 122.41(j)(3)(ii));
 - 3. The date(s) analyses were performed (40 C.F.R. § 122.41(j)(3)(iii));
 - 4. The individual(s) who performed the analyses (40 C.F.R. § 122.41(j)(3)(iv));
 - 5. The analytical techniques or methods used (40 C.F.R. § 122.41(j)(3)(v)); and
 - 6. The results of such analyses. (40 C.F.R. § 122.41(j)(3)(vi).)
- C. **Claims of confidentiality for the following information will be denied (40 C.F.R. § 122.7(b)):**
 - 1. The name and address of any permit applicant or Discharger (40 C.F.R. § 122.7(b)(1)); and
 - 2. Permit applications and attachments, permits and effluent data. (40 C.F.R. § 122.7(b)(2).)

V. STANDARD PROVISIONS – REPORTING

A. Duty to Provide Information

The Discharger shall furnish to the Regional Water Board, State Water Board, or USEPA within a reasonable time, any information which the Regional Water Board, State Water Board, or USEPA may request to determine whether cause exists for modifying, revoking and reissuing, or terminating this Order or to determine compliance with this Order. Upon request, the Discharger shall also furnish to the Regional Water Board, State Water Board, or USEPA copies of records required to be kept by this Order. (40 C.F.R. § 122.41(h); Wat. Code, § 13267.)

B. Signatory and Certification Requirements

1. All applications, reports, or information submitted to the Regional Water Board, State Water Board, and/or USEPA shall be signed and certified in accordance with Standard Provisions – Reporting V.B.2, V.B.3, V.B.4, and V.B.5 below. (40 C.F.R. § 122.41(k).)
2. All permit applications shall be signed by either a principal executive officer or ranking elected official. For purposes of this provision, a principal executive officer of a federal agency includes: (i) the chief executive officer of the agency, or (ii) a senior executive officer having responsibility for the overall operations of a principal geographic unit of the agency (e.g., Regional Administrators of USEPA). (40 C.F.R. § 122.22(a)(3).)
3. All reports required by this Order and other information requested by the Regional Water Board, State Water Board, or USEPA shall be signed by a person described in Standard Provisions – Reporting V.B.2 above, or by a duly authorized representative of that person. A person is a duly authorized representative only if:
 - a. The authorization is made in writing by a person described in Standard Provisions – Reporting V.B.2 above (40 C.F.R. § 122.22(b)(1));
 - b. The authorization specifies either an individual or a position having responsibility for the overall operation of the regulated facility or activity such as the position of plant manager, operator of a well or a well field, superintendent, position of equivalent responsibility, or an individual or position having overall responsibility for environmental matters for the company. (A duly authorized representative may thus be either a named individual or any individual occupying a named position.) (40 C.F.R. § 122.22(b)(2)); and
 - c. The written authorization is submitted to the Regional Water Board and State Water Board. (40 C.F.R. § 122.22(b)(3).)
4. If an authorization under Standard Provisions – Reporting V.B.3 above is no longer accurate because a different individual or position has responsibility for the overall operation of the facility, a new authorization satisfying the

- requirements of Standard Provisions – Reporting V.B.3 above must be submitted to the Regional Water Board and State Water Board prior to or together with any reports, information, or applications, to be signed by an authorized representative. (40 C.F.R. § 122.22(c).)
5. Any person signing a document under Standard Provisions – Reporting V.B.2 or V.B.3 above shall make the following certification:
“I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.” (40 C.F.R. § 122.22(d).)

C. Monitoring Reports

1. Monitoring results shall be reported at the intervals specified in the Monitoring and Reporting Program (Attachment E) in this Order. (40 C.F.R. § 122.22(l)(4).)
2. Monitoring results must be reported on a Discharge Monitoring Report (DMR) form or forms provided or specified by the Regional Water Board or State Water Board for reporting results of monitoring of sludge use or disposal practices. (40 C.F.R. § 122.41(l)(4)(i).)
3. If the Discharger monitors any pollutant more frequently than required by this Order using test procedures approved under Part 136 or, in the case of sludge use or disposal, approved under Part 136 unless otherwise specified in Part 503, or as specified in this Order, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the DMR or sludge reporting form specified by the Regional Water Board. (40 C.F.R. § 122.41(l)(4)(ii).)
4. Calculations for all limitations, which require averaging of measurements, shall utilize an arithmetic mean unless otherwise specified in this Order. (40 C.F.R. § 122.41(l)(4)(iii).)

D. Compliance Schedules

Reports of compliance or noncompliance with, or any progress reports on, interim and final requirements contained in any compliance schedule of this Order, shall be submitted no later than 14 days following each schedule date. (40 C.F.R. § 122.41(l)(5).)

E. Twenty-Four Hour Reporting

1. The Discharger shall report any noncompliance that may endanger health or the environment. Any information shall be provided orally within 24 hours from the time the Discharger becomes aware of the circumstances. A written submission shall also be provided within five (5) days of the time the Discharger becomes aware of the circumstances. The written submission shall contain a description of the noncompliance and its cause; the period of noncompliance, including exact dates and times, and if the noncompliance has not been corrected, the anticipated time it is expected to continue; and steps taken or planned to reduce, eliminate, and prevent reoccurrence of the noncompliance. (40 C.F.R. § 122.41(l)(6)(i).)
2. The following shall be included as information that must be reported within 24 hours under this paragraph (40 C.F.R. § 122.41(l)(6)(ii)):
 - a. Any unanticipated bypass that exceeds any effluent limitation in this Order. (40 C.F.R. § 122.41(l)(6)(ii)(A).)
 - b. Any upset that exceeds any effluent limitation in this Order. (40 C.F.R. § 122.41(l)(6)(ii)(B).)
3. The Regional Water Board may waive the above-required written report under this provision on a case-by-case basis if an oral report has been received within 24 hours. (40 C.F.R. § 122.41(l)(6)(iii).)

F. Planned Changes

The Discharger shall give notice to the Regional Water Board as soon as possible of any planned physical alterations or additions to the permitted facility. Notice is required under this provision only when (40 C.F.R. § 122.41(l)(1)):

1. The alteration or addition to a permitted facility may meet one of the criteria for determining whether a facility is a new source in section 122.29(b) (40 C.F.R. § 122.41(l)(1)(i)); or
2. The alteration or addition could significantly change the nature or increase the quantity of pollutants discharged. This notification applies to pollutants that are not subject to effluent limitations in this Order. (40 C.F.R. § 122.41(l)(1)(ii).)
3. The alteration or addition results in a significant change in the Discharger's sludge use or disposal practices, and such alteration, addition, or change may justify the application of permit conditions that are different from or absent in the existing permit, including notification of additional use or disposal sites not reported during the permit application process or not reported pursuant to an approved land application plan. (40 C.F.R. § 122.41(l)(1)(iii).)

G. Anticipated Noncompliance

The Discharger shall give advance notice to the Regional Water Board or State Water Board of any planned changes in the permitted facility or activity that may result in noncompliance with General Order requirements. (40 C.F.R. § 122.41(l)(2).)

H. Other Noncompliance

The Discharger shall report all instances of noncompliance not reported under Standard Provisions – Reporting V.C, V.D, and V.E above at the time monitoring reports are submitted. The reports shall contain the information listed in Standard Provision – Reporting V.E above. (40 C.F.R. § 122.41(l)(7).)

I. Other Information

When the Discharger becomes aware that it failed to submit any relevant facts in a permit application, or submitted incorrect information in a permit application or in any report to the Regional Water Board, State Water Board, or USEPA, the Discharger shall promptly submit such facts or information. (40 C.F.R. § 122.41(l)(8).)

VI. STANDARD PROVISIONS – ENFORCEMENT

A. The Regional Water Board is authorized to enforce the terms of this permit under several provisions of the Water Code, including, but not limited to, sections 13385, 13386, and 13387.

VII. ADDITIONAL PROVISIONS – NOTIFICATION LEVELS

A. Publicly-Owned Treatment Works (POTWs)

All POTWs shall provide adequate notice to the Regional Water Board of the following (40 C.F.R. § 122.42(b)):

1. Any new introduction of pollutants into the POTW from an indirect discharger that would be subject to sections 301 or 306 of the CWA if it were directly discharging those pollutants (40 C.F.R. § 122.42(b)(1)); and
2. Any substantial change in the volume or character of pollutants being introduced into that POTW by a source introducing pollutants into the POTW at the time of adoption of the Order. (40 C.F.R. § 122.42(b)(2).)
3. Adequate notice shall include information on the quality and quantity of effluent introduced into the POTW as well as any anticipated impact of the change on the quantity or quality of effluent to be discharged from the POTW. (40 C.F.R. § 122.42(b)(3).)

ATTACHMENT E – MONITORING AND REPORTING PROGRAM

Table of Contents

Attachment E – Monitoring and Reporting Program (MRP).....	C-2
I. General Monitoring Provisions	C-2
II. Monitoring Locations	C-2
III. Influent Monitoring Requirements	C-2
A. Monitoring Location INF-001	C-2
IV. Effluent Monitoring Requirements	C-3
A. Monitoring Location M-CCC	C-3
B. Monitoring Location M-001	C-3
V. Whole Effluent Toxicity Testing Requirements.....	C-4
A. Acute Toxicity Testing	C-4
B. Chronic Toxicity Testing	C-5
C. Chronic Toxicity Reporting	C-7
VI. Land Discharge Monitoring Requirements	C-8
VII. Reclamation Monitoring Requirements	C-8
VIII. Receiving Water Monitoring Requirements – Surface Water and Groundwater.....	C-8
A. Monitoring Location R-001	C-8
IX. Other Monitoring Requirements	C-9
X. Reporting Requirements	C-9
A. General Monitoring and Reporting Requirements	C-9
B. Self Monitoring Reports (SMRs).....	C-9
C. Discharge Monitoring Reports (DMRs).....	C-12
D. Other Reports.....	C-13

List of Tables

Table E-1. Monitoring Station Locations.....	C-2
Table E-2. Influent Monitoring	C-3
Table E-3. Internal Monitoring	C-3
Table E-4. Effluent Monitoring.....	C-3
Table E-5. Receiving Water Monitoring Requirements.....	C-8
Table E-6. Receiving Water Monitoring Requirements.....	C-9
Table E-7. Monitoring Periods and Reporting Schedule.....	C-10

ATTACHMENT E – MONITORING AND REPORTING PROGRAM (MRP)

The Code of Federal Regulations section 122.48 requires that all NPDES permits specify monitoring and reporting requirements. Water Code Sections 13267 and 13383 also authorize the Regional Water Quality Control Board (Regional Water Board) to require technical and monitoring reports. This MRP establishes monitoring and reporting requirements, which implement the federal and California regulations.

I. GENERAL MONITORING PROVISIONS

- A. Wastewater Monitoring Provision.** Composite samples may be taken by a proportional sampling device approved by the Executive Officer or by grab samples composited in proportion to flow. In compositing grab samples, the sampling interval shall not exceed one hour.
- B.** Laboratories analyzing monitoring samples shall be certified by the Department of Health Services, in accordance with the provisions of Water Code section 13176, and must include quality assurance/quality control data with their reports.
- C.** If the Discharger monitors any pollutant more frequently than required by this permit, using test procedures approved under 40 Code of Federal Regulations (CFR) Part 136 or as specified in this Order, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the monthly and annual discharger monitoring reports.

II. MONITORING LOCATIONS

The Discharger shall establish the following monitoring locations to demonstrate compliance with the effluent limitations, discharge specifications, and other requirements in this Order:

Table E-1. Monitoring Station Locations

Discharge Point Name	Monitoring Location Name	Monitoring Location Description (include Latitude and Longitude when available)
--	INF-001	A representative point preceding primary treatment
--	M-CCC	Effluent from the chlorine contact chamber prior to dechlorination for purposes of measuring chlorine residual
001	M-001	A representative point following full treatment, including dechlorination, but prior to contact with the receiving water
--	R-001	Wetland surface water upstream beyond influence of the discharge or as approved by the Executive Officer
--	R-002	Wetland surface water at the point of discharge or other location approved by the Executive Officer

III. INFLUENT MONITORING REQUIREMENTS

A. Monitoring Location INF-001

- 1. The Discharger shall monitor influent to the facility at INF-001 as follows:

Table E-2. Influent Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
BOD ₅	mg/L	24-hour composite	monthly	Standard Methods ¹
TSS	mg/L	24-hour composite	monthly	Standard Methods

¹In accordance with the current edition of Standard Methods for the Examination of Water and Wastewater (American Public Health Administration) or current test procedures specified in 40 CFR Part 136.

IV. EFFLUENT MONITORING REQUIREMENTS

A. Monitoring Location M-CCC

1. The Discharger shall monitor the discharge from the chlorine contact chamber prior to dechlorination at Monitoring Location M-CCC as follows:

Table E-3. Internal Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method and (Minimum Level, units), respectively
Chlorine Residual	mg/L	Grab	Daily	Standard Methods

B. Monitoring Location M-001

1. The Discharger shall monitor treated wastewater at M-001 as follows. If more than one analytical test method is listed for a given parameter, the Discharger must select from the listed methods and select the method with a corresponding Minimum Level:

Table E-4. Effluent Monitoring

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method and (Minimum Level, units), respectively
Flow (Mean)	gpd	Continuous	Daily	Meter
BOD ₅	mg/L	24-hour composite	Monthly	Standard Methods
TSS	mg/L	24-hour composite	Monthly	Standard Methods
Settleable Solids	ml/L	24-hour composite	Weekly	Standard Methods
Total Coliform Organisms	MPN/100 mL	Grab	Weekly	Standard Methods
Chlorine Residual	mg/L	Grab	Daily	Standard Methods
pH	Standard Units	Grab	Weekly ²	Standard Methods
Temperature	°F or °C	Grab	Monthly ²	Standard Methods
Unionized Ammonia	mg/L	Grab	Quarterly	Standard Methods
Ammonia Nitrogen	mg/L	Grab	Quarterly	Standard Methods
Nitrate Nitrogen	mg/L	Grab	Quarterly	Standard Methods
Total Phosphorous	mg/L	Grab	Quarterly	Standard Methods
Acute Toxicity	TU _A	Grab	Twice Yearly	Per Section V. A, below
Chronic Toxicity	TU _C	Grab	Twice Yearly	Per Section V. B, below

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method and (Minimum Level, units), respectively
Priority Pollutants ¹	µg/l	Grab	2x/Order Term	Standard Methods

¹ Those pollutants identified by the California Toxics Rule at 40 CFR 131.38. Analytical methods must achieve the lowest minimum level (ML) specified in Attachment 4 of the SIP; and in accordance with Section 2.4 of the SIP, the Discharger shall report the ML and MDL for each sample result. Where no methods are specified for a given pollutant, the Discharger shall use methods approved by the Regional Board.

² Measurements for temperature and pH must be taken in timing with ammonia sampling when required

V. WHOLE EFFLUENT TOXICITY TESTING REQUIREMENTS

A. Acute Toxicity Testing

The Discharger shall conduct acute toxicity testing to determine compliance with acute toxicity effluent limitations and shall meet the following acute toxicity testing requirements:

- 1. Test Frequency.** The Discharger shall conduct twice annual acute toxicity testing, conducted during the months of December and March when discharges to the wetland are occurring.
- 2. Sample Type.** For 96-hour static renewal or 96-hour static non-renewal testing, the samples shall be a 24-hour composite and shall be representative of the volume and quality of the discharge from the wastewater treatment facility. Effluent samples shall be collected at Monitoring Location M-001.
- 3. Test Species.** Test species for acute testing shall be with an invertebrate, the water flea, *Ceriodaphnia dubia*, and a vertebrate, the rainbow trout, *Oncorhynchus mykiss*, for at least the first two suites of tests conducted within 12 months after the effective date of the Order. After this screening period, monitoring shall be conducted using the most sensitive species. At least one time every five years, the Discharger shall re-screen with the two species listed above and continue routine monitoring with the most sensitive species.
- 4. Test Methods.** The presence of acute toxicity shall be estimated as specified in *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms* (USEPA Report No. EPA-821-R-02-012, 5th edition or subsequent editions), or other methods approved by the Executive Officer.
- 5. Test Dilutions.** The acute toxicity test shall be conducted using 100 percent effluent collected at Monitoring Location M-001, when discharging to surface waters.

6. **Test Failure.** If an acute toxicity test does not meet all test acceptability criteria, as specified in the test method, the Discharger shall re-sample and re-test as soon as possible, not to exceed 7 days following notification of test failure.
7. **Accelerated Monitoring.** If the result of any acute toxicity test fails to meet the single test minimum limitation (70 percent survival) and the testing meets all test acceptability criteria, the Discharger shall take two more samples, one within 14 days, and one within 21 days of receiving the initial sample result. If any of the additional samples do not comply with the three sample median minimum limitation (90 percent survival), the Discharger shall initiate a Toxicity Reduction Evaluation (TRE) in accordance with Section VI.C.2.c of the Order. If the two additional samples are in compliance with the acute toxicity requirement and the testing meets all test acceptability criteria, then a TRE will not be required. If the discharge has ceased before the additional samples could be collected, the Discharger shall contact the Executive Officer within 21 days with a plan to demonstrate compliance with the acute toxicity effluent limitation.
8. **Notification.** The Discharger shall notify the Regional Water Board in writing 14 days after the receipt of test results exceeding an effluent limitation or trigger. The notification will describe actions the Discharger has taken or will take to investigate and correct the cause(s) of toxicity. It may also include a status report on any actions required by this Order, with a schedule for actions not yet completed. If no actions have been taken, the reasons shall be given.
9. **Reporting.** Test results for acute toxicity tests shall be reported according to the acute toxicity manual Chapter 12 (Report Preparation) or in an equivalent format that clearly demonstrates that the Discharger is in compliance with effluent limitations and other permit requirements.

B. Chronic Toxicity Testing

The Discharger shall conduct chronic toxicity testing to demonstrate compliance with effluent limitations and the Basin Plan's narrative water quality objective for toxicity. The Discharger shall meet the following chronic toxicity testing requirements:

1. **Test Frequency.** The Discharger shall conduct twice annual chronic toxicity testing.
2. **Sample Type.** For 96-hour static renewal or 96-hour static non-renewal testing, the samples shall be 24-hour composite and shall be representative

of the volume and quality of the discharge. The effluent sample shall be collected at Monitoring Location M-001.

3. **Test Species.** Test species for chronic testing shall be a vertebrate, the fathead minnow, *Pimephales promelas* (larval survival and growth test), an invertebrate, the water flea, *Ceriodaphnia dubia* (survival and reproduction test), and a plant, the green alga, *Selenastrum capricornutum* (growth test).
4. **Test Methods.** The presence of chronic toxicity shall be estimated as specified in USEPA's *Short-Term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Water to Freshwater Organisms* (USEPA Report No. EPA-821-R-02-013, 4th or subsequent editions).
5. **Test Dilutions.** The chronic toxicity test shall be conducted using a series of at least five dilutions and a control. The series shall consist of the following dilution series: 12.5, 25, 50, 75, and 100 percent effluent. Control and dilution water should be receiving water at an appropriate location upstream of the discharge point. Laboratory water may be substituted for receiving water, as described in the manual, upon approval by the Regional Water Board Executive Officer. Specifically, for the *Selenastrum capricornutum* test, synthetic laboratory water with a hardness similar to the receiving water shall be used as the control and dilution water. If the dilution water used is different from the culture water, a second control using culture water shall be used.
6. **Reference Toxicant.** If organisms are not cultured in-house, concurrent testing with a reference toxicant shall be conducted. Where organisms are cultured in-house, monthly reference toxicant testing is sufficient. Reference toxicant tests also shall be conducted using the same test conditions as the effluent toxicity tests (e.g., same test duration, etc).
7. **Test Failure.** If either the reference toxicant test or the chronic toxicity test does not meet all test acceptability criteria, as specified in the test method, the Discharger shall re-sample and re-test as soon as possible, not to exceed 7 days following notification of test failure.
8. **Notification.** The Discharger shall notify the Regional Water Board in writing 14 days after the receipt of test results exceeding an effluent limitation or trigger.
9. **Accelerated Monitoring Requirements.** If the result of any chronic toxicity test exceeds the effluent limit of 1.0 TUc, and the testing meets all test acceptability criteria, the Discharger shall evaluate the most recent five chronic toxicity testing results to determine if violations have occurred with a frequency greater than or equal to twenty percent of the time. If the discharge

has exceeded the effluent limitation of 1.0 TUc twenty percent of the time or more, the Discharger shall initiate a TRE including accelerated and or confirmation monitoring. If the discharge will cease before additional samples can be collected, the Discharger shall contact the Executive Officer within 21 days with a plan to reduce chronic toxicity in effluent below 1.0 TUc. The following protocol shall be used for accelerated monitoring and TRE implementation:

- a. The Discharger shall cease accelerated monitoring and initiate a TRE to investigate the cause(s) of, and identify corrective actions to reduce or eliminate effluent toxicity. Within thirty (30) days of notification by the laboratory of the test results exceeding the effluent limitation during accelerated monitoring, the Discharger shall submit a TRE Action Plan to the Regional Water Board including, at minimum:
 1. Specific actions the Discharger will take to investigate and identify the cause(s) of toxicity, including TRE WET monitoring schedule;
 2. Specific actions the Discharger will take to mitigate the impact of the discharge and prevent the recurrence of toxicity; and
 3. A schedule for these actions.

C. Chronic Toxicity Reporting

1. **Routine Reporting.** Test results for chronic tests shall be reported according to the acute and chronic manuals and the Monitoring and Reporting Program and shall be attached to the corresponding monthly self-monitoring report. Test results shall include, at a minimum, for each test:
 - a. sample date(s)
 - b. test initiation date
 - c. test species
 - d. end point values for each dilution (e.g., number of young, growth rate, percent survival)
 - e. NOEC value(s) in percent effluent
 - f. IC15, IC25, IC40, and IC50 values (or EC15, EC25...etc.) in percent effluent
 - g. TUc values (100/NOEC, 100/IC25, 100/ EC25)
 - h. Mean percent mortality (\pm s.d.) after 96 hours in 100 percent effluent (if applicable)
 - i. NOEC and LOEC values for reference toxicant test(s)
 - j. IC50 or EC50 value(s) for reference toxicant test(s)
 - k. Available water quality measurements for each test (e.g., pH, DO, temperature, conductivity, hardness, salinity, ammonia)
 - l. Statistical methods used to calculate endpoints.

m. The statistical output page, which includes the calculation of percent minimum significant difference (PMSD)

2. **Quality Assurance Reporting.** Because the permit requires sublethal hypothesis testing endpoints from Methods 1000.0, 1002.0, and 1003.0 in the test methods manual titled *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms* (EPA-821-R-02-013, 2002), with-in test variability must be reviewed for acceptability, and variability criteria (upper and lower PMSD bounds) must be applied, as directed under section 10.2.8 – *Test Variability* of the test methods manual. Under section 10.2.8, the calculated PMSD for both reference toxicant test and effluent toxicity test results must be compared with the upper and lower PMSD bounds variability criteria specified in Table 6 – *Variability Criteria (Upper and Lower PMSD Bounds) for Sublethal Hypothesis Testing Endpoints Submitted Under NPDES Permits*, following the review criteria in paragraphs 10.2.8.2.1 through 10.2.8.2.5 of the test methods manual. Based on this review, only accepted effluent toxicity test results shall be reported.
3. **Compliance Summary:** The monthly discharger self-monitoring reports shall contain an updated chronology of chronic toxicity test results expressed in TUc, and organized by test species, type of test (survival, growth or reproduction), and monitoring frequency (routine, accelerated, or TRE). The final report shall clearly demonstrate that the Discharger is in compliance with effluent limitations and other permit requirements.

VI. LAND DISCHARGE MONITORING REQUIREMENTS

This Section does not apply to the Loleta Wastewater Treatment Facility.

VII. RECLAMATION MONITORING REQUIREMENTS

This Section does not apply to the Loleta Wastewater Treatment Facility.

VIII. RECEIVING WATER MONITORING REQUIREMENTS – SURFACE WATER AND GROUNDWATER

A. Monitoring Location R-001

1. The Discharger shall monitor the wetland at R-001 as follows:

Table E-5. Receiving Water Monitoring Requirements

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
pH	Standard Units	Grab	Monthly ¹	Standard Methods
Temperature	°F or °C	Grab	Monthly ¹	Standard Methods
Dissolved Oxygen	mg/L	Grab	Monthly	Standard Methods
Specific Conductance	micromhos	Grab	Monthly	Standard Methods

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
Total Dissolved Solids	mg/L	Grab	Monthly	Standard Methods
Turbidity	mg/L	Grab	Monthly	Standard Methods
Floatables/discoloration	---	Visual	Monthly	---
Priority Pollutants ^b	µg/L	Grab	2x / Order term	Standard Methods
Hardness (CaCO ₃)	mg/L	Grab	Concurrent with Priority Pollutant Sampling	Standard Methods

¹ Measurements for temperature and pH must be taken in timing with effluent ammonia sampling when required

B. Monitoring Location R-002

1. The Discharger shall monitor the wetland at R-002s as follows:

Table E-6. Receiving Water Monitoring Requirements

Parameter	Units	Sample Type	Minimum Sampling Frequency	Required Analytical Test Method
pH	Standard Units	Grab	Monthly	Standard Methods
Temperature	°F or °C	Grab	Monthly	Standard Methods
Dissolved Oxygen	mg/L	Grab	Monthly	Standard Methods
Specific Conductance	micromhos	Grab	Monthly	Standard Methods
Total Dissolved Solids	mg/L	Grab	Monthly	Standard Methods
Turbidity	mg/L	Grab	Monthly	Standard Methods
Floatables/discoloration	---	Visual	Monthly	---

IX. OTHER MONITORING REQUIREMENTS

This Section does not apply to the Loleta Wastewater Treatment Facility.

X. REPORTING REQUIREMENTS

A. General Monitoring and Reporting Requirements

1. The Discharger shall comply with all Standard Provisions (Attachment D) related to monitoring, reporting, and recordkeeping.
2. **Compliance Time Schedules.** If applicable, for compliance time schedules included in the Order, the Discharger shall submit to the Regional Water Board, on or before each compliance due date, the specified document or a written report detailing compliance or noncompliance with the specific date and task. If noncompliance is reported, the Discharger shall state the reasons for noncompliance and include an estimate of the date when the Discharger will be in compliance. The Discharger shall notify the Regional Water Board by letter when it returns to compliance with the compliance time schedule.

B. Self Monitoring Reports (SMRs)

1. At any time during the term of this permit, the State or Regional Water Board may notify the Discharger to electronically submit Self-Monitoring Reports

(SMRs) using the State Water Board's California Integrated Water Quality System (CIWQS) Program Web site (<http://www.waterboards.ca.gov/ciwqs/index.html>). Until such notification is given, the Discharger shall submit hard copy SMRs. The CIWQS Web site will provide additional directions for SMR submittal in the event there will be service interruption for electronic submittal.

2. The Discharger shall report in the SMR the results for all monitoring specified in this MRP under sections III through IX. The Discharger shall submit monthly and annual summary SMRs including the results of all required monitoring using USEPA-approved test methods or other test methods specified in this Order. If the Discharger monitors any pollutant more frequently than required by this Order, the results of this monitoring shall be included in the calculations and reporting of the data submitted in the SMR.
3. Monitoring periods and reporting for all required monitoring shall be completed according to the following schedule:

Table E-7. Monitoring Periods and Reporting Schedule

Sampling Frequency	Monitoring Period Begins On...	Monitoring Period	SMR Due Date
Continuous	May 1, 2008	All	First Day Of Second Calendar Month Following Month Of Sampling
Daily	May 1, 2008	Midnight through 11:59 PM or any 24-hour period that reasonably represents a calendar day for purposes of sampling.	First Day Of Second Calendar Month Following Month Of Sampling
Weekly	May 4, 2008	Sunday through Saturday	First Day Of Second Calendar Month Following Month Of Sampling
Monthly	May 1, 2008	1st day of calendar month through last day of calendar month	First Day Of Second Calendar Month Following Month Of Sampling
Twice Annually	March 1, 2008	March 1 through March 30 and December 1 through December 31	30 days from the end of the monitoring period
Annually	January 1, 2009	January 1 through December 31	February 1
2X / Order Term	July 1, 2007/November 1, 2007	July 1 through November 30 2007	January 1, 2009

4. Reporting Protocols. The Discharger shall report with each sample result the applicable Reporting Level (RL) and the current Method Detection Limit (MDL), as determined by the procedure in CFR Part 136.

The Discharger shall report the results of analytical determinations for the presence of chemical constituents in a sample using the following reporting protocols:

- a. Sample results greater than or equal to the RL shall be reported as measured by the laboratory (i.e., the measured chemical concentration in the sample).
- b. Sample results less than the RL, but greater than or equal to the laboratory's MDL, shall be reported as "Detected, but Not Quantified," or DNQ. The estimated chemical concentration of the sample shall also be reported.

For the purposes of data collection, the laboratory shall write the estimated chemical concentration next to DNQ as well as the words "Estimated Concentration" (may be shortened to "Est. Conc."). The laboratory may, if such information is available, include numerical estimates of the data quality for the reported result. Numerical estimates of data quality may be percent accuracy (\pm a percentage of the reported value), numerical ranges (low to high), or any other means considered appropriate by the laboratory.

- c. Sample results less than the laboratory's MDL shall be reported as "Not Detected," or ND.
 - d. Dischargers are to instruct laboratories to establish calibration standards so that the ML value (or its equivalent if there is differential treatment of samples relative to calibration standards) is the lowest calibration standard. At no time is the Discharger to use analytical data derived from *extrapolation* beyond the lowest point of the calibration curve.
5. The Discharger shall submit SMRs in accordance with the following requirements:
- a. The Discharger shall arrange all reported data in a tabular format. The data shall be summarized to clearly illustrate whether the facility is operating in compliance with interim and/or final effluent limitations. The reported data shall include calculation of all effluent limitations that require averaging, taking of a median or other computation. The Discharger is not required to duplicate the submittal of data that is entered in a tabular format within CIWQS. When electronic submittal of data is required and CIWQS does not provide for entry into a tabular format within the system, the Discharger shall electronically submit the data in a tabular format as an attachment. During periods of land discharge, the reports shall certify "land discharge".

- b. The Discharger shall attach a cover letter to the SMR. The information contained in the cover letter shall clearly identify:
 1. Name and address of facility; (preferably on company letterhead)
 2. WDID number; (facility number found on the front page of the permit, in the format "ID No. _____")
 3. Date of report, and monitoring period; (e.g., May 2007, 1st quarter 2007, etc.)
 4. Summary Table showing:
 - a. Discharge Identification; (SN001, SN002, etc.)
 - b. Analytical results;
 - c. Reporting units;
 - d. Sample results less than the method detection level must be reported as "not detected" or ND and must be followed by the MDL expressed as > X mg/l
 - e. Permit effluent limitations for each constituent sampled;
 - f. Calculations for all limitations that require calculations; (percent removal, average, median)
 5. Identify and report all instances of noncompliance, including instances when there was a failure to collect a required sample, a sample result cannot be reported because the sample result is not valid, or a sample result cannot be reported because a collected sample was lost in transit;
 6. Document maintenance performed during the reporting period, and/or foreseeable maintenance;
 7. Explain how maintenance has or will effect monitoring results;
 8. Attach copies of laboratory reports/chemical examination reports if requested by the Regional Water Board;
- b. SMRs must be submitted to the Regional Water Board, signed and certified as required by the Standard Provisions (Attachment D), to the address listed below:

North Coast Regional Water Quality Control Board
5550 Skylane Blvd, Suite A
Santa Rosa, CA 95403

C. Discharge Monitoring Reports (DMRs)

1. As described in Section X.B.1 above, at any time during the term of this permit, the State or Regional Water Board may notify the Discharger to electronically submit SMRs that will satisfy federal requirements for submittal of Discharge Monitoring Reports (DMRs). Until such notification is given, the Discharger shall submit DMRs in accordance with the requirements described below.

2. DMRs must be signed and certified as required by the standard provisions (Attachment D). The Discharge shall submit the original DMR and one copy of the DMR to the address listed below:

Standard Mail	FedEx/UPS/ Other Private Carriers
State Water Resources Control Board Division of Water Quality c/o DMR Processing Center PO Box 100 Sacramento, CA 95812-1000	State Water Resources Control Board Division of Water Quality c/o DMR Processing Center 1001 I Street, 15 th Floor Sacramento, CA 95814

3. All discharge monitoring results must be reported on the official USEPA pre-printed DMR forms (EPA Form 3320-1). Forms that are self-generated or modified cannot be accepted.

D. Other Reports

1. The Discharger shall report the results of any special studies required by Special Provisions – VI.C.2. a and VI.C.2.b of this Order.
2. Annual Report. The Discharger shall submit an annual report to the Regional Water Board for each calendar year. The report shall be submitted by February 1st of the following year. The report shall, at a minimum, include the following:
 - a. Both tabular and, where appropriate, graphical summaries of the monitoring data and disposal records from the previous year. If the Discharger monitors any pollutant more frequently than required by this Order, using test procedures approved under 40 CFR Part 136 or as specified in this Order, the results of this monitoring shall be included in the calculation and report of the data submitted SMR.
 - b. A comprehensive discussion of the facility’s compliance (or lack thereof) with all effluent limitations and other WDRs, and the corrective actions taken or planned, which may be needed to bring the discharge into full compliance with the Order.
 - c. Sanitary Sewer System Reporting. The Discharger shall submit, as part of its annual report to the Regional Water Board, a description of the Discharger’s activities within the sanitary sewer system over the previous twelve months. The report shall contain:
 - i. A description of any change in the local legal authorities enacted to implement the Sewer System Management Plan (SSMP);

- ii. A summary of the SSOs that occurred in the past year. The summary shall include the date, location of overflow point, affected receiving water (if any), estimated volume, and cause of the SSO, and the names and addresses of the responsible parties as well as the names and addresses of the property owner(s) affected by the sanitary sewer overflow;
 - iii. A summary of compliance and enforcement activities during the past year. The summary shall include fines, other penalties, or corrective actions taken as a result of the SSO. The summary shall also include a description of public participation activities to involve and inform the public;
 - iv. Documentation that all feasible steps to stop and mitigate impacts of sanitary sewer overflows have been taken;
 - v. Documentation that the annual report has been made available to the public.
- d. Source Control Activity Reporting. The Discharger shall submit, as part of its annual report to the Regional Water Board, a description of the Discharger's source control activities, as required by Provision VI.C.5.b. of Order No. R1-2006-0049, during the past year. This annual report is due on February 1st of each year, beginning on February 1, 2008 and shall contain:
- i. A copy of the source control standards.
 - ii. A description of the waste hauler permit system; if applicable.
 - iii. A summary of the compliance and enforcement activities during the past year. The summary shall include the names and addresses of any industrial or commercial users under surveillance by the Discharger, an explanation of whether they were inspected, sampled, or both, the frequency of these activities at each user, and the conclusions or results from the inspection or sampling of each user.
 - iv. A summary of public participation activities to involve and inform the public.

ATTACHMENT F – FACT SHEET

Table of Contents

Attachment F – Fact Sheet.....	D-3
I. Permit Information.....	D-3
II. Facility Description	D-4
A. Description of Wastewater and Biosolids Treatment or Controls.....	D-4
B. Discharge Points and Receiving Waters	Error! Bookmark not defined.
C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data	D-5
D. Compliance Summary	D-5
E. Planned Changes	D-5
III. Applicable Plans, Policies, and Regulations.....	D-5
A. Legal Authorities.....	D-5
B. California Environmental Quality Act (CEQA).....	D-6
C. State and Federal Regulations, Policies, and Plans	D-6
D. Impaired Water Bodies on CWA 303(d) List.....	D-9
E. Other Plans, Polices and Regulations	D-9
IV. Rationale For Effluent Limitations and Discharge Specifications	D-10
A. Discharge Prohibitions.....	D-10
B. Technology-Based Effluent Limitations	D-12
1. Scope and Authority	D-12
2. Applicable Technology-Based Effluent Limitations	D-13
C. Water Quality-Based Effluent Limitations (WQBELs)	D-14
1. Scope and Authority	D-14
2. Applicable Beneficial Uses and Water Quality Criteria and Objectives.....	D-14
3. Determining the Need for WQBELs.....	D-15
4. WQBEL Calculations	D-16
5. Summary of Water Quality-based Effluent Limitations Discharge Point 001	D-16
6. Whole Effluent Toxicity (WET).....	D-1
D. Final Effluent Limitations	D-1
1. Satisfaction of Anti-Backsliding Requirements	D-1
2. Satisfaction of Antidegradation Policy	D-2
3. Stringency of Requirements for Individual Pollutants	D-2
E. Interim Effluent Limitations	D-3
F. Land Discharge Specifications	D-4
G. Reclamation Specifications	D-4
V. Rationale for Receiving Water Limitations.....	D-4
A. Surface Water.....	D-4
B. Groundwater.....	D-4
VI. Rationale for Monitoring and Reporting Requirements	D-5
A. Influent Monitoring	D-5
B. Effluent Monitoring.....	D-5
C. Whole Effluent Toxicity Testing Requirements	D-6
1. Acute Toxicity	D-6
2. Chronic Toxicity	D-7
D. Receiving Water Monitoring	D-9

1. Surface Water.....	D-9
2. Groundwater.....	D-9
D. Other Monitoring Requirements.....	D-9
VII. Rationale for Provisions	D-9
A. Standard Provisions	D-9
B. Special Provisions	D-10
1. Reopener Provisions	D-10
2. Special Studies and Additional Monitoring Requirements	D-10
3. Best Management Practices and Pollution Prevention	D-12
4. Construction, Operation, and Maintenance Specifications	D-12
5. Special Provisions for Municipal Facilities (POTWs Only).....	D-12
6. Other Special Provisions	D-15
7. Compliance Schedules.....	D-15
VIII. Public Participation.....	D-15
A. Notification of Interested Parties.....	D-15
B. Written Comments.....	D-15
C. Public Hearing	D-15
D. Waste Discharge Requirements Petitions	D-16
E. Information and Copying	D-16
F. Register of Interested Persons	D-16
G. Additional Information.....	D-16

List of Tables

Table F-1. Facility Information.....	D-3
Table F-2. Historic Effluent Limitations and Monitoring Data.....	D-5
Table F-3. Basin Plan Beneficial Uses for the Receiving Water	D-6
Table F-4. Summary of Water Quality-based Effluent Limitations	D-1
Table F-5. Effluent Limitations – Discharge Point 001.....	D-3

ATTACHMENT F – FACT SHEET

As described in section II of this Order, this Fact Sheet includes the legal requirements and technical rationale that serve as the basis for the requirements of this Order. This Order has been prepared under a standardized format to accommodate a broad range of discharge requirements for dischargers in California. Only those sections or subsections of this Order that are specifically identified as “not applicable” have been determined not to apply to this Discharger. Sections or subsections of this Order not specifically identified as “not applicable” are fully applicable to this Discharger.

I. PERMIT INFORMATION

The following table summarizes administrative information related to the facility.

Table F-1. Facility Information

WDID	1B80081OHUM
Discharger	Loleta Community Services District
Name of Facility	Loleta Community Services District Wastewater Treatment Facility
Facility Address	298 Eel River Drive
	Loleta, CA 95551
	Humboldt County
Facility Contact, Title and Phone	Marcus Drumm, General Manager, (707) 733-1717
Authorized Person to Sign and Submit Reports	General Manager (707) 733-1717
Mailing Address	P.O Box 236 Loleta, CA 95551
Billing Address	SAME
Type of Facility	POTW
Major or Minor Facility	Minor
Threat to Water Quality	2
Complexity	B
Pretreatment Program	N/A
Reclamation Requirements	N/A
Facility Permitted Flow	0.081 MGD (average dry weather flow)
	0.143 MGD (average wet weather flow)
Facility Design Flow	0.081 MGD (average dry weather flow)
	0.143 MGD (average wet weather flow)
Watershed	Eel River
Receiving Water	Wetland tributary to the Eel River
Receiving Water Type	Inland surface water

- A. The Loleta Community Services District (hereinafter Discharger) is the owner and operator of the Loleta Community Services District Wastewater Treatment Facility (hereinafter Facility), a wastewater treatment plant. For the purposes of this Order, references to the “discharger” or “permittee” in applicable federal and state laws, regulations, plans, or policy are held to be equivalent to references to the Discharger herein.

- B. The Facility discharges wastewater to a wetland, tributary to an unnamed slough (hereinafter slough) and the Eel River, a water of the United States, and is currently regulated by Order R1-2001-59 which was adopted on June 28, 2001 and expired on June 28, 2006. The terms and conditions of the current Order have been automatically continued and remain in effect until new Waste Discharge Requirements and National Pollutant Discharge Elimination System (NPDES) permit are adopted pursuant to this Order.
- C. The Discharger filed a report of waste discharge and submitted an application for renewal of its Waste Discharge Requirements (WDRs) and NPDES permit on December 30, 2005. A site visit was conducted on April 6, 2007 to observe operations and collect additional data to develop permit limitations and conditions.

II. FACILITY DESCRIPTION

The Loleta Community Services District is located in Humboldt County off Highway 101 approximately 13 miles south of Eureka. The district is located within the Lower Eel River watershed and serves approximately 750 residential customers and two commercial customers, the Humboldt Creamery Association facility and the Loleta Cheese Factory. The Discharger owns and operates all wastewater collection and treatment facilities.

A. Description of Wastewater and Biosolids Treatment or Controls

Waste treatment and disposal facilities include an aeration basin, clarifier, sludge storage vault, chlorine contact chamber, and chlorine and sulfur flow-proportioning equipment. The chlorine contact chamber was rebuilt in 2001 and clarifier baffles were repaired and replaced in 2003. The chlorine disinfection system was also recently improved along with the installation of a new alarm system and emergency generator.

Effluent is discharged at Discharge Point 001 to a wetland, which is tributary to the slough, which is tributary to the Eel River. The discharge to the wetland occurs at a point on the north bank $\frac{1}{4}$ mile south of Dugan Road in the NW $\frac{1}{4}$ Section 19, T3N, R1W, HB&M as shown on Attachment B.

Sludge from the clarifier is stored in a vault and is periodically pumped and hauled to a permitted facility for further treatment and disposal.

The Facility receives wastewater from a Humboldt Creamery Association production facility and the Loleta Cheese Factory. Both facilities impact the performance of the Facility as a result of discharges of high strength (BOD_5) washwater and wastewaters characterized by high and low pH. The Discharger regulates these two facilities through District Ordinance No. 76-01, Article 8, Section 3.8.

C. Summary of Existing Requirements and Self-Monitoring Report (SMR) Data

Effluent limitations contained in the previous Order (R1-2001-059) for discharges from Discharge Point 001 and representative monitoring data from the term of the previous Order are presented in Table F-2.

Table F-2. Historic Effluent Limitations and Monitoring Data

Parameter	Units	Effluent Limitation			Monitoring Data (From 1/1/2002 – 12/31/2006)	
		Average Monthly	Average Weekly	Maximum Daily	Highest Average Monthly Discharge	Highest Daily Discharge
BOD	mg/L	30	45	60	27	-
	lb/day	25	38	50	33	-
TSS	mg/L	30	45	60	27.5	-
	lb/day	25	38	50	63	-
Settleable Solids	ml/L	0.1	N/A	0.2	0.125	0.6
Coliform Organisms	MPN/100 ml	23	N/A	230	341	1600
pH	S.U.	Not less than 6.5 nor greater than 8.5			4.8 ^a	7.15 ^b

^a Lowest reported value

^b Highest reported value

D. Compliance Summary

Administrative Civil Liability Order No. R1-2007-0003 was adopted to address compliance issues regarding this discharger. The tentative order states that the Discharger has exceeded effluent limitations 91 times during the period from January 1, 2000 through April 30, 2005, and establishes a penalty for each serious and chronic violation. A portion of the penalties are to be directed toward a Compliance Project which includes improvements to the treatment system and repair and testing of the collection system to reduce I&I.

E. Planned Changes

The Discharger has budgeted in excess of \$20,000 per year over the term of the next permit in order to conduct further smoke testing and pipe repairs on the collection system. This funding is intended to address the I&I problems that have resulted in exceedances of flow and effluent limitations. Funding is being provided in the form of a Compliance Project (see Order No. R1-2007-0003)

III. APPLICABLE PLANS, POLICIES, AND REGULATIONS

The requirements contained in the proposed Order are based on the requirements and authorities described in this section.

A. Legal Authorities

This Order is issued pursuant to section 402 of the federal Clean Water Act (CWA) and implementing regulations adopted by the U.S. Environmental Protection Agency (USEPA) and chapter 5.5, division 7 of the California Water Code (commencing with section 13370). It shall serve as a NPDES permit for point

source discharges from this facility to surface waters. This Order also serves as Waste Discharge Requirements (WDRs) pursuant to article 4, chapter 4, division 7 of the Water Code (commencing with section 13260).

B. California Environmental Quality Act (CEQA)

Under Water Code section 13389, this action to adopt an NPDES permit is exempt from the provisions of CEQA, Public Resources Code sections 21100 through 21177.

C. State and Federal Regulations, Policies, and Plans

1. **Water Quality Control Plans.** The Regional Water Quality Control Board (Regional Water Board) adopted a Water Quality Control Plan for the North Coast (hereinafter Basin Plan) that designates beneficial uses, establishes water quality objectives, and contains implementation programs and policies to achieve those objectives for all waters addressed through the plan. Requirements of this Order implement the Basin Plan.
2. The Basin Plan at page 2-1.00 states that the beneficial uses of any specifically identified water body generally apply to its tributary streams. The Basin Plan specifies beneficial uses for wetlands, however it does not specifically identify beneficial uses for the slough, but identifies present and potential uses for the Eel River, to which the wetland and slough are tributary. In addition, the Basin Plan implements State Water Resources Control Board (State Water Board) Resolution No. 88-63, which established State policy that all waters, with certain exceptions, should be considered suitable or potentially suitable for municipal or domestic supply. Thus, beneficial uses applicable to and the Eel River are as follows:

Table F-3. Basin Plan Beneficial Uses for the Receiving Water

Discharge Point	Receiving Water Name	Beneficial Use(s)
001 (formerly SN 001)	Wetland, tributary to the Eel River	<u>Existing:</u> MUN – Municipal and Domestic Supply AGR – Agricultural Supply IND – Industrial Service Supply GWR – Groundwater Recharge FRSH – Freshwater Replenishment NAV – Navigation REC1 – Water Contact Recreation REC2 – Non-Contact Water Recreation COMM – Commercial and Sport Fishing COLD – Cold Freshwater Habitat WILD – Wildlife Habitat RARE – Preservation of Rare, Threatened, or Endangered Species MIGR – Migration of Aquatic Organisms SPWN – Spawning, Reproduction, and/or Early Development SHELL – Shellfish Harvesting EST – Estuarine Habitat CUL – Native American Culture WET – Wetland Habitat <u>Potential:</u> PRO – Industrial Process Supply POW – Hydropower Generation MAR – Marine Habitat AQUA – Aquaculture FLD – Flood Peak Attenuation/Flood Water Storage WQE – Water Quality Enhancement

Of particular importance to the Loleta Community Services District and its NPDES permit is that the Basin Plan establishes a prohibition against discharges to the Eel River and its tributaries between May 15 and September 30 in all years and at all other times when the rate of waste discharge exceeds one percent of the flow of the receiving water. An exception to the rate of discharge could be granted by the Regional Water Board in accordance with Basin Plan requirements if shown to provide adequate protection of beneficial uses.

- 2. Thermal Plan.** The State Water Board adopted a Water Quality Control Plan for Control of Temperature in the Coastal and Interstate Water and Enclosed Bays and Estuaries of California (Thermal Plan) on May 18, 1972, and amended this plan on September 18, 1975. The Loleta Community Services District’s wastewater treatment facility does not discharge thermal or elevated temperature wastes and therefore the Order does not include effluent limitations for temperature in response to the requirements of the Thermal Plan.

- 3. National Toxics Rule (NTR) and California Toxics Rule (CTR).** USEPA adopted the NTR on December 22, 1992, and later amended it on May 4, 1995 and November 9, 1999. About forty criteria in the NTR applied in California. On May 18, 2000, USEPA adopted the CTR. The CTR promulgated new toxics criteria for California and, in addition, incorporated the previously adopted NTR criteria that were applicable in the state. The CTR was amended on February 13, 2001. These rules contain water quality criteria for priority pollutants which are applicable to discharges from the Loleta Community Services District's wastewater treatment facility.
- 4. State Implementation Policy.** On March 2, 2000, the State Water Board adopted the Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (State Implementation Policy or SIP). The SIP became effective on April 28, 2000 with respect to the priority pollutant criteria promulgated for California by the USEPA through the NTR and to the priority pollutant objectives established by the Regional Water Board in the Basin Plan. The SIP became effective on May 18, 2000 with respect to the priority pollutant criteria promulgated by the USEPA through the CTR. The State Water Board adopted amendments to the SIP on February 24, 2005 that became effective on July 13, 2005. The SIP establishes implementation provisions for priority pollutant criteria and objectives and provisions for chronic toxicity control. Requirements of this Order implement the SIP.
- 5. Alaska Rule.** On March 30, 2000, USEPA revised its regulation that specifies when new and revised state and tribal water quality standards (WQS) become effective for CWA purposes (40 C.F.R. § 131.21, 65 Fed. Reg. 24641 (April 27, 2000)). Under the revised regulation (also known as the Alaska rule), new and revised standards submitted to USEPA after May 30, 2000, must be approved by USEPA before being used for CWA purposes. The final rule also provides that standards already in effect and submitted to USEPA by May 30, 2000, may be used for CWA purposes, whether or not approved by USEPA.
- 6. Antidegradation Policy.** Section 131.12 requires that the state water quality standards include an antidegradation policy consistent with the federal policy. The State Water Board established California's antidegradation policy in State Water Board Resolution No. 68-16. Resolution No. 68-16 incorporates the federal antidegradation policy where the federal policy applies under federal law. Resolution No. 68-16 requires that existing water quality be maintained unless degradation is justified based on specific findings. The Regional Water Board's Basin Plan implements, and incorporates by reference, both the State and federal antidegradation policies. The permitted discharge is consistent with the antidegradation provision of section 131.12 and State Water Board Resolution No. 68-16.

7. Anti-Backsliding Requirements. Sections 402(o)(2) and 303(d)(4) of the CWA and federal regulations at title 40, Code of Federal Regulations¹ section 122.44(l) prohibit backsliding in NPDES permits. These anti-backsliding provisions require that effluent limitations in a reissued permit must be as stringent as those in the previous permit, with some exceptions in which limitations may be relaxed.

D. Impaired Water Bodies on CWA 303(d) List

The USEPA approved the State's 2006 303(d) list of impaired water bodies on December 26, 2006. Certain receiving waters in the Eel River watershed do not fully support beneficial uses and therefore have been classified as impaired on the 2006 303(d) list. The 2006 State Water Board's California 303(d) List classifies the Lower Eel River as impaired. The pollutants of concern include temperature and sediment. TMDLs are under development. None-the-less, discharges from the Loleta WWTF will have no measurable adverse impacts to sediment or temperature in the Eel River or its tributaries.

E. Other Plans, Policies and Regulations

1. The Basin Plan includes water quality objectives, implementation plans for point source and nonpoint source discharges, prohibitions, and statewide plans and policies.
2. The Basin Plan contains a narrative objective (standard) for toxicity that requires:

All waters shall be maintained free of toxic substances in concentrations that are toxic to, or that produce detrimental physiological responses in human, plant, animal, or aquatic life. Compliance with this objective will be determined by use of indicator organisms, analyses of species diversity, population density, growth anomalies, bioassay of appropriate duration or other appropriate methods as specified by the Regional Water Board.

The survival of aquatic life in surface waters subjected to a waste discharge, or other controllable water quality factors, shall not be less than that for the same water body in areas unaffected by the waste discharge, or when necessary for other control water that is consistent with the requirements for "experimental water" as described in Standard Methods for the Examination of Water and Wastewater 18th Edition (1992). At a minimum, compliance with this objective as stated in the previous sentence shall be evaluated with a 96-hour bioassay.

In addition, effluent limits based upon acute bioassays of effluent will be prescribed. Where appropriate, additional numerical receiving water

¹ All further statutory references are to title 40 of the Code of Federal Regulations unless otherwise indicated.

objectives for specific toxicants will be established as sufficient data become available, and source control of toxic substances will be required.

IV. RATIONALE FOR EFFLUENT LIMITATIONS AND DISCHARGE SPECIFICATIONS

The CWA requires point source dischargers to control the amount of conventional, non-conventional, and toxic pollutants that are discharged into the waters of the United States. The control of pollutants discharged is established through effluent limitations and other requirements in NPDES permits. There are two principal bases for effluent limitations in the Code of Federal Regulations: section 122.44(a) requires that permits include applicable technology-based limitations and standards; and section 122.44(d) requires that permits include water quality-based effluent limitations to attain and maintain applicable numeric and narrative water quality criteria to protect the beneficial uses of the receiving water.

A. Discharge Prohibitions

The discharge prohibitions are based on the requirements of the Basin Plan, State Water Board's plans and policies, the Water Code, and previous permit provisions, and are consistent with the requirements set for other discharges regulated by NPDES permits to waters of the United States.

1. Discharge Prohibition III.A. Discharge of any waste not disclosed by the Discharger or not within the reasonable contemplation of the Regional Water Board is prohibited.

This prohibition is based on the Basin Plan, previous Order, and State Water Board Order WQO 2002-0012 regarding the petition of WDR Order No. 01-072 for the East Bay Municipal Utility District and Bay Area Clean Water Agencies. In Order WQO 2002-0012, the State Water Board found that this prohibition is acceptable in permits, but should be interpreted to apply only to constituents that are either not disclosed by the discharger or are not reasonably anticipated to be present in the discharge, but have not been disclosed by the discharger. It specifically does not apply to constituents in the discharge that do not have "reasonable potential" to exceed water quality objectives.

The State Water Board has stated that the only pollutants not covered by this prohibition are those which were "disclosed to the permitting authority and . . . can be reasonably contemplated." (In re the Petition of East Bay Municipal Utilities District et al., (State Water Board 2002) Order No. WQ 2002-0012, p. 24.) The case cited in that order by the State Water Board reasoned that the Discharger is liable for discharges "not within the reasonable contemplation of the permitting authority . . . , whether spills or otherwise" (Piney Run Preservation Assn. v. County Commissioners of Carroll County, Maryland (4th Cir. 2001) 268 F.3d 255, 268.) Thus, State Water Board authority provides that, to be permissible, the constituent discharged (1) must have

been disclosed by the Discharger and (2) can be reasonably contemplated by the Regional Water Board.

The Regional Water Board has the authority to determine whether the discharge of a constituent is “reasonably contemplated.” The Piney Run case makes clear that the Discharger is liable for discharges “not within the reasonable contemplation of the permitting authority (emphasis added)” (268 F.3d 255, 268) In other words, whether or not the Discharger reasonably contemplates the discharge of a constituent is not relevant. What matters is whether the Discharger disclosed the constituent to the Regional Water Board or whether the presence of the pollutant in the discharge can otherwise be reasonably contemplated by the Regional Water Board at the time of permit adoption.

2. **Discharge Prohibition III.B. Creation of a pollution, contamination, or nuisance, as defined by Section 13050 of the California Water Code, is prohibited.**
This prohibition is based on CWC Section 13050 and is retained from Order R1-2001-59.
3. **Discharge Prohibition III.C. Discharge of sludge or digester supernatant is prohibited except as provided by Sections VI. C .5. d. and e.**
This prohibition is based on restrictions on the disposal of sludge found in federal and State regulations (40 CFR Part 503 and Title 27 of the California Code of Regulations). It has been retained from Order R1-2001-59.
4. **Discharge Prohibition III.D. The discharge or reclamation of untreated or partially treated wastewater is prohibited, except as provided for in Attachment D, Standard Provision G (Bypass Provision).**
This prohibition is based on the Basin Plan objective of protecting beneficial uses from adverse effects of unpermitted discharges, and on the intent of Water Code sections 13260 through 13264 relating to the discharges to waters of the State without filing for and being issued a permit. This prohibition applies to, but is not limited to, sanitary sewer overflows, spills, and other unauthorized discharges of wastewater within the collection, treatment, reclamation, and disposal facilities.
5. **Discharge Prohibition III.E. Discharges to the Eel River and its tributaries is prohibited during the period from May 15 through September 30**
This prohibition is required by the Basin Plan, which prohibits discharges to the Eel River and its tributaries during the period of May 15 through September 30 (Chapter 4, North Coastal Basin Discharge Prohibition No.3). The intent of the prohibition is to prevent the contribution of wastewater to the baseline flow during the period of the year when the Eel River and its

tributaries experience the heaviest water contact recreation use and when flows are lowest. This prohibition has been retained from Order R1-2001-59.

It is unclear at this time if the Loleta facility is in compliance with this prohibition. Accordingly, a special study required under Provision VI.C.2.a. of this Order requires the Discharger to evaluate compliance.

6. Discharge Prohibition III.F. During the period of October 1 through May 14, discharges of wastewater shall not exceed one percent of the flow of the Eel River or its tributaries at any time.

The Basin Plan prohibits discharges to the Eel River or its tributaries which are greater than one percent of the receiving stream's flow during the period from October 1 through the May 14 (Chapter 4, North Coastal Basin Discharge Prohibition No.3). This prohibition is retained from Order No. R1-2001-59. A special study required under Provision VI.C.2.b. of this Order requires the Discharger to evaluate the actual discharge rate in the wetland and show compliance or find an alternate method to achieve compliance with the Basin Plan prohibition.

7. Discharge Prohibition III.G. Discharges to land not owned by or under agreement for use by the Discharger are prohibited.

Land used for the application of wastewater must be owned by, or be under the control of, the Discharger by contract so that the Discharger maintains a means for ultimate disposal of treated wastewater.

8. Discharge Prohibition III.H. Discharges of waste at any point not described in Finding II.B. or authorized by the State Water Board or another Regional Water Board permit are prohibited.

This prohibition is a general prohibition that allows the Discharger to discharge waste only in accordance with waste discharge requirements. It is based on CWA sections 301 and 402 and Water Code section 13263.

B. Technology-Based Effluent Limitations

1. Scope and Authority

Regulations promulgated in section 125.3 (a) (1) require technology-based effluent limitations for municipal dischargers to be placed in NPDES Orders based on Secondary Treatment Standards or Equivalent to Secondary Treatment Standards.

The Federal Water Pollution Control Act Amendments of 1972 (PL 92-500) established the minimum performance requirements for POTWs [defined in section 304(d)(1)]. Section 301(b)(1)(B) of that Act requires that such treatment works must, as a minimum, meet effluent limitations based on secondary treatment as defined by the USEPA Administrator.

Based on this statutory requirement, USEPA developed secondary treatment regulations, which are specified in section 133. These technology-based regulations apply to all municipal wastewater treatment plants and identify the minimum level of effluent quality attainable by secondary treatment in terms of biochemical oxygen demand (BOD₅), total suspended solids (TSS), and pH, as follows:

- a. BOD and Suspended Solids
 - (1) The 30-day average shall not exceed 30 mg/L
 - (2) The 7-day average shall not exceed 45 mg/L
 - (3) The 30-day average percent removal shall not be less than 85%
- b. pH
 - (1) The pH shall be maintained within the limits of 6.0 to 9.0

In addition, section 122.45 (f) requires the establishment of mass-based effluent limitations for all pollutants limited in Orders, except, 1) for pH, temperature, radiation, or other pollutants which cannot appropriately be expressed by mass, and (2) when applicable standards and limitations are expressed in terms of other units of measure.

2. Applicable Technology-Based Effluent Limitations

a. Summary of Technology-Based Effluent Limitations, Discharge Point 001

- (1) Numeric effluent limitations for BOD₅ and TSS established by USEPA's secondary treatment regulations at 40 CFR 133, including the percent removal requirement, are retained from Order No. R1-2001-59.
- (2) Effluent limitations for settleable solids are also retained from Order No. R1-2001-59. Untreated or improperly treated wastewater can contain high amounts of settleable solids, which can have an adverse effect on aquatic habitat. As the lower Eel River is listed as impaired by sediment, settleable solids effluent limitations should be retained from the previous Order. The monthly average and maximum daily effluent limitations of 0.1 and 0.2 ml/L, respectively, reflect typical standards of performance for secondary treatment facilities and are included as a limitation based on the best professional judgment of Regional Water Board staff.
- (3) Mass effluent limitations for BOD and TSS are required pursuant to 40 CFR 122.45(f) for the purpose of assuring that dilution is not used as a method of achieving the concentration limitations in the permit. Mass-based effluent limitations are technology-based; and for this permit, are based on the facility's design wet weather treatment capacity of 143,000 GPD.

- (4) Effluent limitations for coliform bacteria (23 MPN/100 mL - 30-day median and 230 MPN/100 mL - daily maximum) are retained from the previous Order. These limitations reflect standards adopted by the Department of Health Services for secondary treated recycled water in title 22 of the California Code of Regulations.

C. Water Quality-Based Effluent Limitations (WQBELs)

1. Scope and Authority

Section 301(b) of the CWA and section 122.44(d) require that permits include limitations more stringent than applicable federal technology-based requirements where necessary to achieve applicable water quality standards. Section 122.44(d)(1)(i) mandates that permits include effluent limitations for all pollutants that are or may be discharged at levels that have the reasonable potential to cause or contribute to an exceedance of a water quality standard, including numeric and narrative objectives within a standard. Where reasonable potential has been established for a pollutant, but there is no numeric criterion or objective for the pollutant, water quality-based effluent limitations (WQBELs) must be established using: (1) USEPA criteria guidance under CWA section 304(a), supplemented where necessary by other relevant information; (2) an indicator parameter for the pollutant of concern; or (3) a calculated numeric water quality criterion, such as a proposed state criterion or policy interpreting the state's narrative criterion, supplemented with other relevant information, as provided in section 122.44(d)(1)(vi).

The process for determining reasonable potential and calculating WQBELs when necessary is intended to protect the designated uses of the receiving water as specified in the Basin Plan, and achieve applicable water quality objectives and criteria that are contained in other state plans and policies, or any applicable water quality criteria contained in the CTR and NTR.

2. Applicable Beneficial Uses and Water Quality Criteria and Objectives

- a. **Beneficial Uses.** Applicable beneficial uses excerpted from the Basin Plan are presented in the findings of the Order and Section III.C.1 of this Fact Sheet.
- b. **Basin Plan Objectives.** In addition to the specific water quality objectives indicated above, the Basin Plan contains narrative objectives for color, tastes and odors, floating material, suspended material, settleable material, oil and grease, biostimulatory substances, sediment, turbidity, pH, dissolved oxygen, bacteria, temperature, toxicity, pesticides, chemical constituents, and radioactivity that apply to inland surface waters, enclosed bays, and estuaries, including the Eel River and its tributaries.

- c. State Implementation Policy (SIP), CTR, and NTR. Water quality criteria applicable to the discharge to the Eel River and its tributaries are included in the CTR and NTR, which contain numeric criteria for most of the 126 priority pollutants, and the Basin Plan.

3. Determining the Need for WQBELs

a. Non-Priority Pollutants

(1) pH. Table 3-1 of the Basin Plan establishes water quality objectives for waters within the Eel River Hydrologic Unit of 6.5 – 8.5. The treatment facility’s monitoring data demonstrate that discharges from the facility have a reasonable potential to cause or contribute to exceedances of the applicable water quality objectives for pH. Because these water quality objectives are more stringent than the technology based requirements for pH established at 40 CFR 133, the Order establishes the applicable water quality objectives for pH as end-of-pipe effluent limitations for discharges from the Loleta Community Services District’s wastewater treatment facility. These water quality based pH limitations were also established by the previous Order.

(2) Chlorine Residual. The Basin Plan establishes a narrative water quality objective for toxicity, stating that “[a]ll waters shall be maintained free of toxic substances in concentrations that are toxic to, or that produce detrimental physiological responses in human, plant, animal, or aquatic life.” The Regional Water Board considers any chlorinated discharge as having the reasonable potential to cause or contribute to exceedances of this water quality objective for toxicity, and therefore, the Order establishes effluent limitations for chlorine. USEPA has established the following criteria for chlorine-produced oxidants for protection of fresh water aquatic life. [*Quality Criteria for Water 1986* (The Gold Book, 1986, EPA 440/5-86-001)]

Chronic Criterion	Acute Criterion
0.011 mg/L	0.019 mg/L

The water quality criteria recommended by USEPA are, in effect, non-detectable concentrations by the common amperometric analytical method used for the measurement of chlorine; and therefore, the Regional Water Board is retaining the final effluent limitation for chlorine from the previous Order that requires no detectable level of chlorine in effluent at the point of discharge.

b. Priority Pollutants

(1) The process for determining reasonable potential and calculating WQBELs, when necessary, is intended to protect the designated uses

of the receiving water and achieve applicable water quality objectives and criteria that are contained in applicable plans, policies, or regulations, including the CTR and NTR. Procedures for determining reasonable potential for toxic pollutants and establishing WQBELs for facilities that discharge to inland surface waters of the State are described by the SIP.

(2) By an Order dated April 27, 2001, issued pursuant to CWC Section 13267 (b) the Regional Water Board required the Discharger to monitor its effluent for the CTR toxic pollutants. The Discharger did not comply with the 13267 (b) request, and, therefore, effluent data to determine the need for WQBELs for the priority, toxic pollutants has not been available during reissuance of the District's NPDES permit and Waste Discharge Requirements. Attachment E of this Order requires the Discharger to perform sampling and analyses for priority pollutants in accordance with an aggressive schedule. Attachment E requires the Discharger to collect priority pollutant samples in July and November 2008, and to submit all results by January 1, 2009. Once the data is received, a reasonable potential analysis will be conducted and the permit may be reopened to include any additional WQBELs as determined necessary at that time.

4. WQBEL Calculations

Not applicable at this time.

5. Summary of Water Quality-based Effluent Limitations Discharge Point 001

Table F-4. Summary of Water Quality-based Effluent Limitations

Parameter	Units	Effluent Limitations		
		Average Monthly	Average Weekly	Maximum Daily
Total Residual Chlorine	mg/L	No detectable levels using a minimum limit of 0.1 mg/L		
pH	S.U.	6.5 to 8.5		

6. Whole Effluent Toxicity (WET)

Effluent limits for whole effluent toxicity (WET), acute or chronic, protect the receiving water quality from the aggregate toxic effect of a mixture of pollutants in the effluent. There are two types of WET tests - acute and chronic. An acute toxicity test is conducted over a short time period and measures mortality. A chronic toxicity test is conducted over a longer period of time and may measure mortality, reproduction, and/or growth.

The Basin Plan specifies a narrative objective for toxicity, requiring that all waters be maintained free of toxic substances in concentrations that are lethal to, or produce other detrimental responses in, aquatic organisms.

Detrimental response includes, but is not limited to, decreased growth rate, decreased reproductive success of resident or indicator species, and/or significant alterations in population, community ecology, or receiving water biota. The existing Order contains acute toxicity limitations in accordance with the Basin Plan, which requires that average survival in undiluted effluent for any three consecutive 96-hour static or continuous flow bioassay tests be at least 90 percent, with no single test having less than 70 percent survival.

In addition to the Basin Plan requirements, Section 4 of the SIP states that chronic toxicity effluent limitations are required in Orders for all discharges that will cause, have the reasonable potential to cause, or contribute to chronic toxicity in receiving waters. During the term of Order R1-2001-59, the Discharger reported chronic toxicity in WWTF effluent on three out of eight occasions tested, with the highest toxicity reported at 7.3 TUc. Based on the available information, Regional Water Board staff has determined that discharges from the Loleta WWTF have the reasonable potential to cause or contribute to chronic toxicity in receiving waters. Therefore in accordance with the SIP, this Order establishes a toxicity effluent limitation of 1.0 TUc. Future chronic toxicity results exceeding 1 TUc will be subject to prompt regulatory enforcement.

D. Final Effluent Limitations

1. Satisfaction of Anti-Backsliding Requirements

With the exception of mass-based limitations for BOD and TSS, all effluent limitations in this Order are at least as stringent as the effluent limitations in the previous Order. The mass-based effluent limitations for BOD and suspended solids included in this Order have been modified to be numerically higher than those included in the Discharger's previous Permit. This permit change is

governed by 40 CFR 122.44(l)(1), which provides that relaxations in effluent limitations are permitted where the circumstances justifying permit modification under 40 CFR 122.62 are present. Among the several enumerated grounds is that, as provided in Section 122.62(a)(2), a modification is needed based on new information made available “that was not available at the time of permit issuance... and would have justified the application of different permit conditions at the time of issuance.” Pursuant to 40 CFR 122.45(b), effluent limitations for POTWs are derived for the design flow of the facility. Mass-based effluent limitations in the previous Permit were calculated based on a design flow of 0.1 MGD, but did not take into account peak wet weather flows. The Discharger reports an average wet weather design flow of 0.143 MGD. Based on this new information, this Order correctly calculates mass-based effluent limitations applicable during periods of wet weather flow based on wet weather design flows of 0.143 MGD. Mass-based effluent limitations are to be calculated using the following formula: $8.34 \times Q \times C$, where Q is the flow measured on the day of weekly sampling, C is the weekly concentration-based effluent limitation, and 8.34 is a conversion factor.

2. Satisfaction of Antidegradation Policy

Provisions of the Order are consistent with applicable anti-degradation policy expressed by NPDES regulations at 40 CFR 131.12 and by State Water Board Resolution No. 68-16. The activities allowed in accordance with these waste discharge requirements apply to an existing facility and although mass limitations have been altered to more accurately reflect the facility design flow, it is not anticipated that this change will result in an increased volume or concentration of waste beyond that which was permitted to discharge in accordance with the previous Order. Further, this Order permits only those discharges of waste that have received complete secondary treatment. Discharges from the Facility will be required to maintain protection of the beneficial uses of the receiving water and comply with applicable provisions of the Basin Plan. Limitations and conditions of the Order assure protection and maintenance of the existing quality of receiving waters.

3. Stringency of Requirements for Individual Pollutants

This Order contains both technology-based and water quality-based effluent limitations for individual pollutants. The technology-based effluent limitations consist of restrictions on BOD, TSS, settleable solids and coliform bacteria. Restrictions on these pollutants are discussed in Section IV.B.2 of this Fact Sheet. This Order’s technology-based pollutant restrictions implement the minimum, applicable federal technology-based requirements. In addition, this Order contains effluent limitations more stringent than the minimum, federal technology-based requirements. Specifically, this Order includes effluent limitations for chlorine and pH that are more stringent than applicable federal technology-based requirements, but that are nonetheless necessary to meet numeric objectives or protect beneficial uses set out in the Basin Plan. The

rationale for including these limitations is explained in section IV.C.3 of this Fact Sheet.

Summary of Final Effluent Limitations Discharge Point 001

Table F-5. Effluent Limitations – Discharge Point 001

Parameter	Units	Effluent Limitations		
		Average Monthly ^a	Average Weekly	Maximum Daily
BOD ₅	mg/L	30	45	60
	lbs/day	43	64	86
TSS	mg/L	30	45	60
	lbs/day	43	64	86
Settleable Solids	ml/L	0.1	--	0.2
pH	standard units	Not less than 6.5 nor greater than 8.5		
Total Coliform Bacteria	MPN/100 mL	23	--	230
Chronic Toxicity	TUc	1.0	--	--
Total Residual Chlorine	mg/L	No detectable levels using a minimum detection limit of 0.1 mg/L		

1. **Percent Removal:** The average monthly percent removal of BOD₅ and TSS, by weight, shall not be less than 85 percent. Percent removal shall be determined from the 30-day average value of influent wastewater concentration in comparison to the 30-day average value of effluent concentration for the same constituent over the same time period. [40 CFR 133.101(j)].
2. **Total residual chlorine** concentration shall be maintained at 1.5 mg/L at the end of the disinfection process; and, using a minimum detection level of 0.1 mg/L, there shall be no detectable level of chlorine in effluent at Discharge Point 001.
3. **Acute Toxicity:** As measured at Monitoring Location M-001, there shall be no acute toxicity in the effluent when discharging to the wetland, which is tributary to the Eel River. The Discharger will be considered in compliance with this limitation when the survival of aquatic organisms in a 96-hour bioassay, using undiluted effluent, complies with the following:
 - (1) Minimum for any one bioassay: 70 percent survival, and
 - (2) Median for any three or more consecutive bioassays: at least 90 percent survival.

E. Interim Effluent Limitations

The Order does not establish interim effluent limitations and schedules for compliance with final limitations. Interim limitations are authorized only in certain

circumstances when immediate compliance with newly established final water quality based limitations is not feasible. The draft permit does not include any newly established water quality based limitations; therefore interim limitations are not applicable.

F. Land Discharge Specifications

This section of the standardized permit is not applicable to the Loleta Community Services District.

G. Reclamation Specifications

This section of the standardized permit is not applicable to the Loleta Community Services District.

V. RATIONALE FOR RECEIVING WATER LIMITATIONS

A. Surface Water

CWA section 303(a-c) requires states to adopt water quality standards, including criteria where they are necessary to protect beneficial uses. The Regional Water Board adopted water quality criteria as water quality objectives in the Basin Plan.

The Basin Plan states that “[t]he numerical and narrative water quality objectives define the least stringent standards that the Regional [Water] Board will apply to regional waters in order to protect the beneficial uses.” The Basin Plan includes numeric and narrative water quality objectives for various beneficial uses and water bodies. This Order contains Receiving Surface Water Limitations based on the Basin Plan numerical and narrative water quality objectives for biostimulatory substances, bacteria, chemical constituents, color, dissolved oxygen, floating material, oil and grease, pH, pesticides, radioactivity, sediment, settleable material, suspended material, tastes and odors, temperature, toxicity, and turbidity.

B. Groundwater

1. The beneficial uses of the underlying ground water are municipal and domestic supply, industrial service supply, industrial process supply, and agricultural supply.
2. Basin Plan water quality objectives include narrative objectives for chemical constituents, tastes and odors, bacteria and radioactivity. The chemical constituent objective states groundwater shall not contain chemical constituents in excess of the limits specified in Code of California Regulations, title 22, section 64435, Tables 2 and 3, and section 64444.5 (Table 5) and listed in Table 3-2 of the Basin Plan. Numerical objectives for certain constituents for individual groundwaters are contained in Table 3-1 of the Basin Plan. The tastes and odors objective prohibits taste- or odor-producing substances in concentrations that cause nuisance or adversely affect beneficial uses. The bacteria objective prohibits coliform organisms at or above 1.1 MPN/100 ml.

3. Groundwater limitations are required to protect the beneficial uses of the underlying groundwater.

VI. RATIONALE FOR MONITORING AND REPORTING REQUIREMENTS

Section 122.48 requires that all NPDES permits specify requirements for recording and reporting monitoring results. Water Code sections 13267 and 13383 authorizes the Regional Water Board to require technical and monitoring reports. The Monitoring and Reporting Program (MRP), Attachment E of this Order, establishes monitoring and reporting requirements to implement federal and state requirements.

The following provides the rationale for the monitoring and reporting requirements contained in the MRP for this facility.

A. Influent Monitoring

Influent wastewater monitoring for the WWTP is required in this Order. NPDES regulations at section 133 define secondary treatment to include 85 percent removal of BOD₅ and TSS during treatment. Monitoring of influent for these pollutant parameters, in addition to effluent, is required to monitor compliance with this standard of performance. Influent monitoring requirements are contained in Attachment E, Section III.A, of the MRP.

B. Effluent Monitoring

Pursuant to the requirements of section 122.44(i)(2) effluent monitoring is required for all constituents with effluent limitations. In addition, routine monitoring of the effluent and the receiving water for priority pollutants is required to periodically assess the reasonable potential of the discharge to cause or contribute to an exceedance of CTR criteria. The frequency of routine monitoring for priority pollutants is determined using best professional judgment, with consideration given to the nature of the individual pollutant, the past record of detections in the effluent, and likelihood of the presence of the pollutant in the discharge. Effluent monitoring requirements are contained in Attachment E, Section IV of the MRP.

Varying concentrations of ammonia nitrogen, unionized ammonia, nitrate nitrogen, and total phosphorus are present in discharges from municipal wastewater plants. These substances, alone and in combination, can cause nuisance aquatic growth and/or be toxic to human or aquatic health. The Basin Plan prohibits biostimulatory substances in concentrations that promote aquatic growth to the extent that such growth causes nuisance or adversely affects beneficial uses. The Basin Plan further requires that (1) all receiving waters be maintained free of toxic substances in concentrations that are toxic to or that produce detrimental physiological responses in human, plant, animal, or aquatic life. To further characterize discharges from the Loleta Community Service District wastewater treatment facility and to determine if reasonable potential exists to exceed water quality criteria, requiring development of effluent limitations, effluent monitoring requirements contained in Attachment E, Section IV of the MRP include routine monitoring for ammonia nitrogen, unionized ammonia, and nitrate nitrogen.

C. Whole Effluent Toxicity Testing Requirements

1. Acute Toxicity

- a. **Rationale.** Monthly 96-hour bioassay testing is required to demonstrate compliance with the effluent limitation for acute toxicity (Effluent Limitations IV.A.1.d).
- b. **Test Frequency** - The USEPA recommends monthly WET testing for facilities listed as “major facilities” and quarterly testing for “minor facilities.” (*Regions 9 & 10 Guidance for Implementing Whole Effluent Toxicity Testing Programs*, USEPA, 1996) If WET limits are required, federal regulations (40 CFR 122.44(i)(2) requires a minimum frequency of annual. For small municipalities, not designated as “major facilities,” the USEPA recommends at least one suite of tests to be conducted during the lifetime of the permit and prior to reissuance in order to assess reasonable potential.

This Order specifies routine monitoring twice annually for acute toxicity in order to ensure compliance with the Basin Plan’s narrative toxicity objective.
- c. **Sample Location** – Representative effluent samples shall be collected at Monitoring Location M-001, when discharging to surface water.
- d. **Sample Type** – This Order specifies a 96-hour static renewal or static non-renewal test as described in *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms* (USEPA Report No. EPA 600/4-90-027F, 4th edition or subsequent editions. Upon request, other methods may be approved by the Regional Water Board Executive Officer.
- e. **Test Species** – This Order requires the Discharger to conduct acute toxicity tests with the water flea, *Ceriodaphnia dubia*, and the rainbow trout, *Onchorynchus mykiss*, for at least two suites of tests. For the first two suites of acute toxicity tests, the Discharger will determine the most sensitive aquatic species and continue to monitor with the most sensitive species. At least once every five years, the Discharger will re-screen to re-confirm the most sensitive species for the acute toxicity test.
- f. **Test Method** – The presence of acute toxicity shall be estimated as specified in effluent limitation IV.A.1.d. and shall be consistent with *Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms* (USEPA Report No. EPA 600/4-90-027F, 4th edition or subsequent editions), or other methods approved by the Executive Officer.

- g. Dilution Water** – Acute toxicity tests shall be conducted using undiluted effluent.
- h. Accelerated Monitoring** - The provision requires accelerated acute toxicity testing when a regular acute toxicity test result exceeds the single sample effluent limitation. The purpose of accelerated monitoring is to determine, in an expedient manner, whether there is a pattern of toxicity before requiring the implementation of a TRE. Under this provision, the Discharger is required to conduct at least two additional samples, one within 14 days, and one within 21 days of receiving the initial sample result. If any of the additional samples do not comply with the three sample median minimum limitation (90 percent survival) using that sample result and the two previous sample results, the Discharger shall initiate a TRE. If any test of a sample is ruled invalid, the Discharger will re-sample within 7 days following notification of test invalidation

2. Chronic Toxicity

- a. Rationale.** Chronic whole effluent toxicity testing is required twice annually in order to demonstrate compliance with the Basin Plan's narrative toxicity objective.
- b. Test Frequency** - USEPA has no fixed guidance on the establishment of monitoring frequency, but recommends monthly WET testing for facilities listed as "major facilities" and quarterly testing for "minor facilities" during the first year of WET testing in order to develop sufficient data to conduct a reasonable potential analysis. USEPA further recommends that a reduction in sampling frequency is appropriate if no individual toxicity test exceeds the WET limit or trigger. If WET limits are required, federal regulations (40 CFR 122.44(i)(2) requires a minimum frequency of annual. For small municipalities, not designated as "major facilities," the USEPA recommends at least one suite of tests to be conducted during the lifetime of the permit and prior to reissuance in order to assess reasonable potential. (Regions 9 & 10 Guidance for Implementing Whole Effluent Toxicity Testing Programs, USEPA, 1996)

The Discharger has shown reasonable potential to exceed criteria for the protection of beneficial uses. Therefore this Order implements new effluent limitations for chronic toxicity and maintains routine monitoring for chronic toxicity two times per year from the previous Order.

- c. Sample Location** - Representative effluent samples shall be collected at Monitoring Location M-001, when discharging to surface water.

- d. **Sample Type** – The Discharger shall collect grab samples of storage pond effluent discharged to Discharge Point 001 at Monitoring Location M-001 for critical life stage toxicity testing as indicated in this Order. For toxicity tests requiring renewals, grab samples collected on appropriate days are required as mandated by the methods.
- e. **Test Species** – This Order requires the Discharger to conduct short-term tests with the water flea, *Ceriodaphnia dubia* (survival and reproduction test), the fathead minnow, *Pimephales promelas* (larval survival and growth test), and the green alga, *Selenastrum capricornutum* (growth test). Initially, the Discharger is required to determine the most sensitive test species and monitor the discharge for chronic toxicity using that species for no more than five years, whereupon, the Discharger will repeat the screening procedure to confirm the most sensitive species. If reasonable potential to exceed the narrative water quality objective is found to exist, the Permit may be reopened to include a chronic toxicity limitation, as appropriate. The Basin Plan does not allow a mixing zone for this discharge; therefore, reasonable potential will be based on results of chronic toxicity tests from samples collected at the end of the pipe.
- f. **Test Method** – The presence of chronic toxicity shall be estimated as specified in and shall be consistent with *Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms*, Fourth Edition, EPA-821-R-02-013, October 2002.
- g. **Dilution water** - Control and dilution water should be receiving water at a location immediately upstream and outside the influent of the outfall for all test methods except the short-term chronic *Selenastrum capricornutum* test. For the *Selenastrum capricornutum* test method, synthetic laboratory water with a hardness similar to the receiving water shall be used as the control and dilution water. Laboratory water may be substituted for receiving water, as described in the manual, upon approval by the Regional Water Board Executive Officer
- h. **Accelerated Monitoring** - Guidance regarding accelerated monitoring and TRE initiation is provided in the Technical Support Document for Water Quality-based Toxics Control, EPA/505/2-90-001, March 1991 (TSD). The TSD at page 118 states, “EPA recommends if toxicity is repeatedly or periodically present at levels above effluent limits more than 20 percent of the time, a TRE should be required.” If there is adequate evidence of a pattern of effluent toxicity (i.e. toxicity present exceeding the effluent limitation more than 20 percent of the time), the Regional Water Board Executive Officer will require that the Discharger initiate a TRE. The TRE will include follow-up monitoring requirements to assure toxicity has been mitigated. Due to seasonality of the discharge to surface water,

the TRE and associated follow-up monitoring should be performed in a timely manner, preferably taking no more than 2 to 3 months to complete.

- i. **Monitoring Trigger.** - A numeric toxicity monitoring trigger of > 1.0 TUc (where TUc = $100/\text{NOEC}$) is applied in the provision, because this Order does not allow any dilution for the chronic condition. Therefore, a TRE is triggered when the effluent exhibits a pattern of toxicity at 100% effluent.

D. Receiving Water Monitoring

1. Surface Water.

Monitoring and Reporting Program Order R1-2008-0001 requires routine visual monitoring of the receiving water for floatables and discoloration, as well as monitoring for the CTR priority pollutants one time during the term of the Order. Monitoring for the priority pollutants will provide data required by the SIP for determining reasonable potential (whether effluent limitations are necessary to protect water quality) and for calculating water quality based effluent limitations, if necessary. Hardness of the receiving water must be monitored concurrently with the priority pollutants to determine applicable water quality objectives for hardness-dependent metals.

2. Groundwater.

Groundwater monitoring is not required in conjunction with Monitoring and Reporting Program Order R1-2008-0001. Based on results of the special studies required by section VI.C.2.a - b of the Order, however, routine groundwater monitoring may be required.

C. Other Monitoring Requirements

This section does not apply to the Loleta Community Services District wastewater treatment facility.

VII. RATIONALE FOR PROVISIONS

A. Standard Provisions

Standard Provisions, which apply to all NPDES permits in accordance with section 122.41, and additional conditions applicable to specified categories of permits in accordance with section 122.42, are provided in Attachment D. The discharger must comply with all standard provisions and with those additional conditions that are applicable under section 122.42.

Section 122.41(a)(1) and (b) through (n) establish conditions that apply to all State-issued NPDES permits. These conditions must be incorporated into the permits either expressly or by reference. If incorporated by reference, a specific citation to the regulations must be included in the Order. Section 123.25(a)(12) allows the state to omit or modify conditions to impose more stringent requirements. In accordance with section 123.25, this Order omits federal conditions that address

enforcement authority specified in sections 122.41(j)(5) and (k)(2) because the enforcement authority under the Water Code is more stringent. In lieu of these conditions, this Order incorporates by reference Water Code section 13387(e).

C. Special Provisions

1. Reopener Provisions

Provision VI.C.1 contains a reopener provision. The Regional Water Board may reopen the Order to modify Order conditions and requirements. Causes for modifications include demonstration that the Discharger is causing or significantly contributing to adverse impacts to water quality and/or beneficial uses of receiving waters; new interpretation of water quality objectives of the Basin Plan; or if effluent monitoring or other new information demonstrates reasonable potential for any pollutant or pollutant parameter with applicable water criteria established by the NTR, CTR, or Basin Plan.

2. Special Studies and Additional Monitoring Requirements

a. Discharge Location Characteristics Study (Section VI.C.2.a.)

The Basin Plan establishes a prohibition against discharges to the Eel River and its tributaries between May 15 and September 30. To comply with this prohibition, in the past, the Regional Water Board has issued permits allowing seasonal and year-round discharges to percolation and/or treatment ponds adjacent or nearby to the Eel River and its tributaries. Such discharges have typically been viewed as discharges to land and were not held to the same standards as discharges directly to surface waters. Based upon Regional Water Board staff's best professional judgment, recent evaluation of the receiving water associated with the Loleta WWTF indicates that the primary function of the area may be wetland habitat and therefore discharges to this location could constitute a direct discharge to waters of the U.S., subject to all Basin Plan requirements, NPDES permitting requirements pursuant to section 301 of the CWA, as well as to all waste discharge requirements established by the Regional Water Board pursuant to Water Code section 13263. In order to comply with applicable regulations, including the Basin Plan's summer discharge prohibition to the Eel River and its tributaries, the Discharger will need to evaluate the characteristics of the discharge location and implement actions necessary, if any, to comply with applicable requirements. It is appropriate to provide a reasonable time schedule for the proper evaluation, identification of possible alternatives and implementation for any necessary modifications. The special study requirements under section VI.C.2.a. require the Discharger to show that either the discharge location is not a wetland or other area constituting a direct discharge to surface water during the prohibition season, or requires the Discharger to develop an alternate disposal method during the prohibition season that complies with Basin Plan requirements.

b. Effluent to Receiving Water Discharge Ratio Study (Section VI.C.2.b.)

Discharge Point No. 001 currently discharges to a wetland that is tributary to the Eel River. The Implementation Plan for the North Coast Basin contained in the Basin Plan on page 4-1, prohibits discharges to the Eel River and its tributaries during periods when the waste discharge flow is greater than one percent of the receiving stream's flow. At this time, little if any information has been documented showing the actual flows in the wetland. However, given the hydrology of the location, it is uncertain if the one percent criteria for discharge is being met. In order to comply with applicable regulations, the Discharger shall provide documentation indicating that the discharge is compliance with the Basin Plan's discharge rate requirement, or appropriate for an exception to the Basin Plan requirement or implement modifications that will result in Basin Plan compliance. It is appropriate to provide a reasonable time schedule for the proper evaluation of existing discharges, possible alternatives, and implementation for any necessary modifications.

c. Toxicity Reduction Evaluations (Special Provision VI.C.2.c)

The SIP requires the use of short-term chronic toxicity tests to determine compliance with the narrative toxicity objectives for aquatic life in the Basin Plan. Attachment E of this Order requires chronic toxicity monitoring for demonstration of compliance with the narrative toxicity objective. In addition to WET monitoring, Special Provisions VI.C.2.b. requires the Discharger to submit to the Regional Water Board an Initial Investigative TRE Work Plan for approval by the Executive Officer, to ensure the Discharger has a plan to immediately move forward with the initial tiers of a TRE, in the event effluent toxicity is encountered in the future. The TRE is initiated by evidence of a pattern of toxicity demonstrated exceeding the effluent limitation more than 20 percent of the time.

TRE Guidance. The Discharger is required to prepare a TRE Work Plan in accordance with USEPA guidance. Numerous guidance documents are available, as identified below:

1. Toxicity Reduction Evaluation Guidance for Municipal Wastewater Treatment Plants, (EPA/833B-99/002), August 1999.
2. Generalized Methodology for Conducting Industrial TREs, (EPA/600/2-88/070), April 1989.
3. Methods for Aquatic Toxicity Identification Evaluations: Phase I Toxicity Characterization Procedures, Second Edition, EPA 600/6-91/005F, February 1991.
4. Toxicity Identification Evaluation: Characterization of Chronically Toxic Effluents, Phase I, EPA 600/6-91/005F, May 1992.

5. Methods for Aquatic Toxicity Identification Evaluations: Phase II Toxicity Identification Procedures for Samples Exhibiting acute and Chronic Toxicity, Second Edition, EPA 600/R-92/080, September 1993.
6. Methods for Aquatic Toxicity Identification Evaluations: Phase III Toxicity Confirmation Procedures for Samples Exhibiting Acute and Chronic Toxicity, Second Edition, EPA 600/R-92/081, September 1993.
7. Methods for Measuring the Acute Toxicity of Effluents and Receiving Waters to Freshwater and Marine Organisms, Fifth Edition, EPA-821-R-02-012, October 2002.
8. Short-term Methods for Estimating the Chronic Toxicity of Effluents and Receiving Waters to Freshwater Organisms, Fourth Edition, EPA-821-R-02-013, October 2002.
9. Technical Support Document for Water Quality-based Toxics Control, EPA/505/2-90-001, March 1991

3. Best Management Practices and Pollution Prevention

Pollution Minimization Plan. Provision VI.C.3 is included in this Order as required by Section 2.4.5 of the SIP. The Regional Water Board includes standard provisions in all NPDES permits requiring development of a Pollutant Minimization Program when there is evidence that a toxic pollutant is present in effluent at a concentration greater than an applicable effluent limitation.

4. Construction, Operation, and Maintenance Specifications

40 CFR 122.41 (e) requires proper operation and maintenance of permitted wastewater systems and related facilities to achieve compliance with permit conditions. An up-to-date operation and maintenance manual, as required by Section VI.C.4.a. of the permit, is an integral part of a well-operated and maintained facility.

5. Special Provisions for Municipal Facilities (POTWs Only)

- a. Wastewater Collection System (Provision VI.C.5.a.)
Statewide General WDRs for Sanitary Sewer Systems.

The State Water Board issued General Waste Discharge Requirements for Sanitary Sewer Systems, Water Quality Order No. 2006-0003-DWQ (General Order) on May 2, 2006. The General Order requires public agencies that own or operate sanitary sewer systems with greater than one mile of pipes or sewer lines to enroll for coverage under the General Order. The General Order requires agencies to develop sanitary sewer management plans (SSMPs) and report all sanitary sewer overflows (SSOs), among other requirements and prohibitions.

Further, the General Order contains requirements for operation and maintenance of collection systems and for reporting and mitigating sanitary sewer overflows. Inasmuch that the Discharger's collection system is part of the system that is subject to this Order, certain standard provisions are applicable as specified in Provisions, section VI.C.5. For instance, the 24-hour reporting requirements in this Order are not included in the General Order. The Discharger must comply with both the General Order and this Order. The Discharger and public agencies that are discharging wastewater into the facility were required to obtain enrollment for regulation under the General Order by December 1, 2006.

All NPDES permits for POTWs currently include federally required standard conditions to mitigate discharges (40 CFR 122.41(d)), to report non-compliance (40 CFR 122.41(1)(6) and (7)), and to properly operate and maintain facilities (40 CFR 122.41(e)). This provision is consistent with these federal requirements.

- b. Sanitary Sewer Overflows (Provision VI.C.5.b.)
Order No. 2006-0003-DWQ includes a Reporting Program that requires the Discharger, beginning May 2, 2007, to report SSOs to an online SSO database administered through the California Integrated Water Quality System (CIWQS) and telefax reporting when the online SSO database is not available. The goal of these provisions is to ensure appropriate and timely response by the Discharger to sanitary sewer overflows to protect public health and water quality.

The Order also includes reporting provisions (Provision VI.C.5.c.) and Attachment D subsections I.C., I.D., V.E. and V.H. to ensure adequate and timely notifications are made to the Regional Water Board and appropriate local, state, and federal authorities.

The Order establishes oral reporting limits for SSOs. SSOs less than 100 gallons are not required to be reported orally, while SSOs greater than or equal to 100 gallons must be reported orally to the Regional Water Board. Inevitably, minor amounts of untreated or partially treated wastewater may escape during carefully executed routine operation and maintenance activities. This Order establishes a reasonable minimum volume threshold for oral notifications. It has been the experience of Regional Water Board staff that SSOs to land that are less than 100 gallons are not likely to have a material effect on the environment or public health. Larger volumes in excess of 100 gallons may indicate a lack of proper operation and maintenance and due care, and pose more of a threat to the environment or public health. All SSOs, regardless of volume, must be electronically reported pursuant to State Water Board Order No. 2006-0003-DWQ,

Statewide General Waste Discharge Requirements for Sanitary Sewer Systems.

c. Source Control Provisions (Provision VI.C.5.c.)

Because the design flow of the Facility is less than 5.0 mgd, the Order does not require the Discharger to develop a pretreatment program that conforms to federal regulations. Due to the identification of the reasonable potential for the priority pollutants copper, chlorodibromomethane, and dichlorobromomethane in the discharge, the proposed Order includes requirements for the Discharger to implement a source identification and reduction program. The Discharger's source identification and reduction program will need to address only those pollutants that continue to be detected at levels that trigger reasonable potential.

In addition, the Regional Water Board recognizes that some form of source control is prudent to ensure the efficient operation of the treatment plant, the safety of operations staff, and to ensure that pollutants do not pass through the treatment facility to impair the beneficial uses of the receiving water. The proposed Order includes prohibitions for the discharge of pollutants that may interfere, pass through, or be incompatible with treatment operations, interfere with the use or disposal of sludge, or pose a health hazard to personnel.

d. Sludge Disposal and Handling (Provision VI.C.5.d. and e.)

The disposal or reuse of wastewater treatment screenings, sludges, or other solids removed from the liquid waste stream is regulated by Parts 257, 258, 501, and 503, the State Water Board promulgated provisions of title 27 of the California Code of Regulations, and with the Water Quality Control Plan for Ocean Waters of California (California Ocean Plan). The Discharger has indicated that that all screenings, sludges, and solids removed from the liquid waste stream are currently disposed of at a municipal solid waste landfill in accordance with all applicable regulations.

e. Operator Certification (Provision VI.C.5.f.)

This provision requires the WWTP to be operated by supervisors and operators who are certified as required by title 23, California Code of Regulations, section 3680.

f. Adequate Capacity (Provision VI.C.5.g.)

The goal of this provision is to ensure appropriate and timely planning by the Discharger to ensure adequate capacity for the protection of public health and water quality.

6. Other Special Provisions

The Order requires the Discharger to seek authorization to discharge under and meet the requirements of the State Water Board's Water Quality Order 97-03-DWQ, NPDES General Permit No. CAS000001, *Waste Discharge Requirements for Discharges of Storm Water Associated with Industrial Activities Excluding Construction Activities*, if applicable. Coverage under the general permit is required for wastewater treatment facilities that treat domestic sewage, with a design flow of 1.0 MGD or more, or those required to have an approved pretreatment program pursuant to 40 CFR part 403.

7. Compliance Schedules

This section does not apply the Loleta WWTF at this time.

VIII. PUBLIC PARTICIPATION

The California Regional Water Quality Control Board, North Coast Region (Regional Water Board) is considering the issuance of waste discharge requirements (WDRs) that will serve as a National Pollutant Discharge Elimination System (NPDES) permit for the Loleta Community Services District. As a step in the WDR adoption process, the Regional Water Board staff has developed tentative WDRs. The Regional Water Board encourages public participation in the WDR adoption process.

A. Notification of Interested Parties

The Regional Water Board has notified the Discharger and interested agencies and persons of its intent to prescribe waste discharge requirements for the discharge and has provided them with an opportunity to submit their written comments and recommendations. Notification was provided through posting on the Regional Water Board's Internet site at:

<http://www.waterboards.ca.gov/northcoast/agenda/pending.html> and through publication in the Eureka Times-Standard on December 28, 2007.

B. Written Comments

The staff determinations are tentative. Interested persons are invited to submit written comments concerning these tentative WDRs. Comments must be submitted either in person or by mail to the Executive Office at the Regional Water Board at the address above on the cover page of this Order.

To be fully responded to by staff and considered by the Regional Water Board, written comments should be received at the Regional Water Board offices by 5:00 p.m. on January 27, 2008.

C. Public Hearing

The Regional Water Board will hold a public hearing on the tentative WDRs during its regular Board meeting on the following date and time and at the following location:

Date: March 6, 2008
Time: 9:00 AM
Location: North Coast Regional Water Quality Control Board
5550 Skylane Boulevard, Suite A
Santa Rosa, California 95403

Interested persons are invited to attend. At the public hearing, the Regional Water Board will hear testimony, if any, pertinent to the discharge, WDRs, and permit. Oral testimony will be heard; however, for accuracy of the record, important testimony should be in writing.

Please be aware that dates and venues may change. Our Web address is <http://www.waterboards.ca.gov/northcoast/contact.html> where you can access the current agenda for changes in dates and locations.

D. Waste Discharge Requirements Petitions

Any aggrieved person may petition the State Water Resources Control Board to review the decision of the Regional Water Board regarding the final WDRs. The petition must be submitted within 30 days of the Regional Water Board's action to the following address:

State Water Resources Control Board
Office of Chief Counsel
P.O. Box 100, 1001 I Street
Sacramento, CA 95812-0100

E. Information and Copying

The Report of Waste Discharge (RWD), related documents, tentative effluent limitations and special provisions, comments received, and other information are on file and may be inspected at the address above at any time between 8:30 a.m. and 4:45 p.m., Monday through Friday. Copying of documents may be arranged through the Regional Water Board by calling (707) 576-2220.

F. Register of Interested Persons

Any person interested in being placed on the mailing list for information regarding the WDRs and NPDES permit should contact the Regional Water Board, reference this facility, and provide a name, address, and phone number.

G. Additional Information

Requests for additional information or questions regarding this order should be directed to Lisa Bernard at (707) 576-2677 or lbernard@waterboards.ca.gov.